

DESARROLLO DE COSTOS PRELIMINARES CON EL SOFTWARE CAPDEWORKS

Para ayudar a la evaluación comparativa de alternativas de tratamiento de la PTAR Canoas en la fase conceptual del proyecto, CDM Smith utilizó el software CAPDEWorks, de la Compañía Hydromantis.

El CAPDEWorks fue inspirado en una herramienta que fue desarrollada por el Cuerpo de Ingenieros de los Estados Unidos para la Agencia de Protección Ambiental del mismo país en la década de los 70s, cuando los Estados Unidos se encontraban en la era de la ejecución de los proyectos de saneamiento en todo su territorio. Por esto y buscando facilitar el análisis de alternativas en el proceso de planeación de PTARs, el Cuerpo de Ingenieros desarrollo el software CAPDET (por sus siglas en inglés Computer Assisted Procedure for the Design and Evaluation of Wastewater Treatment Systems).

EL CAPDET está basado técnicas de diseño aprobadas en ese entonces, en conjunto con el establecimiento de curvas de costos, y permitía un desarrollo de costos paramétrico.

El CAPDEWorks de Hydromantis recopiló la idea inicial y le añadió nuevas técnicas de estimación de costos, así como la flexibilidad de utilizar estimación e costos paramétricos o por unidades de proceso. Además, le añadió la gran flexibilidad de poder modificar los costos para reflejar condiciones locales, y permitió la utilización de índices de costos para reflejar el cambio de los costos a través del tiempo, entre muchas otras cosas.

Debido a que uno de los objetivo del Producto 3 en este Contrato es el de la evaluación de alternativas de tratamiento, y teniendo en cuenta todo lo previamente dicho, CDM Smith consideró que la utilización de esta herramienta resulta muy beneficiosa para ayudar a la EAB a tomar decisiones en esta etapa.

INFORMACIÓN DE ENTRADA AL CAPDEWORKS.

Parámetros de entrada

1. Caudal y caracterización del agua.

Se utilizó la caracterización promedio del agua residual estimada para la PTAR Canoas. (Ver sección de este informe)

Como flujo máximo se especificó el caudal máximo hidráulico que soportará la planta. (32 m³/s)

2. Valores unitarios, índices y otros parámetros de entrada.

El Cuadro A-1 contiene el resumen de todos valores unitarios, índices y otros parámetros de entrada utilizados en el CAPDEWorks.

Cuadro A-1 – Valores unitarios, índices y otros parámetros de entrada CAPDEWorks

Appendices		
Unit Costs		
Description	Value	Units
Building Cost	\$46.50	\$/sqft
Excavation	\$0.42	\$/cuft
Wall Concrete	\$12.40	\$/cuft
Slab Concrete	\$11.00	\$/cuft
Crane Rental	\$333.00	\$/hr
Canopy Roof	\$6.50	\$/sqft
Electricity	\$0.20	\$/kWh
Hand Rail	\$11.30	\$/ft
Land Costs	\$0.00	\$/acre
Construction Labor Rate	\$8.00	\$/hr
Operator Labor Rate	\$8.00	\$/hr
Administration Labor Rate ¹	\$5.00	\$/hr
Laboratory Labor Rate	\$8.00	\$/hr
Hydrated Lime-[Ca(OH)2]	\$0.18	\$/lb
Al2(SO4)3*14H2O	\$0.27	\$/lb
Ferric Chloride	\$0.27	\$/lb
Polymer	\$2.27	\$/lb
Interest Rate		4 %
Construction Period		3 years
Operating Life of Plant		40 years
Engineering Design Fee		15 %
Miscellaneous ²		21 %
Administration/Legal		2 %
Inspection		2 %
Contingency		10 %
Technical		2 %
Profit and Overhead		15 %
Cost Indices		
Description	Value	Units
Marshall and Swift Index ³		1500
Engineering News Records Cost Index ⁴		13400
Pipe Cost Index ⁵		739
User Cost Index 1		100
User Cost Index 2		100
User Cost Index 3		100
Additional Site-Specific Costs		
Description	Value	Units
Override Foundation Estimate	TRUE	
	\$0.00	\$
Override Effluent Pumping Estimate	TRUE	
	\$0.00	\$
Override Outfall Diffuser Estimate	TRUE	
	\$0.00	\$
Override Mobilization Estimate	FALSE	
	\$0.00	\$
Override Site Preparation Estimate	FALSE	
	\$0.00	\$
Override Site Electrical Estimate	FALSE	
	\$0.00	\$
Override Yard Piping Estimate	FALSE	
	\$0.00	\$
Override Instrumentation and Control Estimate	FALSE	
	\$0.00	\$
Override Lab and Administration Building Estimate	FALSE	
	\$0.00	\$
Override Raw Sewage Pumping Estimate	TRUE	
	\$0.00	\$
Override Outfall Estimate	TRUE	
	\$0.00	\$

1. Índice Marshall and Swift. Este índice normalmente utilizado en la industria petroquímica de los Estados Unidos, es compuesto de dos componentes principales - media del costo de equipos de la industria de procesos industriales y la media de los equipos industriales generales. equipos de toda la industria media. Algunas industrias consideradas en el promedio del equipo procesos industriales incluyen los productos químicos, productos derivados del petróleo, caucho y papel. El promedio de toda la industria abarca 47 tipos diferentes de industriales, comerciales y equipamiento de la vivienda. Este índice es publicado por la revista Chemical Engineering. SE utilizó el valor por defecto de CAPDETWorks.
2. Índice ENR. Este índice está compuesto por los índices de proyectos de construcción generales e incluye precios de cantidades fijas de acero estructural, cemento, madera, y mano de obra. Es comparable en Colombia al índice Construdata.
3. Índice Pipe Cost. Este índice es también publicado por Chemical Engineering y hace un seguimiento a los precios de las tuberías utilizados en la industria química, que son generalmente aceptados en la industria de infraestructura. Se utilizó el valor por defecto.
4. Costos Específicos del sitio Adicionales. Estos costos permiten al usuario de ingresar información de costos que solo es adecuada a cada sitio específico. Para el Caso de Canoas no se tuvieron en cuenta estos ítems, dado que se considera que todas las alternativas son similares desde estos puntos de vista.

Procesos y Operaciones unitarias

El Cuadro A-2 Contiene el resumen de los datos de entrada a CAPDETWorks. Cabe anotar que los datos que fueron calculados por los algoritmos del CAPDETWorks son alimentados por los parámetros de entrada dados anteriormente, por lo que concuerdan con las alternativas evaluadas.

Cuadro A-2 – Detalle de Datos de Entrada al CAPDETWorks

Unidad o proceso	Subproceso	Predimensionamiento de estructuras		Costo de capital utilizado		Costo de operación utilizado	
		CAPDETWorks	Diseño del consultor	Paramétrico de CAPDETWorks	Costo de proceso del consultor	Paramétrico de CAPDETWorks	Costo de proceso del consultor
Línea de Líquidos							
Tratamiento preliminar		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Tratamiento primario			<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Coagulación y floculación			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Tratamiento secundario							
	Alimentación escalonada (lodos Activados)		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
	Filtros percoladores		<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>	
	BAFs		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		
Tratamiento terciario							
	Alimentación escalonada (BNR)		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
	BAFs		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
	Filtros desnitrificadores		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Desinfección			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Línea de sólidos							
Espesamiento							
	Espesador de gravedad		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>
	Mesa espesadora de gravedad		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
	Pre-deshidratación por centrifugas (alternativa THP)		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Digestión anaeróbica							
	Sistema de Hidrólisis Térmica (THP)		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
	Digestores anaeróbicos mesofílicos		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Deshidratación			<input checked="" type="checkbox"/>				
	Filtros prensa de banda		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
	Centrifugas		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Disposición de Lodos			<input checked="" type="checkbox"/>				
	Disposición en relleno sanitario	<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Otros							
Aprovechamiento del biogás			<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>


La determinación de costos por parte del consultor para los procesos notados anteriormente, provino de las experiencias del Consultor en proyectos similares y de las bases de datos internas de los profesionales de estimación de costos de CDM Smith.

FASE I. TRATAMIENTO PRIMARIO CON ASISTENCIA QUÍMICA (TPQA)

Layout Comparison Summary

Layout Name	Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
FI- CEPT+THP	\$1,070,000,000	\$592,000,000	\$2,570,000	\$1,930,000	\$1,280,000	\$7,060,000	\$3,240,000	\$21,200,000
FI- CEPT+AD	\$1,200,000,000	\$589,000,000	\$2,430,000	\$1,560,000	\$8,090,000	\$8,410,000	\$3,610,000	\$20,000,000

FI- TPQA+THP



Summary

Equipment Database
Sept 2007,(USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$1,070,000,000	\$592,000,000	\$2,570,000	\$1,930,000	\$1,280,000	\$7,060,000	\$3,240,000	\$21,200,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Tratamiento Preliminar	\$13,100,000	\$357,000	\$112,000	\$328,000	\$0	\$49,300	\$662,000
Coagulación y Floculación	\$0	\$0	\$0	\$0	\$4,410,000	\$0	\$0
Sedimentación Primaria	\$36,000,000	\$72,300	\$40,700	\$142,000	\$0	\$21,700	\$806,000
Espasamiento pro gravedad	\$2,350,000	\$48,200	\$22,800	\$23,500	\$0	\$7,060	\$148,000
Centrifugation	\$32,000,000	\$224,000	\$280,000	\$0	\$891,000	\$1,860,000	\$3,540,000
Hidrólisis Térmica	\$46,700,000	\$161,000	\$161,000	\$69,000	\$345,000	\$331,000	\$4,550,000
Digestion Anaerobica	\$43,400,000	\$148,000	\$88,000	\$119,000	\$0	\$315,000	\$3,740,000
Belt-Filter Press	\$6,350,000	\$398,000	\$398,000	\$0	\$1,420,000	\$653,000	\$660,000
Generacion con motores de cc	\$25,000,000	\$830,000	\$830,000	\$550,000	\$0	\$0	\$7,000,000
Iron Feed System	\$2,250,000	\$43,900	\$0	\$45,000	\$0	\$0	\$114,000
Other Costs	\$385,000,000	\$293,000	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		210 acre
Administration labor hours		35400 hr/yr
Laboratory labor hours		14500 hr/yr
Costs		
DIRECT COSTS		
Mobilization	\$14,500,000	\$
Site preparation	\$12,500,000	\$
Site electrical	\$48,400,000	\$
Yard piping	\$29,600,000	\$
Instrumentation and control	\$30,300,000	\$
Lab and administration building	\$23,100,000	\$
Unit process construction costs	\$207,000,000	\$
Profit	\$54,800,000	\$
Total construction costs	\$420,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$21,000,000	\$
Legal cost	\$8,410,000	\$
Engineering design fee	\$63,100,000	\$
Inspection cost	\$8,410,000	\$
Contingency	\$42,000,000	\$
Technical	\$8,410,000	\$
Total indirect costs	\$151,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$20,700,000	\$
LABOR COSTS		
Administration labor cost	\$177,000	\$/yr
Laboratory labor cost	\$116,000	\$/yr
Unit process operation labor cost	\$2,280,000	\$/yr
Unit process maintenance labor cost	\$1,930,000	\$/yr
Total labor costs	\$4,510,000	\$/yr
PROJECT SUMMARY		
Present worth	\$1,070,000,000	\$
Total project cost	\$592,000,000	\$
Total operation labor cost	\$2,570,000	\$/yr
Total maintenance labor cost	\$1,930,000	\$/yr
Total material cost	\$1,280,000	\$/yr
Total chemical cost	\$7,060,000	\$/yr
Total energy cost	\$3,240,000	\$/yr
Total amortization cost	\$21,200,000	\$/yr

Summary of Chemical Feed System for Iron

Description	Value	Units
Iron Salt Solution Feed System		
Quantities		
Ferric chloride dosage rate		44400 lb/d

Iron salt dosage rate as equivalent	15300 lb/d
Liquid chemical solution fed	0,0125 MGD(US)
Operation labor required	5480 pers-hrs/yr
Costs	
Construction and equipment cost	\$2,250,000
Operational labor cost	\$43,900
Material and supply cost	\$45,000
Amortization cost	\$114,000

Afluente Canoas (MM)

User Input Data

Description	Value	Units
Average Flow	365	MGD(US)
Minimum Flow	320	MGD(US)
Maximum Flow	730	MGD(US)
Suspended Solids	226	mg/L
% Volatile Solids	75	%
BOD	271	mg/L
Soluble BOD	80	mg/L
COD	550	mg/L
Soluble COD	350	mg/L
TKN	70,4	mgN/L
Soluble TKN	35,2	mgN/L
Ammonia	26	mgN/L
Total Phosphorus	9,7	mgP/L
pH	7,3	
Cations	160	mg/L
Anions	160	mg/L
Settleable Solids	50	mL/L
Oil and Grease	100	mg/L
Nitrite	0	mgN/L
Nitrate	0	mgN/L
Non-Degradable Fraction of VS	40	%
Average Summer	68	deg F
Average Winter	60,8	deg F

Tratamiento Preliminar

User Input Data

Screening

Description	Value	Units
Cleaning Method	Mechanically Cleaned	
Mechanically Cleaned Depth	9,84	ft
Manually Cleaned Depth	2	ft
Width	0,25	in
Space	0,235	in
Slope	15	degrees
Shape Factor	1,8	
Approach	1,31	ft/s
Max	3	ft/s
Ave	1,31	ft/s

Grit Removal

Description	Value	Units
Particle Size	0,00786	in
Specific Gravity	2	
Type of Grit Removal	Aerated	

Number of Units		1
Design By	Depth	
Depth		14,8 ft
Width		65,6 ft
Current Allowance		1,7
Manning Coefficient		0,035
Volume of Grit		40 cuft grit/MGal(US)
Detention Time		10 min
Air Supply per Unit Length of T		3 scfm/ft
Surface Velocity		1,5 ft/s
Tank Floor Velocity		1 ft/s
Capital Cost		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE \$0.00	\$
Override Annual Operational C	FALSE \$0.00	\$
Override Annual Maintenance	FALSE \$0.00	\$
Override Annual Materials Cos	FALSE \$0.00	\$
Override Annual Chemical Cos	FALSE \$0.00	\$
Override Annual Energy Cost	FALSE \$0.00	\$
Override Annual Amortization (FALSE \$0.00	\$

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		
Bar size		0,25 in
Bar spacing		0,235 in
Slope of bars from horizontal		15 degrees
Head loss through screen	2,6965E+308	ft
Approach velocity		1,31 ft/s
Average flow through velocity (1,31 ft/s
Maximum flow through velocity		3 ft/s
Screen channel width		43,7 ft
Average channel depth		9,84 ft
Aerated Grit Chamber		
Design Information		
Maximum flow		728 MGD(US)
Average flow		365 MGD(US)
Minimum flow		319 MGD(US)
Temperature		60,8 deg F
Maximum flow through velocity		0,356 ft/s
Average flow through velocity (0,178 ft/s
Size of smallest particle 100%	0,00786	in
Specific gravity of particle		2
Number of units		1
Maximum flow/unit		728 MGD(US)
Width of channel		214 ft

Depth of channel		14,8 ft
Length of channel		214 ft
Settling velocity of particle		0,0513 ft/s
Hydraulic retention time		10 min
Volume of grit		0,109 MGD(US)
Air supply		3 cfm
Costs		
Construction and equipment cost	\$13,100,000	\$
Operational labor cost	\$357,000	\$/yr
Maintenance labor cost	\$112,000	\$/yr
Material and supply cost	\$328,000	\$/yr
Energy cost	\$49,300	\$/yr
Amortization cost	\$662,000	\$/yr

Espasamiento pro gravedad

User Input Data

Gravity Thickening

Description	Value	Units
Underflow Concentration		5 %
Depth		14 ft
Based On	Mass Loading	
Mass Loading		24 lb/(sqft·d)
Settling Velocity	0,000694	ft/s
Initial Height		4 ft
Intercept		3 ft
Override Design	TRUE	
Surface Area per Thickener		4500 sqft
Number of Units		7
Override Database Costs	FALSE	
Standard 90 ft Diameter Thickener	\$145,000.00	\$
Thickener		20 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration		4 %
Thickened concentration		5 %

Mass loading	24 lb/(sqft·d)
Hydraulic loading	42,6 gal(US)/(sqft·d)
Hydraulic retention time	59 hr
Number of tanks	7
Tank volume	441000 cuft
Depth	14 ft
Surface area per tank	4500 sqft
Tank diameter	76 ft
Quantities	
Amount of sludge generated	448000 lb/d
Volume of thickened sludge	0,92 MGD(US)
Operation labor required	6020 pers-hrs/yr
Maintenance labor required	2930 pers-hrs/yr
Electrical energy required	35300 kWh/yr
Volume of earthwork required	401000 cuft
Slab thickness	11,4 in
Volume of slab concrete requir	35100 cuft
Wall thickness	14 in
Volume of wall concrete requir	31100 cuft
Costs	
Construction and equipment cost	\$2,350,000
Operational labor cost	\$48,200
Maintenance labor cost	\$22,800
Material and supply cost	\$23,500
Energy cost	\$7,060
Amortization cost	\$148,000

Coagulation y Floculación

User Input Data

Chemical Phosphorus Removal

Description	Value	Units
Metal Precipitant	Equivalent Iron	
Effluent Phosphorus		30 mg/L
Override Design	TRUE	
Chemical Dosage		5 mg/L

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		

Design Information		
Chemical used	Equivalent Iron	
Chemical dosage		5 mg/L
Mass of chemical per year	2530000	kg/yr
Chemical sludge production		-22 mg/L
Organic sludge production		2,8 mg/L
Costs		
Chemical cost	\$4,410,000	\$/yr

Centrifugation

User Input Data

Centrifugation

Description	Value	Units
Cake Solids Content		10 %
Solids Capture		90 %
Power Requirement		1 HP/gpm(US)
Daily Operating Time		8 hr/d
Weekly Operating Time		5 d/wk
Number of Units		2
Excess Capacity Factor	1,25	
Chemical Dose		1 % dry wt
Override Database Costs	FALSE	
Standard 50 hp Centrifuge	\$271,000.00	\$
Centrifuge		15 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$32,000,000.00	\$
Override Annual Operational C	TRUE	
	\$224,000.00	\$
Override Annual Maintenance	TRUE	
	\$280,000.00	\$
Override Annual Materials Cos	TRUE	
	\$0.00	\$
Override Annual Chemical Cos	TRUE	
	\$891,000.00	\$
Override Annual Energy Cost	TRUE	
	\$1,860,000.00	\$
Override Annual Amortization (TRUE	
	\$3,540,000.00	\$

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	3360	HP
Power required per unit	197	HP
Excess capacity factor	1,25	
Number of units	17	
Chemical dose		1 % dry wt
Chemicals required	16900	lb/d
Sludge flow	3,87	MGD(US)
Initial solid conc		5 %
Operational hours per day		8 hr

Operational days per week	5 d
Quantities	
Number of centrifuges	17
Power required per unit	197 HP
Area of building	4650 sqft
Dry solids produced	384000 lb/d
Operation labor required	62900 pers-hrs/yr
Maintenance labor required	10200 pers-hrs/yr
Electrical energy required	4270000 kWh/yr
Polymer Feed System	
Quantities	
Polymer dosage	5640 lb/d
Liquid chemical solution fed	0,27 MGD(US)
O&M labor required	39900 pers-hrs/yr
Dry material handling and mixi	3180 pers-hrs/yr
Total operation labor required	43100 pers-hrs/yr

Sedimentación Primaria

User Input Data

Primary Clarification

Description	Value	Units
Design Basis	Peak Flow	
Surface Overflow Rate	2400	gal(US)/(sqft·d)
Sidewater Depth	16	ft
Specific Gravity	1,05	
Underflow Concentration	4	%
Weir Overflow Rate	15000	gal(US)/(ft·d)
Type of Clarifier	Circular	
Suspended Solids	65	%
BOD	40	%
COD	40	%
TKN	5	%
Phosphorus	5	%
Override Design	TRUE	
Length-Rectangular Only	0	ft
Width-Rectangular Only	0	ft
Diameter-Circular Only	165	ft
Excavation Depth	4	ft
Number of Tanks per Battery	4	
Number of Batteries	4	
Override Database Costs	FALSE	
Standard 20 X 120 ft Rectangu	\$119,000.00	\$
Standard 90 ft Diameter Circul	\$97,600.00	\$
Standard 3000 gpm Pump and	\$19,500.00	\$
Mechanical	20	years
Structural	40	years
Pump	25	years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$36,000,000.00	\$
Override Annual Operational C	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$

Override Annual Materials Cos	FALSE	
	\$0.00	\$
Override Annual Chemical Cos	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization (FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifi	21400	sqft
Diameter of each circular clarif	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	2,01	lb/(sqft·d)
Hydraulic retention time	2,68	hr
Weir length	48800	ft
Volume of sludge generated	1,34	MGD(US)
Surface overflow rate	2140	gal(US)/(sqft·d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete requir	374000	cuft
Wall thickness	15	in
Volume of wall concrete requir	183000	cuft
Costs		
Operational labor cost	\$68,700	\$/yr
Maintenance labor cost	\$37,700	\$/yr
Material and supply cost	\$141,000	\$/yr
Energy cost	\$12,700	\$/yr
Amortization cost	\$802,000	\$/yr
Notes		
Effluent soluble TKN adjusted to satisfy user-specified TKN removal.		
Waste Sludge Pumping		
Design Information		
Average daily pumping rate	1,34	MGD(US)
Total pumping capacity	1,34	MGD(US)
Design capacity per pump	0,671	MGD(US)
Number of pumps	3	
Number of batteries	1	
Firm pumping capacity	1,34	MGD(US)
Quantities		
Operation labor required	457	pers-hrs/yr
Maintenance labor required	376	pers-hrs/yr
Electrical energy required	44900	kWh/yr
Volume of earthwork required	1810	cuft
Area of pump building	226	sqft
Costs		
Operational labor cost	\$3,660	\$/yr

Maintenance labor cost	\$2,920	\$/yr
Material and supply cost	\$517	\$/yr
Energy cost	\$8,990	\$/yr
Amortization cost	\$4,820	\$/yr

Hidrólisis Térmica

User Input Data

User Specified Sludge Process

Description	Value	Units
Volume Reduction		0 %
Percent Volatile Solids Destroy		0 %

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$46,700,000.00	\$
Override Annual Operational C	TRUE	
	\$161,000.00	\$
Override Annual Maintenance	TRUE	
	\$161,000.00	\$
Override Annual Materials Cos	TRUE	
	\$69,000.00	\$
Override Annual Chemical Cos	TRUE	
	\$345,000.00	\$
Override Annual Energy Cost	TRUE	
	\$331,000.00	\$
Override Annual Amortization (TRUE	
	\$4,550,000.00	\$

Design Output Data

Description	Value	Units
User Specified Sludge Treatment Process		
Design Information		
No Design Data		

Digestion Anaerobica

User Input Data

Anaerobic Digestion

Description	Value	Units
Specific Gravity		1,05
Percent Volatile Solids Destroy		45 %
Concentration in Digester		3,4 %
Minimum Detention Time in Pri		15 d
Location	Warm-Winter > 10 D	
Raw Wastewater		60,8 deg F
Digester		104 deg F
Fraction of Influent Flow Return		2 %
Suspended Solids		6250 mg/L
BOD		1000 mg/L
COD		2150 mg/L
TKN		950 mgN/L
Ammonia		650 mg/L
Override Design	TRUE	
Diameter		90 ft
Sidewater Depth		75 ft
Number of Primary Digester Tã		10

Number of Secondary Digester		0
Number of Batteries		1
Override Database Costs	FALSE	
Standard 70 ft Diameter Floatir	\$444,000.00	\$
Standard 60 ft Diameter Gas C	\$131,000.00	\$
Standard 1 Million Btu/Hr Heat	\$55,300.00	\$
Standard 2 in Diameter Gas S	\$43,400.00	\$
Standard Size Sludge Pump 8	\$5,960.00	\$
Natural Gas Per 1000 cuft	\$21.10	\$
Floating Cover		20 years
Gas Circulation Unit		20 years
Heating Unit		20 years
Gas Safety Equipment		20 years
Sludge Pump		25 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$43,400,000.00	\$
Override Annual Operational C	TRUE	
	\$148,000.00	\$
Override Annual Maintenance	TRUE	
	\$88,000.00	\$
Override Annual Materials Cos	TRUE	
	\$119,000.00	\$
Override Annual Chemical Cos	FALSE	
	\$0.00	\$
Override Annual Energy Cost	TRUE	
	\$315,000.00	\$
Override Annual Amortization (TRUE	
	\$3,740,000.00	\$

Design Output Data

Description	Value	Units
Anaerobic Digestion		
Design Information		
Percent VSS destroyed		45 %
Solids concentration in digeste		3,4 %
Detention time		15 d
Digester depth		75 ft
Digester diameter		90 ft
Effective digester volume	5010000	cuft
Number of digesters per batter		10
Number of primary digesters p		10
Number of secondary digester:		0
Number of batteries		1
Gas produced		0,164 MGD(US)
Heat required	14300000	BTU/hr
Digester gas required		5,92 MGD(US)
Total natural gas required		0,284 MGD(US)
Quantities		
Operation labor required		22200 pers-hrs/yr
Maintenance labor required		13100 pers-hrs/yr
Electrical energy required		1970000 kWh/yr
Volume of earthwork required		2230000 cuft

Slab thickness	22,3 in
Volume of slab concrete requir	125000 cuft
Wall thickness	45 in
Volume of wall concrete requir	885000 cuft
Sidewater depth	75 ft
Surface area/floor of 2-story cc	9880 sqft
Piping size	10 in
Length of total piping system	4430 ft
Number of 90 degree elbows	130
Number of tees	255
Number of plug valves	185
Total dry solids treated	363000 lb/d

Notes

Mass balance based on user input

Generacion con motores de combustion biogas

User Input Data

User Specified Sludge Process

Description	Value	Units
Volume Reduction		0 %
Percent Volatile Solids Destroy		0 %

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$25,000,000.00	\$
Override Annual Operational C	TRUE	
	\$830,000.00	\$
Override Annual Maintenance	TRUE	
	\$830,000.00	\$
Override Annual Materials Cos	TRUE	
	\$550,000.00	\$
Override Annual Chemical Cos	TRUE	
	\$0.00	\$
Override Annual Energy Cost	TRUE	
	\$-14,300,000.00	\$
Override Annual Amortization C	TRUE	
	\$7,000,000.00	\$

Design Output Data

Description	Value	Units
-------------	-------	-------

Belt-Filter Press

User Input Data

Belt-Filter Press

Description	Value	Units
Cake Solids Content		32 %
Density of Cake		75 lb/cuft
Operating Schedule per Day		8 hr/d
Days Operating per Week		5 d/wk
Hydraulic Loading per Metre of		0,1 MGD(US)
Polymer Dose		1 % dry wt
Filtrate Solids Concentration		100 mg/L
Override Design	FALSE	
Building Size Requirement		11100 sqft
Number of Belt Filters		26

Override Database Costs	FALSE	
1m Belt Filter System	\$250,000.00	\$
2m Belt Filter System	\$276,000.00	\$
Belt Filter		20 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$6,350,000.00	\$
Override Annual Operational Cost	TRUE	
	\$398,000.00	\$
Override Annual Maintenance	TRUE	
	\$398,000.00	\$
Override Annual Materials Cost	TRUE	
	\$0.00	\$
Override Annual Chemical Cost	TRUE	
	\$1,420,000.00	\$
Override Annual Energy Cost	TRUE	
	\$653,000.00	\$
Override Annual Amortization Cost	TRUE	
	\$660,000.00	\$

Design Output Data

Description	Value	Units
Belt-Filter Press		
Design Information		
Belt filter width		6,56 ft
Number of units		26
Hydraulic loading per unit per r		0,1 MGD(US)
Hydraulic loading required per		5,1 MGD(US)
Final solids content		32 %
Solids capture fraction		0,997
Quantities		
Operation labor required		11500 pers-hrs/yr
Maintenance labor required		2870 pers-hrs/yr
Power		2570000 kWh/yr
Polymer required		4130 lb/d
Dry solids produced		413000 lb/d
Belt filter(s)	\$7,180,000	\$
Building	\$513,000	\$
Installation	\$1,790,000	\$
Polymer system	\$2,660,000	\$
Feed pumps	\$789,000	\$
Conveyor system	\$1,790,000	\$

Deshidratación por centrifugas

User Input Data

Centrifugation

Description	Value	Units
Cake Solids Content		19 %
Solids Capture		90 %
Power Requirement		1 HP/gpm(US)
Daily Operating Time		8 hr/d
Weekly Operating Time		7 d/wk
Number of Units		5

Excess Capacity Factor		1,25
Chemical Dose		1 % dry wt
Override Database Costs	FALSE	
Standard 50 hp Centrifuge	\$271,000.00	\$
Centrifuge		15 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$15,000,000.00	\$
Override Annual Operational C	TRUE	
	\$300,000.00	\$
Override Annual Maintenance	TRUE	
	\$350,000.00	\$
Override Annual Materials Cos	TRUE	
	\$0.00	\$
Override Annual Chemical Cos	TRUE	
	\$4,000,000.00	\$
Override Annual Energy Cost	TRUE	
	\$2,800,000.00	\$
Override Annual Amortization C	TRUE	
	\$1,500,000.00	\$

Design Output Data

Description	Value	Units
-------------	-------	-------

Disposition Final

User Input Data

Hauling and Land Filling

Description	Value	Units
Distance to Disposal Site		15,5 miles
Daily Operation		8 hr
Loading Time per Vehicle		0,75 hr
Hauling Time per Trip		1 hr
Disposal Cost Based On	Sludge Disposal per	
Override Database Costs	TRUE	
Standard 22 cuyd Vehicle	\$314,000.00	\$
Annual Charge of Land Fill	\$43,100.00	\$
Sludge Disposal per cuyd	\$23.60	\$
Sludge Disposal per ton	\$28.00	\$
Vehicle		6 years
Structural		40 years

Cost Override


Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational C	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cos	FALSE	
	\$0.00	\$
Override Annual Chemical Cos	FALSE	
	\$0.00	\$

Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization (FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling		
Design Information		
Volume of sludge hauled	0,128	MGD(US)
Truck capacity	810	cuft
Round trip time to disposal site	1	hr
Truck loading time	0,75	hr
Operational hours per day	8	hr
Number of trucks required	5	
Distance to disposal site	15,5	miles
Quantities		
Total sludge volume hauled	0,128	MGD(US)
Maximum anticipated landfill d	30	d
Anticipated sludge storage hei	8	ft
Sludge storage shed area	64500	sqft
Width of sludge storage shed s	180	ft
Length of sludge storage shed	359	ft
Volume of earthwork required	165000	cuft
Volume of slab concrete requir	66900	cuft
Surface area of canopy roof	64500	sqft
Round trip haul distance	31,1	miles
Round trips per day per truck	5	
Distance traveled per year per	38800	miles
Sludge hauled	1130000	lb/d
Operation labor required	15500	pers-hrs/yr
LandFilling cost	\$5,480,000	\$/yr

FI- TPQA+DA



Summary

Equipment Database

Sept 2007,(USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$1,200,000,000	\$589,000,000	\$2,430,000	\$1,560,000	\$8,090,000	\$8,410,000	\$3,610,000	\$20,000,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Tratamiento Preliminar	\$13,100,000	\$357,000	\$111,000	\$328,000	\$0	\$49,300	\$662,000
Coagulación y Floculación	\$0	\$0	\$0	\$0	\$4,410,000	\$0	\$0
Sedimentación Primaria	\$36,000,000	\$72,300	\$40,400	\$142,000	\$0	\$22,200	\$806,000
Espasamiento por gravedad	\$2,350,000	\$50,000	\$23,300	\$23,500	\$0	\$7,260	\$148,000
Digestión Anaeróbica	\$108,000,000	\$346,000	\$206,000	\$279,000	\$0	\$735,000	\$9,300,000
Deshidratación por centrifugas	\$15,000,000	\$300,000	\$350,000	\$0	\$4,000,000	\$2,800,000	\$1,500,000
Disposición Final	\$3,320,000	\$138,000	\$0	\$6,720,000	\$0	\$0	\$443,000
Generación con motores de co	\$25,000,000	\$830,000	\$830,000	\$550,000	\$0	\$0	\$7,000,000
Iron Feed System	\$2,250,000	\$43,900	\$0	\$45,100	\$0	\$0	\$114,000
Other Costs	\$384,000,000	\$293,000	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		210 acre
Administration labor hours		35400 hr/yr
Laboratory labor hours		14500 hr/yr
Costs		
DIRECT COSTS		
Mobilization	\$14,500,000	\$
Site preparation	\$12,500,000	\$
Site electrical	\$48,400,000	\$
Yard piping	\$29,600,000	\$
Instrumentation and control	\$30,300,000	\$
Lab and administration building	\$23,100,000	\$
Unit process construction costs	\$205,000,000	\$
Profit	\$54,500,000	\$
Total construction costs	\$418,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$20,900,000	\$
Legal cost	\$8,360,000	\$
Engineering design fee	\$62,700,000	\$
Inspection cost	\$8,360,000	\$
Contingency	\$41,800,000	\$
Technical	\$8,360,000	\$
Total indirect costs	\$150,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$20,600,000	\$
LABOR COSTS		
Administration labor cost	\$177,000	\$/yr
Laboratory labor cost	\$116,000	\$/yr
Unit process operation labor cost	\$2,140,000	\$/yr
Unit process maintenance labor cost	\$1,560,000	\$/yr
Total labor costs	\$3,990,000	\$/yr
PROJECT SUMMARY		
Present worth	\$1,200,000,000	\$
Total project cost	\$589,000,000	\$
Total operation labor cost	\$2,430,000	\$/yr
Total maintenance labor cost	\$1,560,000	\$/yr
Total material cost	\$8,090,000	\$/yr
Total chemical cost	\$8,410,000	\$/yr
Total energy cost	\$3,610,000	\$/yr
Total amortization cost	\$20,000,000	\$/yr

Summary of Chemical Feed System for Iron

Description	Value	Units
Iron Salt Solution Feed System		
Quantities		
Ferric chloride dosage rate		44400 lb/d

Iron salt dosage rate as equivalent	15300 lb/d
Liquid chemical solution fed	0,0125 MGD(US)
Operation labor required	5490 pers-hrs/yr
Costs	
Construction and equipment cost	\$2,250,000
Operational labor cost	\$43,900
Material and supply cost	\$45,100
Amortization cost	\$114,000

Afluente Canoas (MM)

User Input Data

Description	Value	Units
Average Flow	365	MGD(US)
Minimum Flow	320	MGD(US)
Maximum Flow	730	MGD(US)
Suspended Solids	226	mg/L
% Volatile Solids	75	%
BOD	271	mg/L
Soluble BOD	80	mg/L
COD	550	mg/L
Soluble COD	350	mg/L
TKN	70,4	mgN/L
Soluble TKN	35,2	mgN/L
Ammonia	26	mgN/L
Total Phosphorus	9,7	mgP/L
pH	7,3	
Cations	160	mg/L
Anions	160	mg/L
Settleable Solids	50	mL/L
Oil and Grease	100	mg/L
Nitrite	0	mgN/L
Nitrate	0	mgN/L
Non-Degradable Fraction of VS	40	%
Average Summer	68	deg F
Average Winter	60,8	deg F

Tratamiento Preliminar

User Input Data

Screening

Description	Value	Units
Cleaning Method	Mechanically Cleaned	
Mechanically Cleaned Depth	9,84	ft
Manually Cleaned Depth	2	ft
Width	0,25	in
Space	0,235	in
Slope	15	degrees
Shape Factor	1,8	
Approach	1,31	ft/s
Max	3	ft/s
Ave	1,31	ft/s

Grit Removal

Description	Value	Units
Particle Size	0,00786	in
Specific Gravity	2	
Type of Grit Removal	Aerated	

Number of Units		1
Design By	Depth	
Depth		14,8 ft
Width		65,6 ft
Current Allowance		1,7
Manning Coefficient		0,035
Volume of Grit		40 cuft grit/MGal(US)
Detention Time		10 min
Air Supply per Unit Length of T		3 scfm/ft
Surface Velocity		1,5 ft/s
Tank Floor Velocity		1 ft/s
Capital Cost		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE \$0.00	\$
Override Annual Operational C	FALSE \$0.00	\$
Override Annual Maintenance	FALSE \$0.00	\$
Override Annual Materials Cos	FALSE \$0.00	\$
Override Annual Chemical Cos	FALSE \$0.00	\$
Override Annual Energy Cost	FALSE \$0.00	\$
Override Annual Amortization (FALSE \$0.00	\$

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		
Bar size		0,25 in
Bar spacing		0,235 in
Slope of bars from horizontal		15 degrees
Head loss through screen	2,6965E+308	ft
Approach velocity		1,31 ft/s
Average flow through velocity (1,31 ft/s
Maximum flow through velocity		3 ft/s
Screen channel width		43,7 ft
Average channel depth		9,84 ft
Aerated Grit Chamber		
Design Information		
Maximum flow		728 MGD(US)
Average flow		365 MGD(US)
Minimum flow		319 MGD(US)
Temperature		60,8 deg F
Maximum flow through velocity		0,356 ft/s
Average flow through velocity (0,178 ft/s
Size of smallest particle 100%	0,00786	in
Specific gravity of particle		2
Number of units		1
Maximum flow/unit		728 MGD(US)
Width of channel		214 ft

Depth of channel	14,8 ft
Length of channel	214 ft
Settling velocity of particle	0,0513 ft/s
Hydraulic retention time	10 min
Volume of grit	0,109 MGD(US)
Air supply	3 cfm

Costs		
Construction and equipment cost	\$13,100,000	\$
Operational labor cost	\$357,000	\$/yr
Maintenance labor cost	\$111,000	\$/yr
Material and supply cost	\$328,000	\$/yr
Energy cost	\$49,300	\$/yr
Amortization cost	\$662,000	\$/yr

Coagulacion y Floculacion

User Input Data

Chemical Phosphorus Removal

Description	Value	Units
Metal Precipitant	Equivalent Iron	
Effluent Phosphorus		30 mg/L
Override Design	TRUE	
Chemical Dosage		5 mg/L

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		
Design Information		
Chemical used	Equivalent Iron	
Chemical dosage		5 mg/L
Mass of chemical per year	2530000	kg/yr
Chemical sludge production		-22 mg/L
Organic sludge production		2,8 mg/L
Costs		
Chemical cost	\$4,410,000	\$/yr

Espasamiento pro gravedad

User Input Data

Gravity Thickening

Description	Value	Units
-------------	-------	-------

Underflow Concentration		5 %
Depth		14 ft
Based On	Mass Loading	
Mass Loading		24 lb/(sqft-d)
Settling Velocity		0,000694 ft/s
Initial Height		4 ft
Intercept		3 ft
Override Design	TRUE	
Surface Area per Thickener		4500 sqft
Number of Units		7
Override Database Costs	FALSE	
Standard 90 ft Diameter Thickener		\$145,000.00
Thickener		20 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration		4 %
Thickened concentration		5 %
Mass loading		24 lb/(sqft-d)
Hydraulic loading		44,8 gal(US)/(sqft-d)
Hydraulic retention time		56,1 hr
Number of tanks		7
Tank volume		441000 cuft
Depth		14 ft
Surface area per tank		4500 sqft
Tank diameter		76 ft
Quantities		
Amount of sludge generated		471000 lb/d
Volume of thickened sludge		0,967 MGD(US)
Operation labor required		6250 pers-hrs/yr
Maintenance labor required		3030 pers-hrs/yr
Electrical energy required		36300 kWh/yr
Volume of earthwork required		401000 cuft
Slab thickness		11,4 in
Volume of slab concrete required		35100 cuft
Wall thickness		14 in

Volume of wall concrete require		31100 cuft
Costs		
Construction and equipment cost	\$2,350,000	\$
Operational labor cost	\$50,000	\$/yr
Maintenance labor cost	\$23,300	\$/yr
Material and supply cost	\$23,500	\$/yr
Energy cost	\$7,260	\$/yr
Amortization cost	\$148,000	\$/yr

Sedimentación Primaria

User Input Data

Primary Clarification

Description	Value	Units
Design Basis	Peak Flow	
Surface Overflow Rate		2400 gal(US)/(sqft·d)
Sidewater Depth		16 ft
Specific Gravity		1,05
Underflow Concentration		4 %
Weir Overflow Rate		15000 gal(US)/(ft·d)
Type of Clarifier	Circular	
Suspended Solids		65 %
BOD		40 %
COD		40 %
TKN		5 %
Phosphorus		5 %
Override Design	TRUE	
Length-Rectangular Only		0 ft
Width-Rectangular Only		0 ft
Diameter-Circular Only		165 ft
Excavation Depth		4 ft
Number of Tanks per Battery		4
Number of Batteries		4
Override Database Costs	FALSE	
Standard 20 X 120 ft Rectangular	\$119,000.00	\$
Standard 90 ft Diameter Circular	\$97,600.00	\$
Standard 3000 gpm Pump and	\$19,500.00	\$
Mechanical		20 years
Structural		40 years
Pump		25 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$36,000,000.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifi	21400	sqft
Diameter of each circular clarif	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	2,11	lb/(sqft·d)
Hydraulic retention time	2,68	hr
Weir length	48800	ft
Volume of sludge generated	1,41	MGD(US)
Surface overflow rate	2140	gal(US)/(sqft·d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete requir	374000	cuft
Wall thickness	15	in
Volume of wall concrete requir	183000	cuft
Costs		
Operational labor cost	\$68,700	\$/yr
Maintenance labor cost	\$37,500	\$/yr
Material and supply cost	\$141,000	\$/yr
Energy cost	\$12,700	\$/yr
Amortization cost	\$802,000	\$/yr
Notes		
Effluent soluble TKN adjusted to satisfy user-specified TKN removal.		
Waste Sludge Pumping		
Design Information		
Average daily pumping rate	1,41	MGD(US)
Total pumping capacity	1,41	MGD(US)
Design capacity per pump	0,705	MGD(US)
Number of pumps	3	
Number of batteries	1	
Firm pumping capacity	1,41	MGD(US)
Quantities		
Operation labor required	460	pers-hrs/yr
Maintenance labor required	379	pers-hrs/yr
Electrical energy required	47200	kWh/yr
Volume of earthwork required	1820	cuft
Area of pump building	228	sqft
Costs		
Operational labor cost	\$3,680	\$/yr
Maintenance labor cost	\$2,920	\$/yr
Material and supply cost	\$527	\$/yr
Energy cost	\$9,440	\$/yr
Amortization cost	\$4,910	\$/yr

Digestion Anaerobica

User Input Data

Anaerobic Digestion

Description	Value	Units
Specific Gravity		1,05
Percent Volatile Solids Destroy		45 %
Concentration in Digester		3,4 %
Minimum Detention Time in Pri		15 d
Location	Warm-Winter > 10 D	
Raw Wastewater		60,8 deg F
Digester		104 deg F
Fraction of Influent Flow Return		2 %
Suspended Solids		6250 mg/L
BOD		1000 mg/L
COD		2150 mg/L
TKN		950 mgN/L
Ammonia		650 mg/L
Override Design	TRUE	
Diameter		90 ft
Sidewater Depth		75 ft
Number of Primary Digester T		10
Number of Secondary Digester		0
Number of Batteries		1
Override Database Costs	FALSE	
Standard 70 ft Diameter Floatir	\$444,000.00	\$
Standard 60 ft Diameter Gas C	\$131,000.00	\$
Standard 1 Million Btu/Hr Heat	\$55,300.00	\$
Standard 2 in Diameter Gas S	\$43,400.00	\$
Standard Size Sludge Pump 8	\$5,960.00	\$
Natural Gas Per 1000 cuft	\$21.10	\$
Floating Cover		20 years
Gas Circulation Unit		20 years
Heating Unit		20 years
Gas Safety Equipment		20 years
Sludge Pump		25 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$108,000,000.00	\$
Override Annual Operational C	TRUE	
	\$346,000.00	\$
Override Annual Maintenance	TRUE	
	\$206,000.00	\$
Override Annual Materials Cos	TRUE	
	\$279,000.00	\$
Override Annual Chemical Cos	FALSE	
	\$0.00	\$
Override Annual Energy Cost	TRUE	
	\$735,000.00	\$
Override Annual Amortization (TRUE	
	\$9,300,000.00	\$

Design Output Data

Description	Value	Units
Anaerobic Digestion		
Design Information		
Percent VSS destroyed		45 %

Solids concentration in digeste	3,4 %
Detention time	15 d
Digester depth	75 ft
Digester diameter	90 ft
Effective digester volume	5010000 cuft
Number of digesters per batter	10
Number of primary digesters p	10
Number of secondary digesters:	0
Number of batteries	1
Gas produced	17,8 MGD(US)
Heat required	23000000 BTU/hr
Digester gas required	9,55 MGD(US)
Total natural gas required	0 MGD(US)
Quantities	
Operation labor required	25200 pers-hrs/yr
Maintenance labor required	14800 pers-hrs/yr
Electrical energy required	2230000 kWh/yr
Volume of earthwork required	2230000 cuft
Slab thickness	22,3 in
Volume of slab concrete requir	125000 cuft
Wall thickness	45 in
Volume of wall concrete requir	885000 cuft
Sidewater depth	75 ft
Surface area/floor of 2-story cc	9880 sqft
Piping size	10 in
Length of total piping system	4430 ft
Number of 90 degree elbows	130
Number of tees	255
Number of plug valves	185
Total dry solids treated	424000 lb/d
Notes	
Mass balance based on user input	

Deshidratación por centrifugas

User Input Data

Centrifugation

Description	Value	Units
Cake Solids Content		19 %
Solids Capture		90 %
Power Requirement		1 HP/gpm(US)
Daily Operating Time		8 hr/d
Weekly Operating Time		7 d/wk
Number of Units		5
Excess Capacity Factor	1,25	
Chemical Dose		1 % dry wt
Override Database Costs	FALSE	
Standard 50 hp Centrifuge	\$271,000.00	\$
Centrifuge		15 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$15,000,000.00	\$
Override Annual Operational C	TRUE	
	\$300,000.00	\$

Override Annual Maintenance	TRUE	
	\$350,000.00	\$
Override Annual Materials Cos	TRUE	
	\$0.00	\$
Override Annual Chemical Cos	TRUE	
	\$4,000,000.00	\$
Override Annual Energy Cost	TRUE	
	\$2,800,000.00	\$
Override Annual Amortization (TRUE	
	\$1,500,000.00	\$

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	2310	HP
Power required per unit	193	HP
Excess capacity factor	1,25	
Number of units	12	
Chemical dose	1	% dry wt
Chemicals required	7940	lb/d
Sludge flow	2,67	MGD(US)
Initial solid conc	3,4	%
Operational hours per day	8	hr
Operational days per week	7	d
Quantities		
Number of centrifuges	12	
Power required per unit	193	HP
Area of building	3290	sqft
Dry solids produced	252000	lb/d
Operation labor required	43500	pers-hrs/yr
Maintenance labor required	7080	pers-hrs/yr
Electrical energy required	2890000	kWh/yr
Polymer Feed System		
Quantities		
Polymer dosage	2650	lb/d
Liquid chemical solution fed	0,127	MGD(US)
O&M labor required	24500	pers-hrs/yr
Dry material handling and mixii	2560	pers-hrs/yr
Total operation labor required	27000	pers-hrs/yr

Generacion con motores de combustion biogas

User Input Data

User Specified Sludge Process

Description	Value	Units
Volume Reduction	0	%
Percent Volatile Solids Destroy	0	%

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$25,000,000.00	\$
Override Annual Operational C	TRUE	
	\$830,000.00	\$
Override Annual Maintenance	TRUE	
	\$830,000.00	\$

Override Annual Materials Cos	TRUE	
	\$550,000.00	\$
Override Annual Chemical Cos	TRUE	
	\$0.00	\$
Override Annual Energy Cost	TRUE	
	\$-14,300,000.00	\$
Override Annual Amortization (TRUE	
	\$7,000,000.00	\$

Design Output Data

Description	Value	Units
-------------	-------	-------

Secado Térmico

User Input Data

User Specified Sludge Process

Description	Value	Units
Volume Reduction		70 %
Percent Volatile Solids Destroy		90 %

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$45,000,000.00	\$
Override Annual Operational C	TRUE	
	\$1,620,000.00	\$
Override Annual Maintenance	TRUE	
	\$1,310,000.00	\$
Override Annual Materials Cos	TRUE	
	\$462,000.00	\$
Override Annual Chemical Cos	TRUE	
	\$0.00	\$
Override Annual Energy Cost	TRUE	
	\$8,100,000.00	\$
Override Annual Amortization (TRUE	
	\$4,550,000.00	\$

Design Output Data

Description	Value	Units
-------------	-------	-------

Disposicion Final

User Input Data

Hauling and Land Filling

Description	Value	Units
Distance to Disposal Site		15,5 miles
Daily Operation		8 hr
Loading Time per Vehicle		0,75 hr
Hauling Time per Trip		1 hr
Disposal Cost Based On	Sludge Disposal per	
Override Database Costs	TRUE	
Standard 22 cuyd Vehicle	\$314,000.00	\$
Annual Charge of Land Fill	\$43,100.00	\$
Sludge Disposal per cuyd	\$23.60	\$
Sludge Disposal per ton	\$28.00	\$
Vehicle		6 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$


Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling Design Information		
Volume of sludge hauled	0,143	MGD(US)
Truck capacity	810	cuft
Round trip time to disposal site	1	hr
Truck loading time	0,75	hr
Operational hours per day	8	hr
Number of trucks required	6	
Distance to disposal site	15,5	miles
Quantities		
Total sludge volume hauled	0,143	MGD(US)
Maximum anticipated landfill duration	30	d
Anticipated sludge storage height	8	ft
Sludge storage shed area	71700	sqft
Width of sludge storage shed	189	ft
Length of sludge storage shed	379	ft
Volume of earthwork required	183000	cuft
Volume of slab concrete required	74300	cuft
Surface area of canopy roof	71700	sqft
Round trip haul distance	31,1	miles
Round trips per day per truck	4	
Distance traveled per year per truck	31100	miles
Sludge hauled	1250000	lb/d
Operation labor required	17200	pers-hrs/yr
LandFilling cost	\$6,100,000	\$/yr
Costs		
Construction and equipment cost	\$3,320,000	\$
Operational labor cost	\$138,000	\$/yr
Material and supply cost	\$6,720,000	\$/yr
Amortization cost	\$443,000	\$/yr

**ALTERNATIVAS PARA FASE II - EXTENSIÓN DE LA PTAR A UN TRATAMIENTO
BIOLÓGICO CONVENCIONAL**

Layout Comparison Summary

Layout Name	Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
FII-Alt 2-FP	\$2,050,000,000	\$1,180,000,000	\$2,940,000	\$1,900,000	\$3,090,000	\$15,100,000	\$10,700,000	\$39,500,000
FII-Alt3-BAF	\$3,410,000,000	\$1,660,000,000	\$3,040,000	\$2,060,000	\$2,510,000	\$16,600,000	\$20,300,000	\$88,000,000
FII-Alt 1- Alim Esc	\$2,360,000,000	\$1,090,000,000	\$2,950,000	\$1,940,000	\$2,360,000	\$16,200,000	\$27,400,000	\$39,800,000



Summary

Equipment Database
Sept 2007, (USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$2,050,000,000	\$1,180,000,000	\$2,940,000	\$1,900,000	\$3,090,000	\$15,100,000	\$10,700,000	\$39,500,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Tratamiento Preliminar	\$13,100,000	\$359,000	\$119,000	\$329,000	\$0	\$49,400	\$664,000
Sedimentación Primaria	\$36,000,000	\$72,400	\$43,100	\$142,000	\$0	\$23,400	\$807,000
Filtro Percolador	\$226,000,000	\$265,000	\$141,000	\$1,390,000	\$0	\$5,820,000	\$11,800,000
Clarificador Secundario	\$61,000,000	\$91,200	\$54,300	\$198,000	\$0	\$34,400	\$1,120,000
Desinfección por cloro	\$10,300,000	\$78,300	\$97,200	\$140,000	\$8,940,000	\$53,700	\$657,000
Espesamiento pro gravedad	\$2,350,000	\$54,800	\$26,900	\$23,500	\$0	\$7,790	\$148,000
Digestion Anaerobica	\$14,700,000	\$398,000	\$23,700	\$322,000	\$0	\$846,000	\$15,000,000
Deshidratación por centrifugas	\$48,000,000	\$438,000	\$547,000	\$0	\$5,420,000	\$3,640,000	\$7,070,000
Espeador de Banda de Gravedad	\$30,500,000	\$61,000	\$15,700	\$0	\$782,000	\$264,000	\$1,170,000
Generacion con motores de combustión biogas	\$37,500,000	\$830,000	\$830,000	\$550,000	\$0	\$0	\$1,050,000
Other Costs	\$696,000,000	\$293,000	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		210 acre
Administration labor hours		35400 hr/yr
Laboratory labor hours		14500 hr/yr
Costs		
DIRECT COSTS		
Mobilization	\$14,500,000	\$
Site preparation	\$12,500,000	\$
Site electrical	\$48,400,000	\$
Yard piping	\$29,600,000	\$
Instrumentation and control	\$30,300,000	\$
Lab and administration building	\$23,100,000	\$
Unit process construction costs	\$479,000,000	\$
Profit	\$95,600,000	\$
Total construction costs	\$733,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$154,000,000	\$
Legal cost	\$14,700,000	\$
Engineering design fee	\$110,000,000	\$
Inspection cost	\$14,700,000	\$
Contingency	\$73,300,000	\$
Technical	\$14,700,000	\$
Total indirect costs	\$381,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$61,100,000	\$
LABOR COSTS		
Administration labor cost	\$177,000	\$/yr
Laboratory labor cost	\$116,000	\$/yr
Unit process operation labor cost	\$2,650,000	\$/yr
Unit process maintenance labor cost	\$1,900,000	\$/yr
Total labor costs	\$4,840,000	\$/yr
PROJECT SUMMARY		
Present worth	\$2,050,000,000	\$
Total project cost	\$1,180,000,000	\$
Total operation labor cost	\$2,940,000	\$/yr
Total maintenance labor cost	\$1,900,000	\$/yr
Total material cost	\$3,090,000	\$/yr
Total chemical cost	\$15,100,000	\$/yr
Total energy cost	\$10,700,000	\$/yr
Total amortization cost	\$39,500,000	\$/yr

Afluente Canoas (MM)

Tratamiento Preliminar

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		

Design Information		
Bar size		0,25 in
Bar spacing		0,235 in
Slope of bars from horizontal		15 degrees
Head loss through screen	2,6965E+308 ft	
Approach velocity		1,31 ft/s
Average flow through velocity (1,31 ft/s
Maximum flow through velocity		3 ft/s
Screen channel width		44 ft
Average channel depth		9,84 ft
Aerated Grit Chamber		
Design Information		
Maximum flow		731 MGD(US)
Average flow		368 MGD(US)
Minimum flow		322 MGD(US)
Temperature		60,8 deg F
Maximum flow through velocity		0,357 ft/s
Average flow through velocity (0,179 ft/s
Size of smallest particle 100%	0,00786 in	
Specific gravity of particle		2
Number of units		1
Maximum flow/unit		731 MGD(US)
Width of channel		214 ft
Depth of channel		14,8 ft
Length of channel		214 ft
Settling velocity of particle	0,0513 ft/s	
Hydraulic retention time		10 min
Volume of grit		0,11 MGD(US)
Air supply		3 cfm
Costs		
Construction and equipment cost	\$13,100,000	\$
Operational labor cost	\$359,000	\$/yr
Maintenance labor cost	\$119,000	\$/yr
Material and supply cost	\$329,000	\$/yr
Energy cost	\$49,400	\$/yr
Amortization cost	\$664,000	\$/yr

Coagulación y Floculación

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		
Design Information		
Chemical used	Equivalent Iron	
Chemical dosage		5 mg/L
Mass of chemical per year	2550000 kg/yr	
Chemical sludge production		31,9 mg/L
Organic sludge production		2,8 mg/L

Espasamiento por gravedad

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration		4 %
Thickened concentration		5 %
Mass loading		24 lb/(sqft·d)

Hydraulic loading	50,4 gal(US)/(sqft·d)
Hydraulic retention time	49,8 hr
Number of tanks	7
Tank volume	441000 cuft
Depth	14 ft
Surface area per tank	4500 sqft
Tank diameter	76 ft
Quantities	
Amount of sludge generated	530000 lb/d
Volume of thickened sludge	1,09 MGD(US)
Operation labor required	6850 pers-hrs/yr
Maintenance labor required	3270 pers-hrs/yr
Electrical energy required	39000 kWh/yr
Volume of earthwork required	401000 cuft
Slab thickness	11,4 in
Volume of slab concrete requir	35100 cuft
Wall thickness	14 in
Volume of wall concrete requir	31100 cuft
Costs	
Construction and equipment cost	\$2,350,000
Operational labor cost	\$54,800
Maintenance labor cost	\$26,900
Material and supply cost	\$23,500
Energy cost	\$7,790
Amortization cost	\$148,000

Espesador de Banda de Gravedad

Design Output Data

Description	Value	Units
Gravity Belt Thickener		
Design Information		
Belt filter width	6,56 ft	
Number of units	32	
Hydraulic loading per unit per r	0,18 MGD(US)	
Hydraulic loading required per	11,5 MGD(US)	
Final solids content	7 %	
Solids capture fraction	0,99	
Quantities		
Operation labor required	7620 pers-hrs/yr	
Maintenance labor required	1910 pers-hrs/yr	
Power	1320000 kWh/yr	
Polymer required	945 lb/d	
Dry solids produced	236000 lb/d	
Belt filter(s)	\$8,830,000	\$
Building	\$604,000	\$
Installation	\$2,210,000	\$
Polymer system	\$3,270,000	\$
Feed pumps	\$972,000	\$
Conveyor system	\$2,210,000	\$
Costs		
Operational labor cost	\$61,000	\$/yr
Maintenance labor cost	\$15,700	\$/yr
Chemical cost	\$782,000	\$/yr
Energy cost	\$264,000	\$/yr
Amortization cost	\$1,170,000	\$/yr

Sedimentación Primaria

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifi	21400	sqft
Diameter of each circular clarif	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	2,66	lb/(sqft·d)
Hydraulic retention time	2,66	hr
Weir length	49000	ft
Volume of sludge generated	1,59	MGD(US)
Surface overflow rate	2150	gal(US)/(sqft·d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete requir	374000	cuft
Wall thickness	15	in
Volume of wall concrete requir	183000	cuft
Costs		
Operational labor cost	\$68,700	\$/yr
Maintenance labor cost	\$40,000	\$/yr
Material and supply cost	\$141,000	\$/yr
Energy cost	\$12,700	\$/yr
Amortization cost	\$802,000	\$/yr

Notes

Effluent soluble TKN adjusted to satisfy user-specified TKN removal.

Waste Sludge Pumping

Design Information		
Average daily pumping rate	1,59	MGD(US)
Total pumping capacity	1,59	MGD(US)
Design capacity per pump	0,794	MGD(US)
Number of pumps	3	
Number of batteries	1	
Firm pumping capacity	1,59	MGD(US)
Quantities		
Operation labor required	467	pers-hrs/yr
Maintenance labor required	385	pers-hrs/yr
Electrical energy required	53200	kWh/yr
Volume of earthwork required	1850	cuft
Area of pump building	231	sqft
Costs		
Operational labor cost	\$3,740	\$/yr
Maintenance labor cost	\$3,170	\$/yr
Material and supply cost	\$552	\$/yr
Energy cost	\$10,600	\$/yr
Amortization cost	\$5,140	\$/yr

Digestion Anaerobica

Design Output Data

Description	Value	Units
-------------	-------	-------

Anaerobic Digestion	
Design Information	
Percent VSS destroyed	45 %
Solids concentration in digeste	3,4 %
Detention time	15 d
Digester depth	75 ft
Digester diameter	90 ft
Effective digester volume	7010000 cuft
Number of digesters per batter	14
Number of primary digesters pr	14
Number of secondary digesters	0
Number of batteries	1
Gas produced	25,4 MGD(US)
Heat required	34100000 BTU/hr
Digester gas required	14,2 MGD(US)
Total natural gas required	0 MGD(US)
Quantities	
Operation labor required	39200 pers-hrs/yr
Maintenance labor required	22600 pers-hrs/yr
Electrical energy required	3390000 kWh/yr
Volume of earthwork required	3130000 cuft
Slab thickness	22,3 in
Volume of slab concrete requir	1750000 cuft
Wall thickness	45 in
Volume of wall concrete requir	1240000 cuft
Sidewater depth	75 ft
Surface area/floor of 2-story cc	14100 sqft
Piping size	10 in
Length of total piping system	6200 ft
Number of 90 degree elbows	182
Number of tees	357
Number of plug valves	259
Total dry solids treated	715000 lb/d
Notes	
Mass balance based on user input	

Filtro Percolador

Design Output Data

Description	Value	Units
Trickling Filtration		
Design Information		
Reaction rate constant	0,00191	
Hydraulic loading rate	1080	gal(US)/(sqft·d)
Total hydraulic loading rate	1260	gal(US)/(sqft·d)
Recirculation ratio	0,167	
Number of towers per stage	48	
Number of stages	1	
Depth of filter tower	19,7	ft
Diameter of filter tower	180	ft
Surface area per filter tower	25400	sqft
Total surface area	1220000	sqft
Volume per filter tower	501000	cuft
Total volume	24000000	cuft
Quantities		
Operation labor required	12800	pers-hr/yr
Maintenance labor required	5200	pers-hr/yr

Volume of earthwork required	20800000	cuft
Volume of slab concrete requir	814000	cuft
Volume of wall concrete requir	692000	cuft
Number of posts per tower	1710	
Total length of precast beams	679000	ft

Costs

Construction and equipment cc	\$214,000,000	\$
Operational labor cost	\$102,000	\$/yr
Maintenance labor cost	\$42,800	\$/yr
Material and supply cost	\$1,310,000	\$/yr
Energy cost	\$26,700	\$/yr
Amortization cost	\$11,000,000	\$/yr

Internal Recycle Pumping

Design Information

Average daily pumping rate	879	MGD(US)
Total pumping capacity	879	MGD(US)
Design capacity per pump	27,5	MGD(US)
Number of pumps	5	
Number of batteries	8	
Firm pumping capacity	879	MGD(US)

Quantities

Operation labor required	20300	pers-hrs/yr
Maintenance labor required	12000	pers-hrs/yr
Electrical energy required	29000000	kWh/yr
Volume of earthwork required	152000	cuft
Area of pump building	18900	sqft

Costs

Construction and equipment cc	\$12,000,000	\$
Operational labor cost	\$163,000	\$/yr
Maintenance labor cost	\$98,500	\$/yr
Material and supply cost	\$84,000	\$/yr
Energy cost	\$5,800,000	\$/yr
Amortization cost	\$783,000	\$/yr

Deshidratación por centrifugas

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	4280	HP
Power required per unit	194	HP
Excess capacity factor	1,25	
Number of units	22	
Chemical dose	1	% dry wt
Chemicals required	14700	lb/d
Sludge flow	4,93	MGD(US)
Initial solid conc	3,4	%
Operational hours per day	8	hr
Operational days per week	7	d
Quantities		
Number of centrifuges	22	
Power required per unit	194	HP
Area of building	5900	sqft
Dry solids produced	466000	lb/d
Operation labor required	74500	pers-hrs/yr
Maintenance labor required	12000	pers-hrs/yr

Electrical energy required	5100000 kWh/yr
Polymer Feed System	
Quantities	
Polymer dosage	4890 lb/d
Liquid chemical solution fed	0,234 MGD(US)
O&M labor required	36400 pers-hrs/yr
Dry material handling and mixi	3050 pers-hrs/yr
Total operation labor required	39400 pers-hrs/yr

Generacion con motores de combustion biogas

Design Output Data

Description	Value	Units
-------------	-------	-------

Clarificador Secundario

Design Output Data

Description	Value	Units
-------------	-------	-------

Secondary Clarification		
Design Information		
Surface area	509000	sqft
Surface area per circular clarifi	25400	sqft
Diameter of each circular clarif	180	ft
Number of clarifiers per battery	4	
Number of batteries	5	
Solids loading rate	0,462	lb/(sqft·d)
Hydraulic retention time	3,67	hr
Weir length	48900	ft
Volume of wasted sludge	2,74	MGD(US)
Surface overflow rate	1440	gal(US)/(sqft·d)
Quantities		
Operation labor required	10900	pers-hrs/yr
Maintenance labor required	6190	pers-hrs/yr
Electrical energy required	80300	kWh/yr
Volume of earthwork required	8660000	cuft
Slab thickness	11,6	in
Volume of slab concrete requir	540000	cuft
Wall thickness	14,4	in
Volume of wall concrete requir	223000	cuft
Costs		
Operational labor cost	\$87,200	\$/yr
Maintenance labor cost	\$50,900	\$/yr
Material and supply cost	\$197,000	\$/yr
Energy cost	\$16,100	\$/yr
Amortization cost	\$1,110,000	\$/yr
Waste Sludge Pumping		
Design Information		
Average daily pumping rate	2,74	MGD(US)
Total pumping capacity	2,74	MGD(US)
Design capacity per pump	1,37	MGD(US)
Number of pumps	3	
Number of batteries	1	
Firm pumping capacity	2,74	MGD(US)
Quantities		
Operation labor required	501	pers-hrs/yr
Maintenance labor required	418	pers-hrs/yr
Electrical energy required	91600	kWh/yr
Volume of earthwork required	2030	cuft

Area of pump building		254 sqft
Costs		
Operational labor cost	\$4,010	\$/yr
Maintenance labor cost	\$3,440	\$/yr
Material and supply cost	\$685	\$/yr
Energy cost	\$18,300	\$/yr
Amortization cost	\$6,390	\$/yr

Secado Térmico

Design Output Data

Description	Value	Units
User Specified Sludge Treatment Process		
Design Information		
No Design Data		

Disposicion Final - Costo No Incluido

Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling		
Design Information		
Volume of sludge hauled	0,0502	MGD(US)
Truck capacity	810	cuft
Round trip time to disposal site	1	hr
Truck loading time	0,75	hr
Operational hours per day	8	hr
Number of trucks required	2	
Distance to disposal site	10	miles
Quantities		
Total sludge volume hauled	0,0502	MGD(US)
Maximum anticipated landfill d	30	d
Anticipated sludge storage hei	8	ft
Sludge storage shed area	25200	sqft
Width of sludge storage shed s	112	ft
Length of sludge storage shed	224	ft
Volume of earthwork required	65100	cuft
Volume of slab concrete requir	26700	cuft
Surface area of canopy roof	25200	sqft
Round trip haul distance	20	miles
Round trips per day per truck	5	
Distance traveled per year per	25000	miles
Sludge hauled	440000	lb/d
Operation labor required	3890	pers-hrs/yr
LandFilling cost	\$43,100	\$/yr

Desinfeccion por cloro

Design Output Data


Description	Value	Units
Chlorination		
Design Information		
Volume of tank	2030000	cuft
Average chlorine required	30400	lb/d
Peak chlorine required	60900	lb/d
Influent coliform count	10000000	/100mL
Effluent coliform count	29,2	/100mL
Quantities		
Operational labor required	9790	pers-hrs/yr

Maintenance labor required	11800 pers-hrs/yr
Electrical energy required	269000 kWh/yr
Volume of earthwork required	731000 cuft
Volume of slab concrete requir	204000 cuft
Volume of wall concrete require	167000 cuft
Number of chlorinators and ev:	4
Chlorination building area	1440 sqft
Number of chlorine cylinders	457
Area of chlorine storage buildir	64000 sqft

Costs

Construction and equipment cc	\$10,300,000	\$
Operational labor cost	\$78,300	\$/yr
Maintenance labor cost	\$97,200	\$/yr
Material and supply cost	\$140,000	\$/yr
Chemical cost	\$8,940,000	\$/yr
Energy cost	\$53,700	\$/yr
Amortization cost	\$657,000	\$/yr

FII-Alt3-BAF



Summary

Equipment Database

Sept 2007,(USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$3,410,000,000	\$1,660,000,000	\$3,040,000	\$2,060,000	\$2,510,000	\$16,600,000	\$20,300,000	\$88,000,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Tratamiento Preliminar	\$13,300,000	\$370,000	\$122,000	\$332,000	\$0	\$50,200	\$671,000
Sedimentación Primaria	\$36,000,000	\$72,400	\$43,000	\$142,000	\$0	\$23,800	\$807,000
BAF	\$550,000,000	\$330,000	\$330,000	\$1,000,000	\$0	\$15,000,000	\$56,000,000
Desinfección por cloro	\$10,300,000	\$78,300	\$96,800	\$140,000	\$8,940,000	\$53,700	\$656,000
Espesamiento por gravedad	\$2,350,000	\$56,400	\$27,400	\$23,500	\$0	\$7,960	\$148,000
Digestión Anaeróbica	\$14,700,000	\$398,000	\$23,700	\$322,000	\$0	\$846,000	\$15,000,000
Deshidratación por centrifugas	\$48,000,000	\$438,000	\$547,000	\$0	\$5,420,000	\$3,640,000	\$7,070,000
Espesador de Banda de Grave	\$30,500,000	\$173,000	\$44,300	\$0	\$2,200,000	\$694,000	\$6,620,000
Generación con motores de co	\$37,500,000	\$830,000	\$830,000	\$550,000	\$0	\$0	\$1,050,000
Other Costs	\$919,000,000	\$293,000	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		210 acre
Administration labor hours		35400 hr/yr
Laboratory labor hours		14500 hr/yr

Costs

DIRECT COSTS

Mobilization	\$14,500,000	\$
Site preparation	\$12,500,000	\$
Site electrical	\$48,400,000	\$
Yard piping	\$29,600,000	\$
Instrumentation and control	\$30,300,000	\$
Lab and administration building	\$23,100,000	\$
Unit process construction costs	\$743,000,000	\$
Profit	\$135,000,000	\$
Total construction costs	\$1,040,000,000	\$

INDIRECT COSTS

Miscellaneous cost	\$218,000,000	\$
Legal cost	\$20,700,000	\$
Engineering design fee	\$155,000,000	\$
Inspection cost	\$20,700,000	\$
Contingency	\$104,000,000	\$
Technical	\$20,700,000	\$
Total indirect costs	\$539,000,000	\$

MISC

Cost of land	\$0	\$
Interest during construction	\$86,400,000	\$

LABOR COSTS

Administration labor cost	\$177,000	\$/yr
Laboratory labor cost	\$116,000	\$/yr
Unit process operation labor cost	\$2,750,000	\$/yr
Unit process maintenance labor cost	\$2,060,000	\$/yr
Total labor costs	\$5,100,000	\$/yr

PROJECT SUMMARY

Present worth	\$3,410,000,000	\$
Total project cost	\$1,660,000,000	\$
Total operation labor cost	\$3,040,000	\$/yr
Total maintenance labor cost	\$2,060,000	\$/yr
Total material cost	\$2,510,000	\$/yr
Total chemical cost	\$16,600,000	\$/yr
Total energy cost	\$20,300,000	\$/yr
Total amortization cost	\$88,000,000	\$/yr

Afluente Canoas (MM) Tratamiento Preliminar Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		

Bar size	0,25 in	
Bar spacing	0,235 in	
Slope of bars from horizontal	15 degrees	
Head loss through screen	2,6965E+308 ft	
Approach velocity	1,31 ft/s	
Average flow through velocity (1,31 ft/s	
Maximum flow through velocity	3 ft/s	
Screen channel width	45,6 ft	
Average channel depth	9,84 ft	
Aerated Grit Chamber		
Design Information		
Maximum flow	744 MGD(US)	
Average flow	380 MGD(US)	
Minimum flow	335 MGD(US)	
Temperature	60,8 deg F	
Maximum flow through velocity	0,36 ft/s	
Average flow through velocity (0,184 ft/s	
Size of smallest particle 100%	0,00786 in	
Specific gravity of particle	2	
Number of units	1	
Maximum flow/unit	744 MGD(US)	
Width of channel	216 ft	
Depth of channel	14,8 ft	
Length of channel	216 ft	
Settling velocity of particle	0,0513 ft/s	
Hydraulic retention time	10 min	
Volume of grit	0,114 MGD(US)	
Air supply	3 cfm	
Costs		
Construction and equipment cost	\$13,300,000	\$
Operational labor cost	\$370,000	\$/yr
Maintenance labor cost	\$122,000	\$/yr
Material and supply cost	\$332,000	\$/yr
Energy cost	\$50,200	\$/yr
Amortization cost	\$671,000	\$/yr

Coagulacion y Floculacion

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		
Design Information		
Chemical used	Equivalent Iron	
Chemical dosage		5 mg/L
Mass of chemical per year	2640000	kg/yr
Chemical sludge production		30,9 mg/L
Organic sludge production		2,81 mg/L

Espasamiento pro gravedad

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration		4 %
Thickened concentration		5 %
Mass loading		24 lb/(sqft·d)
Hydraulic loading		52,3 gal(US)/(sqft·d)

Hydraulic retention time	48 hr	
Number of tanks	7	
Tank volume	441000 cuft	
Depth	14 ft	
Surface area per tank	4500 sqft	
Tank diameter	76 ft	
Quantities		
Amount of sludge generated	550000 lb/d	
Volume of thickened sludge	1,13 MGD(US)	
Operation labor required	7050 pers-hrs/yr	
Maintenance labor required	3340 pers-hrs/yr	
Electrical energy required	39800 kWh/yr	
Volume of earthwork required	401000 cuft	
Slab thickness	11,4 in	
Volume of slab concrete requir	35100 cuft	
Wall thickness	14 in	
Volume of wall concrete requir	31100 cuft	
Costs		
Construction and equipment cc	\$2,350,000	\$
Operational labor cost	\$56,400	\$/yr
Maintenance labor cost	\$27,400	\$/yr
Material and supply cost	\$23,500	\$/yr
Energy cost	\$7,960	\$/yr
Amortization cost	\$148,000	\$/yr

Espeador de Banda de Gravedad

Design Output Data

Description	Value	Units
Gravity Belt Thickener		
Design Information		
Belt filter width	6,56 ft	
Number of units	182	
Hydraulic loading per unit per r	0,18 MGD(US)	
Hydraulic loading required per	65,4 MGD(US)	
Final solids content	7 %	
Solids capture fraction	0,98	
Quantities		
Operation labor required	21700 pers-hrs/yr	
Maintenance labor required	5410 pers-hrs/yr	
Power	3470000 kWh/yr	
Polymer required	2660 lb/d	
Dry solids produced	664000 lb/d	
Belt filter(s)	\$50,200,000	\$
Building	\$2,870,000	\$
Installation	\$12,600,000	\$
Polymer system	\$18,600,000	\$
Feed pumps	\$5,530,000	\$
Conveyor system	\$12,600,000	\$
Costs		
Operational labor cost	\$173,000	\$/yr
Maintenance labor cost	\$44,300	\$/yr
Chemical cost	\$2,200,000	\$/yr
Energy cost	\$694,000	\$/yr
Amortization cost	\$6,620,000	\$/yr

Sedimentación Primaria

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifi	21400	sqft
Diameter of each circular clarif	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	2,76	lb/(sqft-d)
Hydraulic retention time	2,57	hr
Weir length	49800	ft
Volume of sludge generated	1,65	MGD(US)
Surface overflow rate	2180	gal(US)/(sqft-d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete requir	374000	cuft
Wall thickness	15	in
Volume of wall concrete requir	183000	cuft
Costs		
Operational labor cost	\$68,700	\$/yr
Maintenance labor cost	\$39,800	\$/yr
Material and supply cost	\$141,000	\$/yr
Energy cost	\$12,700	\$/yr
Amortization cost	\$802,000	\$/yr

Notes

Effluent soluble TKN adjusted to satisfy user-specified TKN removal.

Waste Sludge Pumping

Design Information		
Average daily pumping rate	1,65	MGD(US)
Total pumping capacity	1,65	MGD(US)
Design capacity per pump	0,824	MGD(US)
Number of pumps	3	
Number of batteries	1	
Firm pumping capacity	1,65	MGD(US)
Quantities		
Operation labor required	469	pers-hrs/yr
Maintenance labor required	388	pers-hrs/yr
Electrical energy required	55200	kWh/yr
Volume of earthwork required	1860	cuft
Area of pump building	233	sqft
Costs		
Operational labor cost	\$3,750	\$/yr
Maintenance labor cost	\$3,170	\$/yr
Material and supply cost	\$560	\$/yr
Energy cost	\$11,000	\$/yr
Amortization cost	\$5,220	\$/yr

Digestion Anaerobica

Design Output Data

Description	Value	Units
Anaerobic Digestion		

Design Information	
Percent VSS destroyed	45 %
Solids concentration in digester	3,4 %
Detention time	15 d
Digester depth	75 ft
Digester diameter	90 ft
Effective digester volume	7010000 cuft
Number of digesters per batter	14
Number of primary digesters per batter	14
Number of secondary digesters per batter	0
Number of batteries	1
Gas produced	50,6 MGD(US)
Heat required	45800000 BTU/hr
Digester gas required	19,1 MGD(US)
Total natural gas required	0 MGD(US)
Quantities	
Operation labor required	59100 pers-hrs/yr
Maintenance labor required	33400 pers-hrs/yr
Electrical energy required	5000000 kWh/yr
Volume of earthwork required	3130000 cuft
Slab thickness	22,3 in
Volume of slab concrete required	175000 cuft
Wall thickness	45 in
Volume of wall concrete required	1240000 cuft
Sidewater depth	75 ft
Surface area/floor of 2-story concrete	14100 sqft
Piping size	10 in
Length of total piping system	6200 ft
Number of 90 degree elbows	182
Number of tees	357
Number of plug valves	259
Total dry solids treated	1160000 lb/d
Notes	
Mass balance based on user input	

BAF

Design Output Data

Description	Value	Units
User Specified Wastewater Process		
Design Information		
No Design Data		

Deshidratación por centrifugas

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	6240	HP
Power required per unit	195	HP
Excess capacity factor	1,25	
Number of units	32	
Chemical dose	1	% dry wt
Chemicals required	21400	lb/d
Sludge flow	7,19	MGD(US)
Initial solid conc	3,4	%
Operational hours per day	8	hr

Operational days per week	7 d
Quantities	
Number of centrifuges	32
Power required per unit	195 HP
Area of building	8510 sqft
Dry solids produced	680000 lb/d
Operation labor required	104000 pers-hrs/yr
Maintenance labor required	16600 pers-hrs/yr
Electrical energy required	7240000 kWh/yr
Polymer Feed System	
Quantities	
Polymer dosage	7140 lb/d
Liquid chemical solution fed	0,342 MGD(US)
O&M labor required	46500 pers-hrs/yr
Dry material handling and mixi	3390 pers-hrs/yr
Total operation labor required	49900 pers-hrs/yr

Generacion con motores de combustion biogas

Design Output Data

Description	Value	Units
-------------	-------	-------

Secado Térmico

Design Output Data

Description	Value	Units
-------------	-------	-------

User Specified Sludge Treatment Process
Design Information
No Design Data

Desinfeccion por cloro

Design Output Data

Description	Value	Units
-------------	-------	-------

Chlorination		
Design Information		
Volume of tank	2030000	cuft
Average chlorine required	30400	lb/d
Peak chlorine required	60900	lb/d
Influent coliform count	10000000	/100mL
Effluent coliform count	29,2	/100mL
Quantities		
Operational labor required	9790	pers-hrs/yr
Maintenance labor required	11800	pers-hrs/yr
Electrical energy required	269000	kWh/yr
Volume of earthwork required	731000	cuft
Volume of slab concrete requir	204000	cuft
Volume of wall concrete requir	167000	cuft
Number of chlorinators and ev:	4	
Chlorination building area	1440	sqft
Number of chlorine cylinders	457	
Area of chlorine storage buildir	64000	sqft
Costs		
Construction and equipment cc	\$10,300,000	\$
Operational labor cost	\$78,300	\$/yr
Maintenance labor cost	\$96,800	\$/yr
Material and supply cost	\$140,000	\$/yr
Chemical cost	\$8,940,000	\$/yr
Energy cost	\$53,700	\$/yr


Amortization cost	\$656,000	\$/yr
-------------------	-----------	-------

Disposicion Final - Costo No Includo

Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling		
Design Information		
Volume of sludge hauled	0,0733	MGD(US)
Truck capacity	810	cuft
Round trip time to disposal site	1	hr
Truck loading time	0,75	hr
Operational hours per day	8	hr
Number of trucks required	3	
Distance to disposal site	10	miles
Quantities		
Total sludge volume hauled	0,0733	MGD(US)
Maximum anticipated landfill d	30	d
Anticipated sludge storage heiç	8	ft
Sludge storage shed area	36800	sqft
Width of sludge storage shed s	136	ft
Length of sludge storage shed	271	ft
Volume of earthwork required	94500	cuft
Volume of slab concrete requir	38600	cuft
Surface area of canopy roof	36800	sqft
Round trip haul distance	20	miles
Round trips per day per truck	5	
Distance traveled per year per	25000	miles
Sludge hauled	643000	lb/d
Operation labor required	5680	pers-hrs/yr
LandFilling cost	\$43,100	\$/yr

FIII/FII-línea de lodos THP



Summary

Equipment Database

Sept 2007,(USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$1,140,000,000	\$402,000,000	\$1,390,000	\$915,000	\$13,000,000	\$6,950,000	\$5,250,000	\$22,600,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Espesamiento pro gravedad	\$10.000.000	\$58.200	\$28.600	\$23.500	\$0	\$8.150	\$148.000
Digestion Anaerobica	\$149.000.000	\$518.000	\$308.000	\$418.000	\$0	\$1.100.000	\$15.000.000
Deshidratación por centrifugas	\$23.000.000	\$438.000	\$547.000	\$0	\$5.420.000	\$3.640.000	\$7.070.000
Disposicion Final	\$5.760.000	\$254.000	\$0	\$12.500.000	\$0	\$0	\$422.000
Espesador de Banda de Gravedad	\$30.500.000	\$120.000	\$31.300	\$0	\$1.530.000	\$494.000	\$0
Other Costs	\$184.000.000	\$0	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		8,57 acre
Administration labor hours		0 hr/yr
Laboratory labor hours		0 hr/yr
Costs		
DIRECT COSTS		
Unit process construction cost	\$218,000,000	\$
Profit	\$32,700,000	\$
Total construction costs	\$251,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$52,700,000	\$
Legal cost	\$5,020,000	\$
Engineering design fee	\$37,700,000	\$
Inspection cost	\$5,020,000	\$
Contingency	\$25,100,000	\$
Technical	\$5,020,000	\$
Total indirect costs	\$131,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$20,900,000	\$
LABOR COSTS		
Administration labor cost	\$0	\$/yr
Laboratory labor cost	\$0	\$/yr
Unit process operation labor cost	\$1,390,000	\$/yr
Unit process maintenance labor cost	\$915,000	\$/yr
Total labor costs	\$2,300,000	\$/yr

PROJECT SUMMARY

Present worth	\$1,140,000,000	\$
Total project cost	\$402,000,000	\$
Total operation labor cost	\$1,390,000	\$/yr
Total maintenance labor cost	\$915,000	\$/yr
Total material cost	\$13,000,000	\$/yr
Total chemical cost	\$6,950,000	\$/yr
Total energy cost	\$5,250,000	\$/yr
Total amortization cost	\$22,600,000	\$/yr

Afluente Canoas (MM)

Tratamiento Preliminar

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		
Bar size		0,25 in
Bar spacing		0,235 in
Slope of bars from horizontal		15 degrees
Head loss through screen	2,6965E+308	ft
Approach velocity		1,31 ft/s
Average flow through velocity (1,31 ft/s
Maximum flow through velocity		3 ft/s
Screen channel width		45,3 ft
Average channel depth		9,84 ft
Aerated Grit Chamber		
Design Information		
Maximum flow		742 MGD(US)
Average flow		378 MGD(US)

Minimum flow	333 MGD(US)
Temperature	60,8 deg F
Maximum flow through velocity	0,359 ft/s
Average flow through velocity (0,183 ft/s
Size of smallest particle 100%	0,00786 in
Specific gravity of particle	2
Number of units	1
Maximum flow/unit	742 MGD(US)
Width of channel	216 ft
Depth of channel	14,8 ft
Length of channel	216 ft
Settling velocity of particle	0,0513 ft/s
Hydraulic retention time	10 min
Volume of grit	0,113 MGD(US)
Air supply	3 cfm

Coagulación y Floculación

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		
Design Information		
Chemical used	Equivalent Iron	
Chemical dosage	12 mg/L	
Mass of chemical per year	6300000 kg/yr	
Chemical sludge production	40 mg/L	
Organic sludge production	6,71 mg/L	

Espasamiento pro gravedad

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration	1 %	
Thickened concentration	5 %	
Mass loading	24 lb/(sqft·d)	
Hydraulic loading	218 gal(US)/(sqft·d)	
Hydraulic retention time	11,5 hr	
Number of tanks	7	
Tank volume	441000 cuft	
Depth	14 ft	
Surface area per tank	4500 sqft	
Tank diameter	76 ft	
Quantities		
Amount of sludge generated	572000 lb/d	
Volume of thickened sludge	1,18 MGD(US)	
Operation labor required	7270 pers-hrs/yr	
Maintenance labor required	3430 pers-hrs/yr	
Electrical energy required	40800 kWh/yr	
Volume of earthwork required	401000 cuft	
Slab thickness	11,4 in	
Volume of slab concrete requir	35100 cuft	
Wall thickness	14 in	
Volume of wall concrete requir	31100 cuft	
Costs		
Operational labor cost	\$58,200	\$/yr
Maintenance labor cost	\$28,600	\$/yr
Material and supply cost	\$23,500	\$/yr
Energy cost	\$8,150	\$/yr
Amortization cost	\$148,000	\$/yr

Espesador de Banda de Gravedad

Design Output Data

Description	Value	Units
Gravity Belt Thickener		

Design Information		
Belt filter width		6,56 ft
Number of units		94
Hydraulic loading per unit per r		0,18 MGD(US)
Hydraulic loading required per		33,8 MGD(US)
Final solids content		6 %
Solids capture fraction		0,985
Quantities		
Operation labor required		15000 pers-hrs/yr
Maintenance labor required		3750 pers-hrs/yr
Power		2470000 kWh/yr
Polymer required		1850 lb/d
Dry solids produced		463000 lb/d
Belt filter(s)	\$25,900,000	\$
Building	\$1,540,000	\$
Installation	\$6,490,000	\$
Polymer system	\$9,600,000	\$
Feed pumps	\$2,850,000	\$
Conveyor system	\$6,490,000	\$
Costs		
Operational labor cost	\$120,000	\$/yr
Maintenance labor cost	\$31,300	\$/yr
Chemical cost	\$1,530,000	\$/yr
Energy cost	\$494,000	\$/yr

Sedimentación Primaria

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifi	21400	sqft
Diameter of each circular clarif	165	ft
Number of clarifiers per batter	4	
Number of batteries	4	
Solids loading rate	2,85	lb/(sqft·d)
Hydraulic retention time	2,59	hr
Weir length	49700	ft
Volume of sludge generated	6,86	MGD(US)
Surface overflow rate	2180	gal(US)/(sqft·d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete requir	374000	cuft
Wall thickness	15	in
Volume of wall concrete requir	183000	cuft
Notes		
Effluent soluble TKN adjusted to satisfy user-specified TKN removal.		
Waste Sludge Pumping		
Design Information		
Average daily pumping rate	6,86	MGD(US)
Total pumping capacity	6,86	MGD(US)
Design capacity per pump	3,43	MGD(US)
Number of pumps	3	
Number of batteries	1	
Firm pumping capacity	6,86	MGD(US)
Quantities		
Operation labor required	564	pers-hrs/yr
Maintenance labor required	479	pers-hrs/yr
Electrical energy required	229000	kWh/yr
Volume of earthwork required	2680	cuft

Area of pump building 335 sqft

Digestion Anaerobica

Design Output Data

Description	Value	Units
Anaerobic Digestion		
Design Information		
Percent VSS destroyed	43	%
Solids concentration in digeste	3,4	%
Detention time	15	d
Digester depth	75	ft
Digester diameter	90	ft
Effective digester volume	7010000	cuft
Number of digesters per batter	14	
Number of primary digesters p	14	
Number of secondary digester:	0	
Number of batteries	1	
Gas produced	29,5	MGD(US)
Heat required	43300000	BTU/hr
Digester gas required	18	MGD(US)
Total natural gas required	0	MGD(US)
Quantities		
Operation labor required	51200	pers-hrs/yr
Maintenance labor required	29100	pers-hrs/yr
Electrical energy required	4360000	kWh/yr
Volume of earthwork required	3130000	cuft
Slab thickness	22,3	in
Volume of slab concrete requir	175000	cuft
Wall thickness	45	in
Volume of wall concrete requir	1240000	cuft
Sidewater depth	75	ft
Surface area/floor of 2-story cc	14100	sqft
Piping size	10	in
Length of total piping system	6200	ft
Number of 90 degree elbows	182	
Number of tees	357	
Number of plug valves	259	
Total dry solids treated	982000	lb/d
Notes		
Mass balance based on user input		

Alimentacion Escalonada

Design Output Data

Description	Value	Units
BNR System for BIO-P and N Removal		
Design Information		
Design Override Enabled - sizi		
5-Stage Biological Phosphorus		
Design aerobic SRT for nitrifica	5	d
Total reactor SRT	10	d
Design SS	2260	mg/L
Calculated VSS	1390	mg/L
Calculated VSS:TSS ratio	0,613	lb VSS/lb SS
Total volume of anaerobic reac	366000	cuft
Total volume of anoxic reactor:	16000000	cuft
Total volume of aerobic reacto	16400000	cuft
Total volume of all reactors	32800000	cuft
Width of parallel train	262	ft
Sidewater depth	16,4	ft
Number of batteries	1	
Number of parallel trains per b:	24	
Number of anoxic cells within c	3	
Number of aerobic cells within	3	
Anaerobic hydraulic retention t	0,176	hr

Anoxic hydraulic retention time	7,72 hr
Aerobic hydraulic retention time	7,9 hr
Amount of sludge generated	464000 lb/d
Sludge recycle ratio	51 %
Sludge recycle rate	190 MGD(US)
Nitrogen required for biomass	14,9 mg/L
Phosphorus required for biomass	2,98 mg/L
Oxygen required to meet average	944000 lb/d
Air flow required to meet average	277000 scfm
Design air flow	16,9 scfm/1000 cuft
Design air flow	6,65 scfm/ft2

Quantities

Operation labor required	19800 pers-hrs/yr
Maintenance labor required	14900 pers-hrs/yr
Electrical energy required	81000000 kWh/yr
Volume of earthwork required	14200000 cuft
Volume of slab concrete required	4250000 cuft
Volume of wall concrete required	578000 cuft
Handrail length	15400 ft
Number of diffusers per train	5770
Fine bubble diffuser floor coverage	6,12 %
Number of swing arm headers	13
Required mixing power	8100 HP
Total number of mixers	288
Required mixing power per mixer	28,1 HP
Design mixing power per mixer	5 HP
Mixing power for each unaerated	84,4 HP

Notes

Minimum SRT not calculated, design SRT specified by user

Design is based on user specified design overrides - Performance data is assumed to be correct.

WARNING: Anoxic HRT is out of the normal range, consider changing your design override values

WARNING: Anaerobic HRT is out of the normal range, consider changing your design override values

Required hp per mixer exceeds the maximum allowed of 5 hp/mixer, consider increasing number of mixers per tank

Aerobic-Anoxic internal recycle pumps sized for 4x the influent flow

Internal Recycle Pumping

Design Information

Average daily pumping rate	62,2 MGD(US)
Total pumping capacity	62,2 MGD(US)
Design capacity per pump	20,7 MGD(US)
Number of pumps	96
Number of batteries	1
Firm pumping capacity	62,2 MGD(US)

Quantities

Operation labor required	1450 pers-hrs/yr
Maintenance labor required	1230 pers-hrs/yr
Electrical energy required	2060000 kWh/yr
Volume of earthwork required	11400 cuft
Area of pump building	1430 sqft

Notes

Pumps are sized based on an individual battery of internal pumps for each train

Sludge Recycle Pumping

Design Information

Average daily pumping rate	373 MGD(US)
Total pumping capacity	373 MGD(US)
Design capacity per pump	23,3 MGD(US)
Number of pumps	5
Number of batteries	4
Firm pumping capacity	373 MGD(US)

Quantities

Operation labor required	8530 pers-hrs/yr
Maintenance labor required	5630 pers-hrs/yr
Electrical energy required	12300000 kWh/yr
Volume of earthwork required	65200 cuft
Area of pump building	8160 sqft

Deshidratación por centrifugas

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	6290	HP
Power required per unit	196	HP
Excess capacity factor	1,25	
Number of units	32	
Chemical dose	1	% dry wt
Chemicals required	21600	lb/d
Sludge flow	7,24	MGD(US)
Initial solid conc	3,4	%
Operational hours per day	8	hr
Operational days per week	7	d
Quantities		
Number of centrifuges	32	
Power required per unit	196	HP
Area of building	8550	sqft
Dry solids produced	685000	lb/d
Operation labor required	104000	pers-hrs/yr
Maintenance labor required	16700	pers-hrs/yr
Electrical energy required	7280000	kWh/yr
Polymer Feed System		
Quantities		
Polymer dosage	7190	lb/d
Liquid chemical solution fed	0,345	MGD(US)
O&M labor required	46700	pers-hrs/yr
Dry material handling and mixi	3400	pers-hrs/yr
Total operation labor required	50100	pers-hrs/yr

Generacion con motores de combustion biogas

Design Output Data

Description	Value	Units
--------------------	--------------	--------------

Sedimentador Secundario

Design Output Data

Description	Value	Units
Secondary Clarification		
Design Information		
Surface area	509000	sqft
Surface area per circular clarifi	25400	sqft
Diameter of each circular clarif	180	ft
Number of clarifiers per batter	5	
Number of batteries	4	
Solids loading rate	20,9	lb/(sqft·d)
Hydraulic retention time	4,16	hr
Weir length	49200	ft
Volume of wasted sludge	8,06	MGD(US)
Surface overflow rate	733	gal(US)/(sqft·d)
Quantities		
Operation labor required	10900	pers-hrs/yr
Maintenance labor required	6190	pers-hrs/yr
Electrical energy required	80300	kWh/yr
Volume of earthwork required	8660000	cuft
Slab thickness	12,2	in
Volume of slab concrete requir	566000	cuft
Wall thickness	15,5	in
Volume of wall concrete requir	273000	cuft
Waste Sludge Pumping		
Design Information		
Average daily pumping rate	8,06	MGD(US)
Total pumping capacity	8,06	MGD(US)

Design capacity per pump	4,03 MGD(US)
Number of pumps	3
Number of batteries	1
Firm pumping capacity	8,06 MGD(US)
Quantities	
Operation labor required	592 pers-hrs/yr
Maintenance labor required	502 pers-hrs/yr
Electrical energy required	269000 kWh/yr
Volume of earthwork required	2870 cuft
Area of pump building	359 sqft

Secado Térmico

Design Output Data

Description	Value	Units
-------------	-------	-------

Disposicion Final

Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling		
Design Information		
Volume of sludge hauled	0,263 MGD(US)	
Truck capacity	810 cuft	
Round trip time to disposal site	1 hr	
Truck loading time	0,75 hr	
Operational hours per day	8 hr	
Number of trucks required	10	
Distance to disposal site	15,5 miles	
Quantities		
Total sludge volume hauled	0,263 MGD(US)	
Maximum anticipated landfill duration	30 d	
Anticipated sludge storage height	8 ft	
Sludge storage shed area	132000 sqft	
Width of sludge storage shed	257 ft	
Length of sludge storage shed	514 ft	
Volume of earthwork required	336000 cuft	
Volume of slab concrete required	136000 cuft	
Surface area of canopy roof	132000 sqft	
Round trip haul distance	31,1 miles	
Round trips per day per truck	5	
Distance traveled per year per truck	38800 miles	
Sludge hauled	2310000 lb/d	
Operation labor required	31700 pers-hrs/yr	
Landfilling cost	\$11,200,000	\$/yr
Costs		
Construction and equipment cost	\$5,760,000	\$
Operational labor cost	\$254,000	\$/yr
Material and supply cost	\$12,500,000	\$/yr
Amortization cost	\$422,000	\$/yr


Desinfeccion por cloro

Design Output Data

Description	Value	Units
Chlorination		
Design Information		
Volume of tank	2030000 cuft	
Average chlorine required	30400 lb/d	
Peak chlorine required	60900 lb/d	
Influent coliform count	10000000 /100mL	
Effluent coliform count	29,2 /100mL	
Quantities		
Operational labor required	9790 pers-hrs/yr	
Maintenance labor required	11800 pers-hrs/yr	
Electrical energy required	269000 kWh/yr	
Volume of earthwork required	731000 cuft	

Volume of slab concrete requir	204000 cuft
Volume of wall concrete requir	167000 cuft
Number of chlorinators and ev:	4
Chlorination building area	1440 sqft
Number of chlorine cylinders	457
Area of chlorine storage buildir	64000 sqft

FII-Alt 1- Alim Esc



Summary

Equipment Database

Sept 2007, (USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$2,360,000,000	\$1,090,000,000	\$2,950,000	\$1,940,000	\$2,360,000	\$16,200,000	\$27,400,000	\$39,800,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Tratamiento Preliminar	\$13,200,000	\$363,000	\$122,000	\$330,000	\$0	\$49,700	\$666,000
Sedimentación Primaria	\$36,000,000	\$72,400	\$43,700	\$142,000	\$0	\$23,500	\$807,000
Alimentación Escalonada (MLE)	\$89,400,000	\$184,000	\$151,000	\$678,000	\$0	\$22,100,000	\$6,120,000
Sedimentador Secundario	\$61,000,000	\$91,700	\$55,600	\$174,000	\$0	\$59,600	\$1,000,000
Desinfección por cloro	\$10,300,000	\$78,300	\$98,600	\$140,000	\$98,940,000	\$53,700	\$656,000
Espasamiento pro gravedad	\$2,350,000	\$55,500	\$27,500	\$23,500	\$0	\$7,860	\$148,000
Digestión Anaerobica	\$14,700,000	\$398,000	\$23,700	\$322,000	\$0	\$846,000	\$15,000,000
Deshidratación por centrifugas	\$48,000,000	\$438,000	\$547,000	\$0	\$5,420,000	\$3,640,000	\$7,070,000
Espesador de Banda de Gravedad	\$30,500,000	\$145,000	\$37,900	\$0	\$1,860,000	\$590,000	\$2,800,000
Generación con motores de cc	\$37,500,000	\$830,000	\$830,000	\$550,000	\$0	\$0	\$1,050,000
Blower System	\$88,400,000	\$0	\$0	\$0	\$0	\$0	\$4,470,000
Other Costs	\$656,000,000	\$293,000	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		210 acre
Administration labor hours		35400 hr/yr
Laboratory labor hours		14500 hr/yr
Costs		
DIRECT COSTS		
Mobilization	\$14,500,000	\$
Site preparation	\$12,500,000	\$
Site electrical	\$48,400,000	\$
Yard piping	\$29,600,000	\$
Instrumentation and control	\$30,300,000	\$
Lab and administration building	\$23,100,000	\$
Unit process construction cost	\$431,000,000	\$
Profit	\$88,500,000	\$
Total construction costs	\$678,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$142,000,000	\$
Legal cost	\$13,600,000	\$
Engineering design fee	\$102,000,000	\$
Inspection cost	\$13,600,000	\$
Contingency	\$67,800,000	\$
Technical	\$13,600,000	\$
Total indirect costs	\$353,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$56,500,000	\$
LABOR COSTS		
Administration labor cost	\$177,000	\$/yr
Laboratory labor cost	\$116,000	\$/yr
Unit process operation labor cost	\$2,660,000	\$/yr
Unit process maintenance labor cost	\$1,940,000	\$/yr
Total labor costs	\$4,880,000	\$/yr
PROJECT SUMMARY		
Present worth	\$2,360,000,000	\$
Total project cost	\$1,090,000,000	\$
Total operation labor cost	\$2,950,000	\$/yr
Total maintenance labor cost	\$1,940,000	\$/yr
Total material cost	\$2,360,000	\$/yr
Total chemical cost	\$16,200,000	\$/yr
Total energy cost	\$27,400,000	\$/yr
Total amortization cost	\$39,800,000	\$/yr

Summary of Air Supply System

Description	Value	Units
Blower System for Entire Plant		

Design Information

Minimum air flow capacity	349000	scfm
Safety factor	1,5	
Requested air flow capacity	524000	scfm
Total capacity of blowers	524000	scfm
Number of blowers in use	6	
Total number of blowers	7	
Capacity of individual blowers	87400	scfm
Estimated cost of an installed blower	\$11,400,000	\$
Blower building area	3730	sqft
Costs		
Construction and equipment cost	\$88,400,000	\$
Amortization cost	\$4,470,000	\$/yr

Notes

Energy costs are shown at the individual unit processes that require air

Afluyente Canoas (MM)

Tratamiento Preliminar

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		
Bar size	0,25	in
Bar spacing	0,235	in
Slope of bars from horizontal	15	degrees
Head loss through screen	2,6965E+308	ft
Approach velocity	1,31	ft/s
Average flow through velocity (1,31	ft/s
Maximum flow through velocity	3	ft/s
Screen channel width	44,5	ft
Average channel depth	9,84	ft
Aerated Grit Chamber		
Design Information		
Maximum flow	735	MGD(US)
Average flow	371	MGD(US)
Minimum flow	326	MGD(US)
Temperature	60,8	deg F
Maximum flow through velocity	0,358	ft/s
Average flow through velocity (0,181	ft/s
Size of smallest particle 100%	0,00786	in
Specific gravity of particle	2	
Number of units	1	
Maximum flow/unit	735	MGD(US)
Width of channel	215	ft
Depth of channel	14,8	ft
Length of channel	215	ft
Settling velocity of particle	0,0513	ft/s
Hydraulic retention time	10	min
Volume of grit	0,111	MGD(US)
Air supply	3	cfm
Costs		
Construction and equipment cost	\$13,200,000	\$
Operational labor cost	\$363,000	\$/yr

Maintenance labor cost	\$122,000	\$/yr
Material and supply cost	\$330,000	\$/yr
Energy cost	\$49,700	\$/yr
Amortization cost	\$666,000	\$/yr

Coagulación y Floculación

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		
Design Information		
Chemical used	Equivalent Iron	
Chemical dosage		5 mg/L
Mass of chemical per year	2580000	kg/yr
Chemical sludge production		31,4 mg/L
Organic sludge production		2,8 mg/L

Espesamiento pro gravedad

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration		4 %
Thickened concentration		5 %
Mass loading		24 lb/(sqft-d)
Hydraulic loading		51,2 gal(US)/(sqft-d)
Hydraulic retention time		49,1 hr
Number of tanks		7
Tank volume	441000	cuft
Depth		14 ft
Surface area per tank		4500 sqft
Tank diameter		76 ft
Quantities		
Amount of sludge generated	538000	lb/d
Volume of thickened sludge	1,11	MGD(US)
Operation labor required	6930	pers-hrs/yr
Maintenance labor required	3300	pers-hrs/yr
Electrical energy required	39300	kWh/yr
Volume of earthwork required	401000	cuft
Slab thickness		11,4 in
Volume of slab concrete requir	35100	cuft
Wall thickness		14 in
Volume of wall concrete requir	31100	cuft
Costs		
Construction and equipment cost	\$2,350,000	\$
Operational labor cost	\$55,500	\$/yr
Maintenance labor cost	\$27,500	\$/yr
Material and supply cost	\$23,500	\$/yr
Energy cost	\$7,860	\$/yr
Amortization cost	\$148,000	\$/yr

Espesador de Banda de Gravedad

Design Output Data

Description	Value	Units
-------------	-------	-------

Gravity Belt Thickener		
Design Information		
Belt filter width		6,56 ft
Number of units		77
Hydraulic loading per unit per r		0,18 MGD(US)
Hydraulic loading required per		27,5 MGD(US)
Final solids content		7 %
Solids capture fraction		0,99
Quantities		
Operation labor required		18200 pers-hrs/yr
Maintenance labor required		4540 pers-hrs/yr
Power		2950000 kWh/yr
Polymer required		2250 lb/d
Dry solids produced		563000 lb/d
Belt filter(s)	\$21,300,000	\$
Building	\$1,280,000	\$
Installation	\$5,310,000	\$
Polymer system	\$7,860,000	\$
Feed pumps	\$2,340,000	\$
Conveyor system	\$5,310,000	\$
Costs		
Operational labor cost	\$145,000	\$/yr
Maintenance labor cost	\$37,900	\$/yr
Chemical cost	\$1,860,000	\$/yr
Energy cost	\$590,000	\$/yr
Amortization cost	\$2,800,000	\$/yr

Sedimentación Primaria

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifi	21400	sqft
Diameter of each circular clarif	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	2,7	lb/(sqft·d)
Hydraulic retention time	2,63	hr
Weir length	49200	ft
Volume of sludge generated	1,61	MGD(US)
Surface overflow rate	2160	gal(US)/(sqft·d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete requir	374000	cuft
Wall thickness	15	in
Volume of wall concrete requir	183000	cuft
Costs		
Operational labor cost	\$68,700	\$/yr

Maintenance labor cost	\$40,500	\$/yr
Material and supply cost	\$141,000	\$/yr
Energy cost	\$12,700	\$/yr
Amortization cost	\$802,000	\$/yr

Notes

Effluent soluble TKN adjusted to satisfy user-specified TKN removal.

Waste Sludge Pumping

Design Information

Average daily pumping rate	1,61 MGD(US)
Total pumping capacity	1,61 MGD(US)
Design capacity per pump	0,806 MGD(US)
Number of pumps	3
Number of batteries	1
Firm pumping capacity	1,61 MGD(US)

Quantities

Operation labor required	468 pers-hrs/yr
Maintenance labor required	386 pers-hrs/yr
Electrical energy required	54000 kWh/yr
Volume of earthwork required	1850 cuft
Area of pump building	232 sqft

Costs

Operational labor cost	\$3,740	\$/yr
Maintenance labor cost	\$3,220	\$/yr
Material and supply cost	\$555	\$/yr
Energy cost	\$10,800	\$/yr
Amortization cost	\$5,180	\$/yr

Digestion Anaerobica

Design Output Data

Description	Value	Units
Anaerobic Digestion		
Design Information		
Percent VSS destroyed	45	%
Solids concentration in digeste	3,4	%
Detention time	15	d
Digester depth	75	ft
Digester diameter	90	ft
Effective digester volume	7010000	cuft
Number of digesters per batter	14	
Number of primary digesters p	14	
Number of secondary digester:	0	
Number of batteries	1	
Gas produced	37,8	MGD(US)
Heat required	42800000	BTU/hr
Digester gas required	17,8	MGD(US)
Total natural gas required	0	MGD(US)
Quantities		
Operation labor required	54200	pers-hrs/yr
Maintenance labor required	30800	pers-hrs/yr
Electrical energy required	4610000	kWh/yr
Volume of earthwork required	3130000	cuft
Slab thickness	22,3	in
Volume of slab concrete requir	175000	cuft

Wall thickness	45 in
Volume of wall concrete required	1240000 cuft
Sidewater depth	75 ft
Surface area/floor of 2-story cc	14100 sqft
Piping size	10 in
Length of total piping system	6200 ft
Number of 90 degree elbows	182
Number of tees	357
Number of plug valves	259
Total dry solids treated	1050000 lb/d
Notes	
Mass balance based on user input	

Alimentacion Escalonada (MLE)

Design Output Data

Description	Value	Units
Pre-Denitrification Activated Sludge Design Information		
Design Override Enabled - size		
Pre-denitrification Design		
Design aerobic SRT for nitrification	3 d	
Total reactor SRT	3,27 d	
Design SS	3060 mg/L	
Calculated VSS	2330 mg/L	
Calculated VSS:TSS ratio	0,76 lb VSS/lb SS	
Total volume of anoxic reactor	802000 cuft	
Total volume of aerobic reactor	8820000 cuft	
Total volume of all reactors	9630000 cuft	
Width of parallel train	22 ft	
Sidewater depth	16,4 ft	
Number of batteries	1	
Number of parallel trains per battery	7	
Number of anoxic cells within battery	1	
Number of aerobic cells within battery	3	
Total number of dividing walls	21	
Anoxic hydraulic retention time	0,387 hr	
Aerobic hydraulic retention time	4,26 hr	
Amount of sludge generated	562000 lb/d	
Sludge recycle rate	164 MGD(US)	
Nitrogen requirement for biomass	13,8 mg/L	
Phosphorus requirement for biomass	2,76 mg/L	
Oxygen requirement to meet average	983000 lb/d	
Air flow required to meet average	349000 scfm	
Design air flow	39,6 scfm/1000 cuft	
Design air flow	4,55 scfm/ft2	
Quantities		
Operation labor required	17900 pers-hrs/yr	
Maintenance labor required	14100 pers-hrs/yr	
Electrical energy required	90700000 kWh/yr	
Volume of earthwork required	4400000 cuft	
Volume of slab concrete required	1150000 cuft	
Volume of wall concrete required	985000 cuft	
Handrail length	42200 ft	

Number of diffusers per train	25000
Fine bubble diffuser floor cover	14,4 %
Number of swing arm headers	153
Required mixing power	396 HP
Total number of mixers	21
Required mixing power per mixer	18,9 HP
Design mixing power per mixer	5 HP
Mixing power for each unaerated	56,6 HP

Costs

Construction and equipment cost	\$72,600,000	\$
Operational labor cost	\$143,000	\$/yr
Maintenance labor cost	\$118,000	\$/yr
Material and supply cost	\$561,000	\$/yr
Energy cost	\$18,100,000	\$/yr
Amortization cost	\$5,030,000	\$/yr

Notes

Minimum winter SRT not calculated, design SRT specified by user

WARNING: User inputs for autotrophic kinetics and/or SRT suggest system may not nitrify, consider changing inputs

Design is based on user specified design overrides - Performance data is assumed to be correct.

WARNING: Anoxic HRT is out of the normal range

Required hp per mixer exceeds the maximum allowed of 5 hp/mixer, consider increasing number of mixers per tank

Internal Recycle Pumping

Design Information

Average daily pumping rate	62,8 MGD(US)
Total pumping capacity	126 MGD(US)
Design capacity per pump	20,9 MGD(US)
Number of pumps	28
Number of batteries	2
Firm pumping capacity	62,8 MGD(US)

Quantities

Operation labor required	1460 pers-hrs/yr
Maintenance labor required	1240 pers-hrs/yr
Electrical energy required	2080000 kWh/yr
Volume of earthwork required	23000 cuft
Area of pump building	2880 sqft

Costs

Construction and equipment cost	\$12,300,000	\$
Operational labor cost	\$11,700	\$/yr
Maintenance labor cost	\$10,300	\$/yr
Material and supply cost	\$86,100	\$/yr
Energy cost	\$2,920,000	\$/yr
Amortization cost	\$803,000	\$/yr

Notes

Pumps are sized based on an individual battery of internal pumps for each train

Sludge Recycle Pumping

Design Information

Average daily pumping rate	164 MGD(US)
Total pumping capacity	327 MGD(US)
Design capacity per pump	27,3 MGD(US)
Number of pumps	5
Number of batteries	3
Firm pumping capacity	164 MGD(US)

Quantities

Operation labor required	3710 pers-hrs/yr
Maintenance labor required	2720 pers-hrs/yr
Electrical energy required	5420000 kWh/yr
Volume of earthwork required	56400 cuft
Area of pump building	7060 sqft
Costs	
Construction and equipment cost	\$4,460,000 \$
Operational labor cost	\$29,600 \$/yr
Maintenance labor cost	\$22,700 \$/yr
Material and supply cost	\$31,200 \$/yr
Energy cost	\$1,080,000 \$/yr
Amortization cost	\$291,000 \$/yr

Deshidratación por centrifugas

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	6260	HP
Power required per unit	195	HP
Excess capacity factor	1,25	
Number of units	32	
Chemical dose	1	% dry wt
Chemicals required	21500	lb/d
Sludge flow	7,21	MGD(US)
Initial solid conc	3,4	%
Operational hours per day	8	hr
Operational days per week	7	d
Quantities		
Number of centrifuges	32	
Power required per unit	195	HP
Area of building	8520	sqft
Dry solids produced	681000	lb/d
Operation labor required	104000	pers-hrs/yr
Maintenance labor required	16600	pers-hrs/yr
Electrical energy required	7250000	kWh/yr
Polymer Feed System		
Quantities		
Polymer dosage	7150	lb/d
Liquid chemical solution fed	0,343	MGD(US)
O&M labor required	46600	pers-hrs/yr
Dry material handling and mixing	3400	pers-hrs/yr
Total operation labor required	49900	pers-hrs/yr

Generacion con motores de combustion biogas

Design Output Data

Description	Value	Units
-------------	-------	-------

Sedimentador Secundario

Design Output Data

Description	Value	Units
-------------	-------	-------

Secondary Clarification
Design Information

Surface area	509000 sqft
Surface area per circular clarifi	25400 sqft
Diameter of each circular clarif	180 ft
Number of clarifiers per battery	4
Number of batteries	5
Solids loading rate	26,8 lb/(sqft-d)
Hydraulic retention time	2,21 hr
Weir length	49100 ft
Volume of wasted sludge	6,54 MGD(US)
Surface overflow rate	730 gal(US)/(sqft-d)
Quantities	
Operation labor required	10900 pers-hrs/yr
Maintenance labor required	6190 pers-hrs/yr
Electrical energy required	80300 kWh/yr
Volume of earthwork required	8660000 cuft
Slab thickness	10,1 in
Volume of slab concrete requir	473000 cuft
Wall thickness	11,5 in
Volume of wall concrete requir	116000 cuft
Costs	
Operational labor cost	\$87,200 \$/yr
Maintenance labor cost	\$51,600 \$/yr
Material and supply cost	\$173,000 \$/yr
Energy cost	\$16,100 \$/yr
Amortization cost	\$992,000 \$/yr
Waste Sludge Pumping	
Design Information	
Average daily pumping rate	6,54 MGD(US)
Total pumping capacity	6,54 MGD(US)
Design capacity per pump	3,27 MGD(US)
Number of pumps	3
Number of batteries	1
Firm pumping capacity	6,54 MGD(US)
Quantities	
Operation labor required	560 pers-hrs/yr
Maintenance labor required	475 pers-hrs/yr
Electrical energy required	218000 kWh/yr
Volume of earthwork required	2630 cuft
Area of pump building	329 sqft
Costs	
Operational labor cost	\$4,480 \$/yr
Maintenance labor cost	\$3,960 \$/yr
Material and supply cost	\$987 \$/yr
Energy cost	\$43,600 \$/yr
Amortization cost	\$9,200 \$/yr

Secado Térmico

Design Output Data

Description	Value	Units
User Specified Sludge Treatment Process		
Design Information		
No Design Data		

Disposicion Final - Costo No Incluido**Design Output Data**

Description	Value	Units
Sludge Hauling and Land Filling		
Design Information		
Volume of sludge hauled	0,0735	MGD(US)
Truck capacity	810	cuft
Round trip time to disposal site	1	hr
Truck loading time	0,75	hr
Operational hours per day	8	hr
Number of trucks required	3	
Distance to disposal site	10	miles
Quantities		
Total sludge volume hauled	0,0735	MGD(US)
Maximum anticipated landfill disposal	30	d
Anticipated sludge storage height	8	ft
Sludge storage shed area	36800	sqft
Width of sludge storage shed	136	ft
Length of sludge storage shed	271	ft
Volume of earthwork required	94700	cuft
Volume of slab concrete required	38700	cuft
Surface area of canopy roof	36800	sqft
Round trip haul distance	20	miles
Round trips per day per truck	5	
Distance traveled per year per truck	25000	miles
Sludge hauled	644000	lb/d
Operation labor required	5690	pers-hrs/yr
LandFilling cost	\$43,100	\$/yr

Desinfeccion por cloro**Design Output Data**

Description	Value	Units
Chlorination		
Design Information		
Volume of tank	2030000	cuft
Average chlorine required	30400	lb/d
Peak chlorine required	60900	lb/d
Influent coliform count	10000000	/100mL
Effluent coliform count	29,2	/100mL
Quantities		
Operational labor required	9790	pers-hrs/yr
Maintenance labor required	11800	pers-hrs/yr
Electrical energy required	269000	kWh/yr
Volume of earthwork required	731000	cuft
Volume of slab concrete required	204000	cuft
Volume of wall concrete required	167000	cuft
Number of chlorinators and evaporators	4	
Chlorination building area	1440	sqft
Number of chlorine cylinders	457	
Area of chlorine storage building	64000	sqft
Costs		
Construction and equipment cost	\$10,300,000	\$
Operational labor cost	\$78,300	\$/yr


Maintenance labor cost	\$98,600	\$/yr
Material and supply cost	\$140,000	\$/yr
Chemical cost	\$8,940,000	\$/yr
Energy cost	\$53,700	\$/yr
Amortization cost	\$656,000	\$/yr

**ALTERNATIVAS PARA FASE III - EXTENSIÓN DE LA PTAR A UN TRATAMIENTO
CON REMOCIÓN DE NITRÓGENO Y FÓSFORO**

Layout Comparison Summary

Layout Name	Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
FIII-Alt 4- Alim Esc	\$1,370,000,000	\$522,000,000	\$1,540,000	\$1,060,000	\$4,220,000	\$6,950,000	\$15,900,000	\$29,400,000
FIII-Alt 3-FP+BAF+FDN	\$3,950,000,000	\$2,930,000,000	\$4,470,000	\$3,660,000	\$5,830,000	\$36,400,000	\$36,200,000	\$49,400,000
FIII-Alt2-BAF+FDN	\$3,650,000,000	\$2,260,000,000	\$4,350,000	\$3,500,000	\$4,110,000	\$40,000,000	\$39,400,000	\$42,100,000
FIII-Alt 1- Alim Esc+FDNs	\$3,470,000,000	\$1,660,000,000	\$3,940,000	\$3,170,000	\$4,240,000	\$36,400,000	\$38,600,000	\$49,300,000

FIII-Alt 4- Alim Esc



Summary
Equipment Database
 Sept 2007,(USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$2,600,000,000	\$1,660,000,000	\$3,440,000	\$2,590,000	\$3,010,000	\$20,400,000	\$33,800,000	\$28,900,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Tratamiento Preliminar	\$13,300,000	\$368,000	\$123,000	\$331,000	\$0	\$50,100	\$669,000
Coagulación y Floculación	\$0	\$0	\$0	\$0	\$4,560,000	\$0	\$0
Sedimentación Primaria	\$36,000,000	\$73,100	\$44,400	\$142,000	\$0	\$56,500	\$811,000
Alimentación Escalonada	\$250,000,000	\$238,000	\$181,000	\$964,000	\$0	\$28,600,000	\$7,680,000
Sedimentador Secundario	\$61,000,000	\$91,900	\$55,700	\$209,000	\$0	\$68,100	\$1,180,000
Desinfección por cloro	\$10,300,000	\$78,300	\$98,500	\$140,000	\$8,940,000	\$53,700	\$656,000
Espesamiento pro gravedad	\$10,000,000	\$56,200	\$27,700	\$23,500	\$0	\$7,930	\$148,000
Digestion Anaerobica	\$149,000,000	\$398,000	\$237,000	\$322,000	\$0	\$846,000	\$3,880,000
Deshidratación por centrifugas	\$50,000,000	\$438,000	\$547,000	\$0	\$5,420,000	\$3,640,000	\$3,990,000
Espesador de Banda de Gravedad	\$30,500,000	\$116,000	\$30,300	\$0	\$1,480,000	\$480,000	\$3,350,000
Generación con motores de co	\$37,500,000	\$1,240,000	\$1,240,000	\$833,000	\$0	\$0	\$1,800,000
Blower System	\$90,500,000	\$0	\$0	\$0	\$0	\$0	\$4,570,000
Iron Feed System	\$2,370,000	\$44,900	\$0	\$47,300	\$0	\$0	\$120,000
Other Costs	\$917,000,000	\$293,000	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		210 acre
Administration labor hours		35400 hr/yr
Laboratory labor hours		14500 hr/yr
Costs		
DIRECT COSTS		
Mobilization	\$14,500,000	\$
Site preparation	\$12,500,000	\$
Site electrical	\$48,400,000	\$
Yard piping	\$29,600,000	\$
Instrumentation and control	\$30,300,000	\$
Lab and administration building	\$23,100,000	\$
Unit process construction costs	\$741,000,000	\$
Profit	\$135,000,000	\$
Total construction costs	\$1,030,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$217,000,000	\$
Legal cost	\$20,700,000	\$
Engineering design fee	\$155,000,000	\$
Inspection cost	\$20,700,000	\$
Contingency	\$103,000,000	\$
Technical	\$20,700,000	\$
Total indirect costs	\$538,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$86,200,000	\$
LABOR COSTS		
Administration labor cost	\$177,000	\$/yr
Laboratory labor cost	\$116,000	\$/yr
Unit process operation labor cost	\$3,140,000	\$/yr
Unit process maintenance labor cost	\$2,590,000	\$/yr
Total labor costs	\$6,020,000	\$/yr
PROJECT SUMMARY		
Present worth	\$2,600,000,000	\$
Total project cost	\$1,660,000,000	\$
Total operation labor cost	\$3,440,000	\$/yr
Total maintenance labor cost	\$2,590,000	\$/yr
Total material cost	\$3,010,000	\$/yr
Total chemical cost	\$20,400,000	\$/yr
Total energy cost	\$33,800,000	\$/yr
Total amortization cost	\$28,900,000	\$/yr

Summary of Air Supply System

Description	Value	Units
Blower System for Entire Plant		
Design Information		
Minimum air flow capacity		277000 scfm

Safety factor	2	
Requested air flow capacity	554000	scfm
Total capacity of blowers	554000	scfm
Number of blowers in use	6	
Total number of blowers	7	
Capacity of individual blowers	92300	scfm
Estimated cost of an installed blower	\$11,600,000	\$
Blower building area	3780	sqft
Costs		
Construction and equipment cost	\$90,500,000	\$
Amortization cost	\$4,570,000	\$/yr
Notes		
Energy costs are shown at the individual unit processes that require air		

Summary of Chemical Feed System for Iron

Description	Value	Units
Iron Salt Solution Feed System		
Quantities		
Ferric chloride dosage rate	45900	lb/d
Iron salt dosage rate as equivalent	15800	lb/d
Liquid chemical solution fed	0,013	MGD(US)
Operation labor required	5610	pers-hrs/yr
Costs		
Construction and equipment cost	\$2,370,000	\$
Operational labor cost	\$44,900	\$/yr
Material and supply cost	\$47,300	\$/yr
Amortization cost	\$120,000	\$/yr

Afluente Canoas (MM)

User Input Data

Description	Value	Units
Average Flow	365	MGD(US)
Minimum Flow	320	MGD(US)
Maximum Flow	730	MGD(US)
Suspended Solids	226	mg/L
% Volatile Solids	75	%
BOD	271	mg/L
Soluble BOD	80	mg/L
COD	550	mg/L
Soluble COD	350	mg/L
TKN	70,4	mgN/L
Soluble TKN	35,2	mgN/L
Ammonia	26	mgN/L
Total Phosphorus	9,7	mgP/L
pH	7,3	
Cations	160	mg/L
Anions	160	mg/L
Settleable Solids	50	mL/L
Oil and Grease	100	mg/L
Nitrite	0	mgN/L
Nitrate	0	mgN/L
Non-Degradable Fraction of VS	40	%
Average Summer	68	deg F
Average Winter	60,8	deg F

Tratamiento Preliminar

User Input Data

Screening

Description	Value	Units
Cleaning Method	Mechanically Cleaned	
Mechanically Cleaned Depth	9,84	ft
Manually Cleaned Depth	2	ft
Width	0,25	in
Space	0,235	in
Slope	15	degrees
Shape Factor	1,8	
Approach	1,31	ft/s
Max	3	ft/s
Ave	1,31	ft/s

Grit Removal

Description	Value	Units
Particle Size	0,00786	in
Specific Gravity	2	
Type of Grit Removal	Aerated	
Number of Units	1	
Design By	Depth	
Depth	14,8	ft
Width	65,6	ft
Current Allowance	1,7	
Manning Coefficient	0,035	
Volume of Grit	40	cuft grit/MGal(US)
Detention Time	10	min
Air Supply per Unit Length of T	3	scfm/ft
Surface Velocity	1,5	ft/s
Tank Floor Velocity	1	ft/s
Capital Cost	40	years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		
Bar size	0,25	in
Bar spacing	0,235	in
Slope of bars from horizontal	15	degrees

Head loss through screen	2,6965E+308 ft	
Approach velocity	1,31 ft/s	
Average flow through velocity (1,31 ft/s	
Maximum flow through velocity	3 ft/s	
Screen channel width	45,2 ft	
Average channel depth	9,84 ft	
Aerated Grit Chamber		
Design Information		
Maximum flow	741 MGD(US)	
Average flow	378 MGD(US)	
Minimum flow	332 MGD(US)	
Temperature	60,8 deg F	
Maximum flow through velocity	0,359 ft/s	
Average flow through velocity (0,183 ft/s	
Size of smallest particle 100%	0,00786 in	
Specific gravity of particle	2	
Number of units	1	
Maximum flow/unit	741 MGD(US)	
Width of channel	216 ft	
Depth of channel	14,8 ft	
Length of channel	216 ft	
Settling velocity of particle	0,0513 ft/s	
Hydraulic retention time	10 min	
Volume of grit	0,113 MGD(US)	
Air supply	3 cfm	
Costs		
Construction and equipment cost	\$13,300,000	\$
Operational labor cost	\$368,000	\$/yr
Maintenance labor cost	\$123,000	\$/yr
Material and supply cost	\$331,000	\$/yr
Energy cost	\$50,100	\$/yr
Amortization cost	\$669,000	\$/yr

Coagulacion y Floculacion

User Input Data

Chemical Phosphorus Removal

Description	Value	Units
Metal Precipitant	Equivalent Iron	
Effluent Phosphorus		5 mg/L
Override Design	TRUE	
Chemical Dosage		5 mg/L

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$

Override Annual Amortization (FALSE
\$0.00 \$

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		
Design Information		
Chemical used	Equivalent Iron	
Chemical dosage		5 mg/L
Mass of chemical per year	2620000	kg/yr
Chemical sludge production		30,9 mg/L
Organic sludge production		2,8 mg/L
Costs		
Chemical cost	\$4,560,000	\$/yr

Espasamiento pro gravedad

User Input Data

Gravity Thickening

Description	Value	Units
Underflow Concentration		5 %
Depth		14 ft
Based On	Mass Loading	
Mass Loading		24 lb/(sqft·d)
Settling Velocity	0,000694	ft/s
Initial Height		4 ft
Intercept		3 ft
Override Design	TRUE	
Surface Area per Thickener		4500 sqft
Number of Units		7
Override Database Costs	FALSE	
Standard 90 ft Diameter Thickener	\$145,000.00	\$
Thickener		20 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$10,000,000.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization (FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration		1 %

Thickened concentration	5 %
Mass loading	24 lb/(sqft·d)
Hydraulic loading	208 gal(US)/(sqft·d)
Hydraulic retention time	12,1 hr
Number of tanks	7
Tank volume	441000 cuft
Depth	14 ft
Surface area per tank	4500 sqft
Tank diameter	76 ft
Quantities	
Amount of sludge generated	547000 lb/d
Volume of thickened sludge	1,12 MGD(US)
Operation labor required	7020 pers-hrs/yr
Maintenance labor required	3330 pers-hrs/yr
Electrical energy required	39700 kWh/yr
Volume of earthwork required	401000 cuft
Slab thickness	11,4 in
Volume of slab concrete requir	35100 cuft
Wall thickness	14 in
Volume of wall concrete requir	31100 cuft
Costs	
Operational labor cost	\$56,200 \$/yr
Maintenance labor cost	\$27,700 \$/yr
Material and supply cost	\$23,500 \$/yr
Energy cost	\$7,930 \$/yr
Amortization cost	\$148,000 \$/yr

Espesador de Banda de Gravedad

User Input Data

Gravity Belt Thickener

Description	Value	Units
Cake Solids Content		6 %
Density of Cake		65 lb/cuft
Operating Schedule per Day		8 hr/d
Days Operating per Week		5 d/wk
Hydraulic Loading per Metre of		0,18 MGD(US)
Polymer Dose		0,004 lb/lb
Filtrate Solids Concentration		100 mg/L
Override Design	FALSE	
Building Size Requirement		13300 sqft
Number of Belt Filters		33
Override Database Costs	FALSE	
1m Belt Filter System	\$250,000.00	\$
2m Belt Filter System	\$276,000.00	\$
Belt Filter		20 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$30,500,000.00	\$
Override Annual Operational C	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cos	FALSE	

	\$0.00	\$
Override Annual Chemical Costs	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Gravity Belt Thickener		
Design Information		
Belt filter width		6,56 ft
Number of units		92
Hydraulic loading per unit per r		0,18 MGD(US)
Hydraulic loading required per		32,8 MGD(US)
Final solids content		6 %
Solids capture fraction		0,985
Quantities		
Operation labor required		14500 pers-hrs/yr
Maintenance labor required		3640 pers-hrs/yr
Power		2400000 kWh/yr
Polymer required		1790 lb/d
Dry solids produced		448000 lb/d
Belt filter(s)	\$25,400,000	\$
Building	\$1,510,000	\$
Installation	\$6,350,000	\$
Polymer system	\$9,400,000	\$
Feed pumps	\$2,790,000	\$
Conveyor system	\$6,350,000	\$
Costs		
Operational labor cost	\$116,000	\$/yr
Maintenance labor cost	\$30,300	\$/yr
Chemical cost	\$1,480,000	\$/yr
Energy cost	\$480,000	\$/yr
Amortization cost	\$3,350,000	\$/yr

Sedimentación Primaria

User Input Data

Primary Clarification

Description	Value	Units
Design Basis	Peak Flow	
Surface Overflow Rate		2400 gal(US)/(sqft-d)
Sidewater Depth		16 ft
Specific Gravity		1,05
Underflow Concentration		1 %
Weir Overflow Rate		15000 gal(US)/(ft-d)
Type of Clarifier	Circular	
Suspended Solids		58 %
BOD		32 %
COD		40 %
TKN		5 %
Phosphorus		5 %
Override Design	TRUE	
Length-Rectangular Only		0 ft
Width-Rectangular Only		0 ft

Diameter-Circular Only	165 ft
Excavation Depth	4 ft
Number of Tanks per Battery	4
Number of Batteries	4
Override Database Costs	FALSE
Standard 20 X 120 ft Rectangu	\$119,000.00 \$
Standard 90 ft Diameter Circul	\$97,600.00 \$
Standard 3000 gpm Pump and	\$19,500.00 \$
Mechanical	20 years
Structural	40 years
Pump	25 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$36,000,000.00	\$
Override Annual Operational C	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cos	FALSE	
	\$0.00	\$
Override Annual Chemical Cos	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization (FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifi	21400	sqft
Diameter of each circular clarif	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	2,72	lb/(sqft-d)
Hydraulic retention time	2,59	hr
Weir length	49600	ft
Volume of sludge generated	6,55	MGD(US)
Surface overflow rate	2180	gal(US)/(sqft-d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete requir	374000	cuft
Wall thickness	15	in
Volume of wall concrete requir	183000	cuft
Costs		
Operational labor cost	\$68,700	\$/yr
Maintenance labor cost	\$40,500	\$/yr
Material and supply cost	\$141,000	\$/yr

Energy cost	\$12,700	\$/yr
Amortization cost	\$802,000	\$/yr

Notes

Effluent soluble TKN adjusted to satisfy user-specified TKN removal.

Waste Sludge Pumping

Design Information

Average daily pumping rate	6,55 MGD(US)
Total pumping capacity	6,55 MGD(US)
Design capacity per pump	3,28 MGD(US)
Number of pumps	3
Number of batteries	1
Firm pumping capacity	6,55 MGD(US)

Quantities

Operation labor required	560 pers-hrs/yr
Maintenance labor required	475 pers-hrs/yr
Electrical energy required	219000 kWh/yr
Volume of earthwork required	2630 cuft
Area of pump building	329 sqft

Costs

Operational labor cost	\$4,480	\$/yr
Maintenance labor cost	\$3,960	\$/yr
Material and supply cost	\$988	\$/yr
Energy cost	\$43,700	\$/yr
Amortization cost	\$9,210	\$/yr

Digestion Anaerobica

User Input Data

Anaerobic Digestion

Description	Value	Units
Specific Gravity		1,05
Percent Volatile Solids Destroy		50 %
Concentration in Digester		3,4 %
Minimum Detention Time in Pri		15 d
Location	Warm-Winter >	10 D
Raw Wastewater		60,8 deg F
Digester		104 deg F
Fraction of Influent Flow Return		2 %
Suspended Solids		6250 mg/L
BOD		1000 mg/L
COD		2150 mg/L
TKN		950 mgN/L
Ammonia		650 mg/L
Override Design	TRUE	
Diameter		90 ft
Sidewater Depth		75 ft
Number of Primary Digester Tanks		14
Number of Secondary Digester		0
Number of Batteries		1
Override Database Costs	FALSE	
Standard 70 ft Diameter Floating Cover	\$444,000.00	\$
Standard 60 ft Diameter Gas Collector	\$131,000.00	\$
Standard 1 Million Btu/Hr Heater	\$55,300.00	\$
Standard 2 in Diameter Gas Scrubber	\$43,400.00	\$
Standard Size Sludge Pump	\$5,960.00	\$
Natural Gas Per 1000 cuft	\$21.10	\$
Floating Cover		20 years

Gas Circulation Unit	20 years
Heating Unit	20 years
Gas Safety Equipment	20 years
Sludge Pump	25 years
Structural	40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE \$149,000,000.00	\$
Override Annual Operational Cost	TRUE \$398,000.00	\$
Override Annual Maintenance	TRUE \$237,000.00	\$
Override Annual Materials Cost	TRUE \$322,000.00	\$
Override Annual Chemical Cost	TRUE \$0.00	\$
Override Annual Energy Cost	TRUE \$846,000.00	\$
Override Annual Amortization Cost	FALSE \$0.00	\$

Design Output Data

Description	Value	Units
Anaerobic Digestion Design Information		
Percent VSS destroyed	50	%
Solids concentration in digester	3,4	%
Detention time	15	d
Digester depth	75	ft
Digester diameter	90	ft
Effective digester volume	7010000	cuft
Number of digesters per batter	14	
Number of primary digesters per batter	14	
Number of secondary digesters per batter	0	
Number of batteries	1	
Gas produced	33,8	MGD(US)
Heat required	42100000	BTU/hr
Digester gas required	17,5	MGD(US)
Total natural gas required	0	MGD(US)
Quantities		
Operation labor required	49500	pers-hrs/yr
Maintenance labor required	28200	pers-hrs/yr
Electrical energy required	4230000	kWh/yr
Volume of earthwork required	3130000	cuft
Slab thickness	22,3	in
Volume of slab concrete required	175000	cuft
Wall thickness	45	in
Volume of wall concrete required	1240000	cuft
Sidewater depth	75	ft
Surface area/floor of 2-story concrete	14100	sqft
Piping size	10	in
Length of total piping system	6200	ft
Number of 90 degree elbows	182	
Number of tees	357	

Number of plug valves	259
Total dry solids treated	944000 lb/d
Costs	
Amortization cost	\$3,880,000 \$/yr
Notes	
Mass balance based on user input	

Alimentacion Escalonada

User Input Data

Biological Nutrient Removal - 3/5 Stage

Description	Value	Units
Number of Stages	5-Stage	
Internal Recycle From Anoxic to	No	
Internal Recycle From Oxidation	Yes	
Aeration Type	Diffused Aeration	
Effluent TKN	20	mgN/L
Effluent Total Phosphorus	2	mgP/L
Design Basis	Specify Design SRT	
Total Reactor SRT	10	d
Safety Factor for Calculated SRT	1,5	
Maximum Heterotrophic Specific Growth Rate	6	1/d
Heterotrophic Decay Rate	0,24	1/d
Maximum Autotrophic Specific Growth Rate	0,75	1/d
Autotrophic Decay Rate	0,08	1/d
Biomass Yield	0,4	
Minimum Influent BOD to P Ratio	20	
Fraction of Influent BOD to P Ratio	0,7	
Total P Content of PAOs	0,1	mg P/mg PAO VSS
Suspended Solids	3200	mg/L
Bubble Size	Fine Bubble	
Alpha Factor for Oxygen Transfer	0,5	
Beta Factor for Oxygen Saturation	0,95	
Coarse Bubble Minimum Air Flow	19,8	scfm/1000 cuft
Fine Bubble Minimum Air Flow	0,12	scfm/ft2
Standard Oxygen Transfer Efficiency	40	%
Override Design	TRUE	
Aerobic Volume	16400000	cuft
Anoxic Volume	16000000	cuft
Anaerobic Volume	366000	cuft
Tank Width	262	ft
Tank Depth	16,4	ft
Pipe Gallery Width	55	ft
Excavation Depth	4,27	ft
Number of Tanks	24	
Number of Batteries	1	
Required Air Flow - Diffused Aeration	16,9	scfm/1000 cuft
Required Horsepower - Mechanical Aerators	0	HP
Number of Mixers per Aeration Basin	3	
Override Database Costs	FALSE	
Slow Speed 20 hp Aerator	\$21,700.00	\$
Standard 2 scfm Fine Bubble Diffuser	\$54.20	\$
Standard 12 scfm Coarse Bubble Diffuser	\$32.50	\$
Standard 550 scfm Swing Arm Diffuser	\$15,200.00	\$
5 hp Vertical Turbine Mixer	\$9,700.00	\$
Standard 3000 gpm Pump and Diffuser	\$19,500.00	\$
Mechanical Aerators	20	years

Fine Bubble Diffuser	10 years
Coarse Bubble Diffuser	20 years
Swing Arm Diffuser	20 years
Turbine Mixer	20 years
Pump	25 years
Structural	40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$250,000,000.00	\$
Override Annual Operational Cost	FALSE	
	\$20,000,000.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
BNR System for BIO-P and N Removal		
Design Information		
Design Override Enabled - size		
5-Stage Biological Phosphorus		
Design aerobic SRT for nitrification	5	d
Total reactor SRT	10	d
Design SS	2190	mg/L
Calculated VSS	1380	mg/L
Calculated VSS:TSS ratio	0,628	lb VSS/lb SS
Total volume of anaerobic reactor	366000	cuft
Total volume of anoxic reactor	16000000	cuft
Total volume of aerobic reactor	16400000	cuft
Total volume of all reactors	32800000	cuft
Width of parallel train	262	ft
Sidewater depth	16,4	ft
Number of batteries	1	
Number of parallel trains per battery	24	
Number of anoxic cells within battery	3	
Number of aerobic cells within battery	3	
Anaerobic hydraulic retention time	0,176	hr
Anoxic hydraulic retention time	7,72	hr
Aerobic hydraulic retention time	7,9	hr
Amount of sludge generated	449000	lb/d
Sludge recycle ratio	48,7	%
Sludge recycle rate	181	MGD(US)
Nitrogen required for biomass growth	14,9	mg/L
Phosphorus required for biomass growth	2,99	mg/L
Oxygen required to meet average demand	947000	lb/d
Air flow required to meet average demand	277000	scfm
Design air flow	16,9	scfm/1000 cuft

Design air flow	6,65	scfm/ft2
Quantities		
Operation labor required	19800	pers-hrs/yr
Maintenance labor required	14900	pers-hrs/yr
Electrical energy required	81000000	kWh/yr
Volume of earthwork required	14200000	cuft
Volume of slab concrete requir	4250000	cuft
Volume of wall concrete requir	578000	cuft
Handrail length	15400	ft
Number of diffusers per train	5770	
Fine bubble diffuser floor cover	6,12	%
Number of swing arm headers	13	
Required mixing power	8100	HP
Total number of mixers	288	
Required mixing power per mix	28,1	HP
Design mixing power per mixer	5	HP
Mixing power for each unaerat	84,4	HP

Costs

Operational labor cost	\$159,000	\$/yr
Maintenance labor cost	\$124,000	\$/yr
Material and supply cost	\$783,000	\$/yr
Energy cost	\$16,200,000	\$/yr
Amortization cost	\$5,990,000	\$/yr

Notes

Minimum SRT not calculated, design SRT specified by user

Design is based on user specified design overrides - Performance data is assumed to be correct

WARNING: Anoxic HRT is out of the normal range, consider changing your design override value

WARNING: Anaerobic HRT is out of the normal range, consider changing your design override value

Required hp per mixer exceeds the maximum allowed of 5 hp/mixer, consider increasing number of mixers

Aerobic-Anoxic internal recycle pumps sized for 4x the influent flow

Internal Recycle Pumping

Design Information

Average daily pumping rate	62,1	MGD(US)
Total pumping capacity	62,1	MGD(US)
Design capacity per pump	20,7	MGD(US)
Number of pumps	96	
Number of batteries	1	
Firm pumping capacity	62,1	MGD(US)

Quantities

Operation labor required	1450	pers-hrs/yr
Maintenance labor required	1230	pers-hrs/yr
Electrical energy required	2060000	kWh/yr
Volume of earthwork required	11400	cuft
Area of pump building	1430	sqft

Costs

Operational labor cost	\$11,600	\$/yr
Maintenance labor cost	\$10,300	\$/yr
Material and supply cost	\$146,000	\$/yr
Energy cost	\$9,890,000	\$/yr
Amortization cost	\$1,360,000	\$/yr

Notes

Pumps are sized based on an individual battery of internal pumps for each train

Sludge Recycle Pumping

Design Information

Average daily pumping rate	373	MGD(US)
Total pumping capacity	373	MGD(US)

Design capacity per pump		23,3 MGD(US)
Number of pumps		5
Number of batteries		4
Firm pumping capacity		373 MGD(US)
Quantities		
Operation labor required		8520 pers-hrs/yr
Maintenance labor required		5630 pers-hrs/yr
Electrical energy required	12300000 kWh/yr	
Volume of earthwork required	65200 cuft	
Area of pump building	8150 sqft	
Costs		
Operational labor cost	\$68,200	\$/yr
Maintenance labor cost	\$46,900	\$/yr
Material and supply cost	\$34,800	\$/yr
Energy cost	\$2,460,000	\$/yr
Amortization cost	\$325,000	\$/yr

Deshidratación por centrifugas

User Input Data

Centrifugation

Description	Value	Units
Cake Solids Content		28 %
Solids Capture		90 %
Power Requirement		1 HP/gpm(US)
Daily Operating Time		8 hr/d
Weekly Operating Time		7 d/wk
Number of Units		5
Excess Capacity Factor	1,25	
Chemical Dose		1 % dry wt
Override Database Costs	FALSE	
Standard 50 hp Centrifuge	\$271,000.00	\$
Centrifuge		15 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$50,000,000.00	\$
Override Annual Operational Cost	TRUE	
	\$438,000.00	\$
Override Annual Maintenance Cost	TRUE	
	\$547,000.00	\$
Override Annual Materials Cost	TRUE	
	\$0.00	\$
Override Annual Chemical Cost	TRUE	
	\$5,420,000.00	\$
Override Annual Energy Cost	TRUE	
	\$3,640,000.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	5620	HP

Power required per unit	194 HP
Excess capacity factor	1,25
Number of units	29
Chemical dose	1 % dry wt
Chemicals required	19300 lb/d
Sludge flow	6,48 MGD(US)
Initial solid conc	3,4 %
Operational hours per day	8 hr
Operational days per week	7 d
Quantities	
Number of centrifuges	29
Power required per unit	194 HP
Area of building	7700 sqft
Dry solids produced	612000 lb/d
Operation labor required	94600 pers-hrs/yr
Maintenance labor required	15100 pers-hrs/yr
Electrical energy required	6570000 kWh/yr
Costs	
Amortization cost	\$3,990,000 \$/yr
Polymer Feed System	
Quantities	
Polymer dosage	6430 lb/d
Liquid chemical solution fed	0,308 MGD(US)
O&M labor required	43400 pers-hrs/yr
Dry material handling and mixii	3300 pers-hrs/yr
Total operation labor required	46700 pers-hrs/yr

Generacion con motores de combustion biogas

User Input Data

User Specified Sludge Process

Description	Value	Units
Volume Reduction		0 %
Percent Volatile Solids Destroy		0 %

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$37,500,000.00	\$
Override Annual Operational C	TRUE	
	\$1,240,000.00	\$
Override Annual Maintenance	TRUE	
	\$1,240,000.00	\$
Override Annual Materials Cos	TRUE	
	\$833,000.00	\$
Override Annual Chemical Cos	TRUE	
	\$0.00	\$
Override Annual Energy Cost	TRUE	
	\$-11,100,000.00	\$
Override Annual Amortization (TRUE	
	\$1,800,000.00	\$

Design Output Data

Description	Value	Units
-------------	-------	-------

Sedimentador Secundario

User Input Data

Secondary Clarifier

Description	Value	Units
Design Basis	Average Flow	
Surface Overflow Rate		1370 gal(US)/(sqft-d)
Sidewater Depth		17 ft
Specific Gravity		1,03
Underflow Concentration		0,67 %
Weir Overflow Rate - Maximum		15000 gal(US)/(ft-d)
Effluent Suspended Solids		20 mg/L
Type of Clarifier	Circular	
Override Design	TRUE	
Length-Rectangular Only		0 ft
Width-Rectangular Only		0 ft
Diameter-Circular Only		180 ft
Excavation Depth		4 ft
Number of Tanks per Battery		5
Number of Batteries		4
Override Database Costs	FALSE	
Rectangular Clarifier Mechanis	\$119,000.00	\$
Circular Clarifier Mechanism-9	\$97,600.00	\$
Standard 3000 gpm Pump and	\$19,500.00	\$
Mechanical		20 years
Structural		40 years
Pump		25 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$61,000,000.00	\$
Override Annual Operational C	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cos	FALSE	
	\$0.00	\$
Override Annual Chemical Cos	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization (FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Secondary Clarification		
Design Information		
Surface area		509000 sqft
Surface area per circular clarifi		25400 sqft
Diameter of each circular clarif		180 ft
Number of clarifiers per battery		5
Number of batteries		4
Solids loading rate		19,9 lb/(sqft-d)
Hydraulic retention time		4,17 hr
Weir length		49200 ft
Volume of wasted sludge		7,81 MGD(US)
Surface overflow rate		732 gal(US)/(sqft-d)

Quantities		
Operation labor required		10900 pers-hrs/yr
Maintenance labor required		6190 pers-hrs/yr
Electrical energy required		80300 kWh/yr
Volume of earthwork required		8660000 cuft
Slab thickness		12,2 in
Volume of slab concrete requir		566000 cuft
Wall thickness		15,5 in
Volume of wall concrete requir		273000 cuft

Costs		
Operational labor cost	\$87,200	\$/yr
Maintenance labor cost	\$51,600	\$/yr
Material and supply cost	\$208,000	\$/yr
Energy cost	\$16,100	\$/yr
Amortization cost	\$1,170,000	\$/yr

Waste Sludge Pumping		
Design Information		
Average daily pumping rate		7,81 MGD(US)
Total pumping capacity		7,81 MGD(US)
Design capacity per pump		3,9 MGD(US)
Number of pumps		3
Number of batteries		1
Firm pumping capacity		7,81 MGD(US)

Quantities		
Operation labor required		586 pers-hrs/yr
Maintenance labor required		497 pers-hrs/yr
Electrical energy required		260000 kWh/yr
Volume of earthwork required		2830 cuft
Area of pump building		354 sqft
Costs		
Operational labor cost	\$4,690	\$/yr
Maintenance labor cost	\$4,140	\$/yr
Material and supply cost	\$1,070	\$/yr
Energy cost	\$52,000	\$/yr
Amortization cost	\$9,940	\$/yr

Disposicion Final - Costo No Incluido

User Input Data

Hauling and Land Filling

Description	Value	Units
Distance to Disposal Site		15,5 miles
Daily Operation		8 hr
Loading Time per Vehicle		0,75 hr
Hauling Time per Trip		1 hr
Disposal Cost Based On	Sludge Disposal per	
Override Database Costs	TRUE	
Standard 22 cuyd Vehicle	\$314,000.00	\$
Annual Charge of Land Fill	\$43,100.00	\$
Sludge Disposal per cuyd	\$23.60	\$
Sludge Disposal per ton	\$28.00	\$
Vehicle		15 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	

	\$0.00	\$
Override Annual Operational Costs	FALSE	
	\$0.00	\$
Override Annual Maintenance Costs	FALSE	
	\$0.00	\$
Override Annual Materials Costs	FALSE	
	\$0.00	\$
Override Annual Chemical Costs	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization (Capex)	TRUE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling Design Information		
Volume of sludge hauled	0,235	MGD(US)
Truck capacity	810	cuft
Round trip time to disposal site	1	hr
Truck loading time	0,75	hr
Operational hours per day	8	hr
Number of trucks required	9	
Distance to disposal site	15,5	miles
Quantities		
Total sludge volume hauled	0,235	MGD(US)
Maximum anticipated landfill duration	30	d
Anticipated sludge storage height	8	ft
Sludge storage shed area	118000	sqft
Width of sludge storage shed	243	ft
Length of sludge storage shed	486	ft
Volume of earthwork required	300000	cuft
Volume of slab concrete required	122000	cuft
Surface area of canopy roof	118000	sqft
Round trip haul distance	31,1	miles
Round trips per day per truck	5	
Distance traveled per year per truck	38800	miles
Sludge hauled	2070000	lb/d
Operation labor required	28400	pers-hrs/yr
LandFilling cost	\$10,100,000	\$/yr

Desinfeccion por cloro

User Input Data

Chlorination

Description	Value	Units
Contact Time At Peak Flow		30 min
Chlorine Dose		10 mg/L
Influent Coliform Count		10000000 /100mL
Override Design	FALSE	
Volume of Tank		2030000 cuft
Override Database Costs	FALSE	
1 Ton of Chlorine	\$1,610.00	\$
Standard 2000 lb/d Chlorinator	\$37,900.00	\$
Chlorinator		15 years
Structural		40 years


Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Chlorination		
Design Information		
Volume of tank	2030000	cuft
Average chlorine required	30400	lb/d
Peak chlorine required	60900	lb/d
Influent coliform count	10000000	/100mL
Effluent coliform count	29,2	/100mL
Quantities		
Operational labor required	9790	pers-hrs/yr
Maintenance labor required	11800	pers-hrs/yr
Electrical energy required	269000	kWh/yr
Volume of earthwork required	731000	cuft
Volume of slab concrete required	204000	cuft
Volume of wall concrete required	167000	cuft
Number of chlorinators and evaporators	4	
Chlorination building area	1440	sqft
Number of chlorine cylinders	457	
Area of chlorine storage building	64000	sqft
Costs		
Construction and equipment cost	\$10,300,000	\$
Operational labor cost	\$78,300	\$/yr
Maintenance labor cost	\$98,500	\$/yr
Material and supply cost	\$140,000	\$/yr
Chemical cost	\$8,940,000	\$/yr
Energy cost	\$53,700	\$/yr
Amortization cost	\$656,000	\$/yr

FIII-AIt 3-FP+BAF+FDN*



Summary
Equipment Database
 Sept 2007, (USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$3,950,000,000	\$2,930,000,000	\$4,470,000	\$3,660,000	\$5,830,000	\$36,400,000	\$36,200,000	\$49,400,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Tratamiento Preliminar	\$13,300,000	\$373,000	\$130,000	\$333,000	\$0	\$50,400	\$673,000
Coagulación y Floculación	\$0	\$0	\$0	\$0	\$11,100,000	\$0	\$0
Sedimentación Primaria	\$36,000,000	\$73,400	\$46,600	\$142,000	\$0	\$67,000	\$812,000
Filtro Percolador	\$226,000,000	\$267,000	\$150,000	\$1,390,000	\$0	\$5,820,000	\$11,800,000
Clarificador Secundario	\$61,000,000	\$88,100	\$55,500	\$256,000	\$0	\$33,800	\$1,520,000
BAF	\$720,000,000	\$520,000	\$520,000	\$1,570,000	\$0	\$15,000,000	\$4,000,000
Filtro Denitrificador	\$107,000,000	\$322,000	\$484,000	\$555,000	\$10,100,000	\$10,100,000	\$6,260,000
Espasamiento por gravedad	\$10,000,000	\$120,000	\$54,700	\$23,500	\$0	\$14,200	\$148,000
Digestión Anaerobica	\$149,000,000	\$518,000	\$308,000	\$418,000	\$0	\$1,100,000	\$15,000,000
Deshidratación por centrifugas	\$23,000,000	\$438,000	\$547,000	\$0	\$5,420,000	\$3,640,000	\$7,070,000
Desinfección por cloro	\$10,300,000	\$78,300	\$103,000	\$140,000	\$8,940,000	\$53,700	\$656,000
Gravity Belt Thickener	\$30,500,000	\$61,100	\$16,600	\$0	\$783,000	\$264,000	\$0
Generación con motores de cc	\$37,500,000	\$1,240,000	\$1,240,000	\$833,000	\$0	\$0	\$1,050,000
Iron Feed System	\$8,420,000	\$79,800	\$0	\$168,000	\$0	\$0	\$425,000
Other Costs	\$1,500,000,000	\$293,000	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		210 acre
Administration labor hours		35400 hr/yr
Laboratory labor hours		14500 hr/yr
Costs		
DIRECT COSTS		
Mobilization	\$14,500,000	\$
Site preparation	\$12,500,000	\$
Site electrical	\$48,400,000	\$
Yard piping	\$29,600,000	\$
Instrumentation and control	\$30,300,000	\$
Lab and administration building	\$23,100,000	\$
Unit process construction costs	\$1,430,000,000	\$
Profit	\$238,000,000	\$
Total construction costs	\$1,830,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$384,000,000	\$
Legal cost	\$36,600,000	\$
Engineering design fee	\$274,000,000	\$
Inspection cost	\$36,600,000	\$
Contingency	\$183,000,000	\$
Technical	\$36,600,000	\$
Total indirect costs	\$951,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$152,000,000	\$
LABOR COSTS		
Administration labor cost	\$177,000	\$/yr
Laboratory labor cost	\$116,000	\$/yr
Unit process operation labor cost	\$4,180,000	\$/yr
Unit process maintenance labor cost	\$3,660,000	\$/yr
Total labor costs	\$8,130,000	\$/yr
PROJECT SUMMARY		
Present worth	\$3,950,000,000	\$
Total project cost	\$2,930,000,000	\$
Total operation labor cost	\$4,470,000	\$/yr
Total maintenance labor cost	\$3,660,000	\$/yr
Total material cost	\$5,830,000	\$/yr
Total chemical cost	\$36,400,000	\$/yr
Total energy cost	\$36,200,000	\$/yr
Total amortization cost	\$49,400,000	\$/yr

Summary of Chemical Feed System for Iron

Description	Value	Units
Iron Salt Solution Feed System		
Quantities		
Ferric chloride dosage rate		112000 lb/d

Iron salt dosage rate as equiva	38500 lb/d	
Liquid chemical solution fed	0,0317 MGD(US)	
Operation labor required	9980 pers-hrs/yr	
Costs		
Construction and equipment cost	\$8,420,000	\$
Operational labor cost	\$79,800	\$/yr
Material and supply cost	\$168,000	\$/yr
Amortization cost	\$425,000	\$/yr

Afluente Canoas (MM)

Tratamiento Preliminar

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		
Bar size	0,25 in	
Bar spacing	0,235 in	
Slope of bars from horizontal	15 degrees	
Head loss through screen	2,6965E+308 ft	
Approach velocity	1,31 ft/s	
Average flow through velocity (1,31 ft/s	
Maximum flow through velocity	3 ft/s	
Screen channel width	45,9 ft	
Average channel depth	9,84 ft	
Aerated Grit Chamber		
Design Information		
Maximum flow	747 MGD(US)	
Average flow	383 MGD(US)	
Minimum flow	338 MGD(US)	
Temperature	60,8 deg F	
Maximum flow through velocity	0,361 ft/s	
Average flow through velocity (0,185 ft/s	
Size of smallest particle 100%	0,00786 in	
Specific gravity of particle	2	
Number of units	1	
Maximum flow/unit	747 MGD(US)	
Width of channel	217 ft	
Depth of channel	14,8 ft	
Length of channel	217 ft	
Settling velocity of particle	0,0513 ft/s	
Hydraulic retention time	10 min	
Volume of grit	0,115 MGD(US)	
Air supply	3 cfm	
Costs		
Construction and equipment cost	\$13,300,000	\$
Operational labor cost	\$373,000	\$/yr
Maintenance labor cost	\$130,000	\$/yr
Material and supply cost	\$333,000	\$/yr
Energy cost	\$50,400	\$/yr
Amortization cost	\$673,000	\$/yr

Coagulación y Floculación

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		
Design Information		

Chemical used	Equivalent Iron	
Chemical dosage		12 mg/L
Mass of chemical per year	6390000 kg/yr	
Chemical sludge production	39,9 mg/L	
Organic sludge production	6,7 mg/L	
Costs		
Chemical cost	\$11,100,000	\$/yr

Espasamiento pro gravedad

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration		1 %
Thickened concentration		5 %
Mass loading		24 lb/(sqft·d)
Hydraulic loading		560 gal(US)/(sqft·d)
Hydraulic retention time		4,49 hr
Number of tanks		7
Tank volume	441000 cuft	
Depth		14 ft
Surface area per tank		4500 sqft
Tank diameter		76 ft
Quantities		
Amount of sludge generated	1470000 lb/d	
Volume of thickened sludge	3,02 MGD(US)	
Operation labor required	15000 pers-hrs/yr	
Maintenance labor required	6280 pers-hrs/yr	
Electrical energy required	71000 kWh/yr	
Volume of earthwork required	401000 cuft	
Slab thickness		11,4 in
Volume of slab concrete requir	35100 cuft	
Wall thickness		14 in
Volume of wall concrete requir	31100 cuft	
Costs		
Operational labor cost	\$120,000	\$/yr
Maintenance labor cost	\$54,700	\$/yr
Material and supply cost	\$23,500	\$/yr
Energy cost	\$14,200	\$/yr
Amortization cost	\$148,000	\$/yr

Gravity Belt Thickener

Design Output Data

Description	Value	Units
Gravity Belt Thickener		
Design Information		
Belt filter width		6,56 ft
Number of units		33
Hydraulic loading per unit per r		0,18 MGD(US)
Hydraulic loading required per		11,5 MGD(US)
Final solids content		6 %
Solids capture fraction		0,99
Quantities		
Operation labor required	7630 pers-hrs/yr	
Maintenance labor required	1910 pers-hrs/yr	
Power	1320000 kWh/yr	

Polymer required		946 lb/d
Dry solids produced		237000 lb/d
Belt filter(s)	\$9,110,000	\$
Building	\$619,000	\$
Installation	\$2,280,000	\$
Polymer system	\$3,370,000	\$
Feed pumps	\$1,000,000	\$
Conveyor system	\$2,280,000	\$
Costs		
Operational labor cost	\$61,100	\$/yr
Maintenance labor cost	\$16,600	\$/yr
Chemical cost	\$783,000	\$/yr
Energy cost	\$264,000	\$/yr

Sedimentación Primaria

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifi	21400	sqft
Diameter of each circular clarif	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	3,37	lb/(sqft·d)
Hydraulic retention time	2,55	hr
Weir length	50000	ft
Volume of sludge generated	8,13	MGD(US)
Surface overflow rate	2190	gal(US)/(sqft·d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete requir	374000	cuft
Wall thickness	15	in
Volume of wall concrete requir	183000	cuft
Costs		
Operational labor cost	\$68,700	\$/yr
Maintenance labor cost	\$42,300	\$/yr
Material and supply cost	\$141,000	\$/yr
Energy cost	\$12,700	\$/yr
Amortization cost	\$802,000	\$/yr

Notes

Effluent soluble TKN adjusted to satisfy user-specified TKN removal.

Waste Sludge Pumping

Design Information	
Average daily pumping rate	8,13 MGD(US)
Total pumping capacity	8,13 MGD(US)
Design capacity per pump	4,07 MGD(US)
Number of pumps	3
Number of batteries	1
Firm pumping capacity	8,13 MGD(US)
Quantities	
Operation labor required	594 pers-hrs/yr

Maintenance labor required		504 pers-hrs/yr
Electrical energy required		271000 kWh/yr
Volume of earthwork required		2880 cuft
Area of pump building		360 sqft
Costs		
Operational labor cost	\$4,750	\$/yr
Maintenance labor cost	\$4,380	\$/yr
Material and supply cost	\$1,090	\$/yr
Energy cost	\$54,200	\$/yr
Amortization cost	\$10,100	\$/yr

Digestion Anaerobica

Design Output Data

Description	Value	Units
Anaerobic Digestion		
Design Information		
Percent VSS destroyed		43 %
Solids concentration in digeste		3,4 %
Detention time		15 d
Digester depth		75 ft
Digester diameter		90 ft
Effective digester volume	7010000	cuft
Number of digesters per batter		14
Number of primary digesters p		14
Number of secondary digesters:		0
Number of batteries		1
Gas produced		64 MGD(US)
Heat required	65600000	BTU/hr
Digester gas required		27,3 MGD(US)
Total natural gas required		0 MGD(US)
Quantities		
Operation labor required		75600 pers-hrs/yr
Maintenance labor required		42300 pers-hrs/yr
Electrical energy required		6330000 kWh/yr
Volume of earthwork required		3130000 cuft
Slab thickness		22,3 in
Volume of slab concrete requir		175000 cuft
Wall thickness		45 in
Volume of wall concrete requir		1240000 cuft
Sidewater depth		75 ft
Surface area/floor of 2-story cc		14100 sqft
Piping size		10 in
Length of total piping system		6200 ft
Number of 90 degree elbows		182
Number of tees		357
Number of plug valves		259
Total dry solids treated		1560000 lb/d
Notes		
Mass balance based on user input		

Filtro Percolador

Design Output Data

Description	Value	Units
Trickling Filtration		
Design Information		
Reaction rate constant	0,00191	

Hydraulic loading rate	1080 gal(US)/(sqft-d)
Total hydraulic loading rate	1240 gal(US)/(sqft-d)
Recirculation ratio	0,149
Number of towers per stage	48
Number of stages	1
Depth of filter tower	19,7 ft
Diameter of filter tower	180 ft
Surface area per filter tower	25400 sqft
Total surface area	1220000 sqft
Volume per filter tower	501000 cuft
Total volume	24000000 cuft

Quantities

Operation labor required	13000 pers-hr/yr
Maintenance labor required	5290 pers-hr/yr
Volume of earthwork required	20800000 cuft
Volume of slab concrete requir	814000 cuft
Volume of wall concrete requir	692000 cuft
Number of posts per tower	1710
Total length of precast beams	679000 ft

Costs

Construction and equipment cost	\$214,000,000	\$
Operational labor cost	\$104,000	\$/yr
Maintenance labor cost	\$46,000	\$/yr
Material and supply cost	\$1,310,000	\$/yr
Energy cost	\$26,700	\$/yr
Amortization cost	\$11,000,000	\$/yr

Internal Recycle Pumping

Design Information

Average daily pumping rate	879 MGD(US)
Total pumping capacity	879 MGD(US)
Design capacity per pump	27,5 MGD(US)
Number of pumps	5
Number of batteries	8
Firm pumping capacity	879 MGD(US)

Quantities

Operation labor required	20300 pers-hrs/yr
Maintenance labor required	12000 pers-hrs/yr
Electrical energy required	29000000 kWh/yr
Volume of earthwork required	152000 cuft
Area of pump building	18900 sqft

Costs

Construction and equipment cost	\$12,000,000	\$
Operational labor cost	\$163,000	\$/yr
Maintenance labor cost	\$104,000	\$/yr
Material and supply cost	\$84,000	\$/yr
Energy cost	\$5,800,000	\$/yr
Amortization cost	\$783,000	\$/yr

Deshidratación por centrifugas

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	8670	HP
Power required per unit	197	HP
Excess capacity factor	1,25	

Number of units	44
Chemical dose	1 % dry wt
Chemicals required	29700 lb/d
Sludge flow	9,99 MGD(US)
Initial solid conc	3,4 %
Operational hours per day	8 hr
Operational days per week	7 d
Quantities	
Number of centrifuges	44
Power required per unit	197 HP
Area of building	11700 sqft
Dry solids produced	944000 lb/d
Operation labor required	138000 pers-hrs/yr
Maintenance labor required	22000 pers-hrs/yr
Electrical energy required	9810000 kWh/yr
Polymer Feed System	
Quantities	
Polymer dosage	9910 lb/d
Liquid chemical solution fed	0,475 MGD(US)
O&M labor required	57500 pers-hrs/yr
Dry material handling and mixi	3730 pers-hrs/yr
Total operation labor required	61200 pers-hrs/yr

Generacion con motores de combustion biogas

Design Output Data

Description	Value	Units
-------------	-------	-------

Clarificador Secundario

Design Output Data

Description	Value	Units
-------------	-------	-------

Secondary Clarification		
Design Information		
Surface area	479000	sqft
Surface area per circular clarifi	7480	sqft
Diameter of each circular clarif	98	ft
Number of clarifiers per battery	16	
Number of batteries	4	
Solids loading rate	0,492	lb/(sqft-d)
Hydraulic retention time	3,37	hr
Weir length	49500	ft
Volume of wasted sludge	2,75	MGD(US)
Quantities		
Operation labor required	10500	pers-hrs/yr
Maintenance labor required	5960	pers-hrs/yr
Electrical energy required	77500	kWh/yr
Volume of earthwork required	6460000	cuft
Slab thickness	11,6	in
Volume of slab concrete requir	531000	cuft
Wall thickness	14,4	in
Volume of wall concrete requir	393000	cuft
Costs		
Operational labor cost	\$84,100	\$/yr
Maintenance labor cost	\$51,900	\$/yr
Material and supply cost	\$256,000	\$/yr
Energy cost	\$15,500	\$/yr
Amortization cost	\$1,520,000	\$/yr

Waste Sludge Pumping		
Design Information		
Average daily pumping rate		2,75 MGD(US)
Total pumping capacity		2,75 MGD(US)
Design capacity per pump		1,37 MGD(US)
Number of pumps		3
Number of batteries		1
Firm pumping capacity		2,75 MGD(US)
Quantities		
Operation labor required		501 pers-hrs/yr
Maintenance labor required		418 pers-hrs/yr
Electrical energy required		91700 kWh/yr
Volume of earthwork required		2030 cuft
Area of pump building		254 sqft
Costs		
Operational labor cost	\$4,010	\$/yr
Maintenance labor cost	\$3,640	\$/yr
Material and supply cost	\$685	\$/yr
Energy cost	\$18,300	\$/yr
Amortization cost	\$6,390	\$/yr

Secado Térmico

Design Output Data

Description	Value	Units
User Specified Sludge Treatment Process		
Design Information		
No Design Data		

BAF

Design Output Data

Description	Value	Units
User Specified Wastewater Process		
Design Information		
No Design Data		

Disposicion Final

Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling		
Design Information		
Volume of sludge hauled	0,109 MGD(US)	
Truck capacity	810 cuft	
Round trip time to disposal site	1 hr	
Truck loading time	0,75 hr	
Operational hours per day	8 hr	
Number of trucks required	4	
Distance to disposal site	15,5 miles	
Quantities		
Total sludge volume hauled	0,109 MGD(US)	
Maximum anticipated landfill d	30 d	
Anticipated sludge storage hei	8 ft	
Sludge storage shed area	55000 sqft	
Width of sludge storage shed s	166 ft	
Length of sludge storage shed	332 ft	
Volume of earthwork required	141000 cuft	
Volume of slab concrete requir	57300 cuft	

Surface area of canopy roof	55000 sqft
Round trip haul distance	31,1 miles
Round trips per day per truck	5
Distance traveled per year per	38800 miles
Sludge hauled	961000 lb/d
Operation labor required	13200 pers-hrs/yr
LandFilling cost	\$4,680,000 \$/yr

Filtro Denitrificador

Design Output Data

Description	Value	Units
Attached Growth Denitrification		
Design Information		
Surface removal rate	0,0061	lb/(sqft·d)
Total media surface area	1380000	sqft
Total volume of media needed	33600	cuft
Total column area	338000	sqft
Actual media volume	4050000	cuft
Hydraulic retention time	120	min
Daily methanol required	195000	lb/d
Total backwash required	4860	MGD(US)
Quantities		
Number of batteries	4	
Number of columns per battery	32	
Height of columns	23	ft
Cross-sectional length of column	103	ft
Cross-sectional width of column	103	ft
Methanol Feed Rate	0,033	MGD(US)
Methanol Storage Volume	92900	cuft
Operation labor required	49200	pers-hrs/yr
Maintenance labor required	31000	pers-hrs/yr
Electrical energy required	38700000	kWhr/yr
Volume of earthwork required	3090000	cuft
Volume of slab concrete required	1010000	cuft
Volume of wall concrete required	283000	cuft
Costs		
Construction and equipment cost	\$96,300,000	\$
Operational labor cost	\$248,000	\$/yr
Maintenance labor cost	\$428,000	\$/yr
Material and supply cost	\$481,000	\$/yr
Chemical cost	\$10,100,000	\$/yr
Energy cost	\$7,740,000	\$/yr
Amortization cost	\$5,580,000	\$/yr
Internal Recycle Pumping		
Design Information		
Average daily pumping rate	365	MGD(US)
Total pumping capacity	730	MGD(US)
Design capacity per pump	26,1	MGD(US)
Number of pumps	5	
Number of batteries	7	
Firm pumping capacity	365	MGD(US)
Quantities		
Operation labor required	8340	pers-hrs/yr
Maintenance labor required	5520	pers-hrs/yr
Electrical energy required	12000000	kWh/yr
Volume of earthwork required	126000	cuft

Area of pump building		15800 sqft
Costs		
Construction and equipment cost	\$9,890,000	\$
Operational labor cost	\$66,700	\$/yr
Maintenance labor cost	\$48,000	\$/yr
Material and supply cost	\$69,200	\$/yr
Energy cost	\$2,410,000	\$/yr
Amortization cost	\$645,000	\$/yr
Wash Water Pumping		
Design Information		
Average daily pumping rate		38 MGD(US)
Total pumping capacity		38 MGD(US)
Design capacity per pump		19 MGD(US)
Number of pumps		3
Number of batteries		1
Firm pumping capacity		38 MGD(US)
Quantities		
Operation labor required		946 pers-hrs/yr
Maintenance labor required		897 pers-hrs/yr
Electrical energy required		1730 kWh/yr
Volume of earthwork required		7600 cuft
Area of pump building		949 sqft
Costs		
Construction and equipment cost	\$588,000	\$
Operational labor cost	\$7,560	\$/yr
Maintenance labor cost	\$7,800	\$/yr
Material and supply cost	\$4,110	\$/yr
Energy cost	\$346	\$/yr
Amortization cost	\$38,400	\$/yr


Desinfeccion por cloro

Design Output Data

Description	Value	Units
Chlorination		
Design Information		
Volume of tank	2030000	cuft
Average chlorine required	30400	lb/d
Peak chlorine required	60900	lb/d
Influent coliform count	10000000	/100mL
Effluent coliform count	29,2	/100mL
Quantities		
Operational labor required	9790	pers-hrs/yr
Maintenance labor required	11800	pers-hrs/yr
Electrical energy required	269000	kWh/yr
Volume of earthwork required	731000	cuft
Volume of slab concrete required	204000	cuft
Volume of wall concrete required	167000	cuft
Number of chlorinators and ev:	4	
Chlorination building area	1440	sqft
Number of chlorine cylinders	457	
Area of chlorine storage building	64000	sqft
Costs		
Construction and equipment cost	\$10,300,000	\$
Operational labor cost	\$78,300	\$/yr
Maintenance labor cost	\$103,000	\$/yr
Material and supply cost	\$140,000	\$/yr

Chemical cost	\$8,940,000	\$/yr
Energy cost	\$53,700	\$/yr
Amortization cost	\$656,000	\$/yr

FIII-AIt2-BAF+FDN



Summary

Equipment Database

Sept 2007, (USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$3,200,000,000	\$2,240,000,000	\$3,940,000	\$3,370,000	\$3,900,000	\$31,300,000	\$37,800,000	\$30,700,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Tratamiento Preliminar	\$13,400,000	\$376,000	\$130,000	\$334,000	\$0	\$50,600	\$675,000
Coagulación y Floculación	\$0	\$0	\$0	\$0	\$4,680,000	\$0	\$0
Sedimentación Primaria	\$36,000,000	\$73,500	\$46,300	\$142,000	\$0	\$70,300	\$812,000
BAF	\$640,000,000	\$520,000	\$520,000	\$1,500,000	\$0	\$23,000,000	\$10,000,000
Filtro Desnitrificador	\$106,000,000	\$322,000	\$480,000	\$553,000	\$12,300,000	\$10,100,000	\$6,240,000
Desinfección por cloro	\$10,300,000	\$78,300	\$102,000	\$140,000	\$8,940,000	\$53,700	\$656,000
Espasamiento pro gravedad	\$10,000,000	\$154,000	\$66,400	\$23,500	\$0	\$17,100	\$148,000
Digestion Anaerobica	\$149,000,000	\$398,000	\$237,000	\$322,000	\$0	\$846,000	\$4,100,000
Deshidratación por centrifugas	\$50,000,000	\$438,000	\$547,000	\$0	\$5,420,000	\$3,640,000	\$6,150,000
Generacion con motores de combustion biogas	\$37,500,000	\$1,240,000	\$1,240,000	\$833,000	\$0	\$0	\$1,800,000
Iron Feed System	\$2,450,000	\$45,600	\$0	\$49,100	\$0	\$0	\$124,000
Other Costs	\$1,180,000,000	\$293,000	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		210 acre
Administration labor hours		35400 hr/yr
Laboratory labor hours		14500 hr/yr
Costs		
DIRECT COSTS		
Mobilization	\$14,500,000	\$
Site preparation	\$12,500,000	\$
Site electrical	\$48,400,000	\$
Yard piping	\$29,600,000	\$
Instrumentation and control	\$30,300,000	\$
Lab and administration buildings	\$23,100,000	\$
Unit process construction costs	\$1,060,000,000	\$
Profit	\$182,000,000	\$
Total construction costs	\$1,400,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$293,000,000	\$
Legal cost	\$27,900,000	\$
Engineering design fee	\$209,000,000	\$
Inspection cost	\$27,900,000	\$
Contingency	\$140,000,000	\$
Technical	\$27,900,000	\$
Total indirect costs	\$726,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$116,000,000	\$
LABOR COSTS		
Administration labor cost	\$177,000	\$/yr
Laboratory labor cost	\$116,000	\$/yr
Unit process operation labor cost	\$3,650,000	\$/yr
Unit process maintenance labor cost	\$3,370,000	\$/yr
Total labor costs	\$7,310,000	\$/yr
PROJECT SUMMARY		
Present worth	\$3,200,000,000	\$
Total project cost	\$2,240,000,000	\$
Total operation labor cost	\$3,940,000	\$/yr
Total maintenance labor cost	\$3,370,000	\$/yr
Total material cost	\$3,900,000	\$/yr
Total chemical cost	\$31,300,000	\$/yr
Total energy cost	\$37,800,000	\$/yr
Total amortization cost	\$30,700,000	\$/yr

Summary of Chemical Feed System for Iron

Description	Value	Units
Iron Salt Solution Feed System		
Quantities		
Ferric chloride dosage rate		47100 lb/d
Iron salt dosage rate as equivalent iron		16200 lb/d

Liquid chemical solution fed		0,0133 MGD(US)
Operation labor required		5700 pers-hrs/yr
Costs		
Construction and equipment cost	\$2,450,000	\$
Operational labor cost	\$45,600	\$/yr
Material and supply cost	\$49,100	\$/yr
Amortization cost	\$124,000	\$/yr

Afluente Canoas (MM)

User Input Data

Description	Value	Units
Average Flow		365 MGD(US)
Minimum Flow		320 MGD(US)
Maximum Flow		730 MGD(US)
Suspended Solids		226 mg/L
% Volatile Solids		75 %
BOD		271 mg/L
Soluble BOD		80 mg/L
COD		550 mg/L
Soluble COD		350 mg/L
TKN		70,4 mgN/L
Soluble TKN		35,2 mgN/L
Ammonia		26 mgN/L
Total Phosphorus		9,7 mgP/L
pH		7,3
Cations		160 mg/L
Anions		160 mg/L
Settleable Solids		50 mL/L
Oil and Grease		100 mg/L
Nitrite		0 mgN/L
Nitrate		0 mgN/L
Non-Degradable Fraction of VSS		40 %
Average Summer		68 deg F
Average Winter		60,8 deg F

Tratamiento Preliminar

User Input Data

Screening

Description	Value	Units
Cleaning Method		Mechanically Cleane
Mechanically Cleaned Depth		9,84 ft
Manually Cleaned Depth		2 ft
Width		0,25 in
Space		0,235 in
Slope		15 degrees
Shape Factor		1,8
Approach		1,31 ft/s
Max		3 ft/s
Ave		1,31 ft/s

Grit Removal

Description	Value	Units
Particle Size		0,00786 in
Specific Gravity		2
Type of Grit Removal		Aerated
Number of Units		1

Design By	Depth	
Depth		14,8 ft
Width		65,6 ft
Current Allowance		1,7
Manning Coefficient		0,035
Volume of Grit		40 cuft grit/MGal(US)
Detention Time		10 min
Air Supply per Unit Length of Tank		3 scfm/ft
Surface Velocity		1,5 ft/s
Tank Floor Velocity		1 ft/s
Capital Cost		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance Cost	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		
Bar size		0,25 in
Bar spacing		0,235 in
Slope of bars from horizontal		15 degrees
Head loss through screen		2,6965E+308 ft
Approach velocity		1,31 ft/s
Average flow through velocity (screen)		1,31 ft/s
Maximum flow through velocity (screen)		3 ft/s
Screen channel width		46,4 ft
Average channel depth		9,84 ft
Aerated Grit Chamber		
Design Information		
Maximum flow		751 MGD(US)
Average flow		387 MGD(US)
Minimum flow		342 MGD(US)
Temperature		60,8 deg F
Maximum flow through velocity (grit chamber)		0,362 ft/s
Average flow through velocity (grit chamber)		0,186 ft/s
Size of smallest particle 100% removed		0,00786 in
Specific gravity of particle		2
Number of units		1
Maximum flow/unit		751 MGD(US)
Width of channel		217 ft
Depth of channel		14,8 ft

Length of channel		217 ft
Settling velocity of particle		0,0513 ft/s
Hydraulic retention time		10 min
Volume of grit		0,116 MGD(US)
Air supply		3 cfm
Costs		
Construction and equipment cost	\$13,400,000	\$
Operational labor cost	\$376,000	\$/yr
Maintenance labor cost	\$130,000	\$/yr
Material and supply cost	\$334,000	\$/yr
Energy cost	\$50,600	\$/yr
Amortization cost	\$675,000	\$/yr

Coagulacion y Floculacion

User Input Data

Chemical Phosphorus Removal

Description	Value	Units
Metal Precipitant	Equivalent Iron	
Effluent Phosphorus		5 mg/L
Override Design	TRUE	
Chemical Dosage		5 mg/L

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance Cost	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		
Design Information		
Chemical used	Equivalent Iron	
Chemical dosage		5 mg/L
Mass of chemical per year		2690000 kg/yr
Chemical sludge production		30,5 mg/L
Organic sludge production		2,81 mg/L
Costs		
Chemical cost	\$4,680,000	\$/yr

Espasamiento pro gravedad

User Input Data

Gravity Thickening

Description	Value	Units
Underflow Concentration		5 %

Depth		14 ft
Based On	Mass Loading	
Mass Loading		24 lb/(sqft·d)
Settling Velocity		0,000694 ft/s
Initial Height		4 ft
Intercept		3 ft
Override Design	TRUE	
Surface Area per Thickener		4500 sqft
Number of Units		7
Override Database Costs	FALSE	
Standard 90 ft Diameter Thickener	\$145,000.00	\$
Thickener		20 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$10,000,000.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance Cost	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration		1 %
Thickened concentration		5 %
Mass loading		24 lb/(sqft·d)
Hydraulic loading		769 gal(US)/(sqft·d)
Hydraulic retention time		3,27 hr
Number of tanks		7
Tank volume		441000 cuft
Depth		14 ft
Surface area per tank		4500 sqft
Tank diameter		76 ft
Quantities		
Amount of sludge generated		2020000 lb/d
Volume of thickened sludge		4,15 MGD(US)
Operation labor required		19200 pers-hrs/yr
Maintenance labor required		7700 pers-hrs/yr
Electrical energy required		85500 kWh/yr
Volume of earthwork required		401000 cuft
Slab thickness		11,4 in
Volume of slab concrete required		35100 cuft
Wall thickness		14 in
Volume of wall concrete required		31100 cuft

Costs		
Operational labor cost	\$154,000	\$/yr
Maintenance labor cost	\$66,400	\$/yr
Material and supply cost	\$23,500	\$/yr
Energy cost	\$17,100	\$/yr
Amortization cost	\$148,000	\$/yr

Sedimentación Primaria

User Input Data

Primary Clarification

Description	Value	Units
Design Basis	Peak Flow	
Surface Overflow Rate		2400 gal(US)/(sqft·d)
Sidewater Depth		16 ft
Specific Gravity		1,05
Underflow Concentration		1 %
Weir Overflow Rate		15000 gal(US)/(ft·d)
Type of Clarifier	Circular	
Suspended Solids		58 %
BOD		32 %
COD		40 %
TKN		5 %
Phosphorus		5 %
Override Design	TRUE	
Length-Rectangular Only		0 ft
Width-Rectangular Only		0 ft
Diameter-Circular Only		165 ft
Excavation Depth		4 ft
Number of Tanks per Battery		4
Number of Batteries		4
Override Database Costs	FALSE	
Standard 20 X 120 ft Rectangular Clarifier Mech	\$119,000.00	\$
Standard 90 ft Diameter Circular Mechanism	\$97,600.00	\$
Standard 3000 gpm Pump and Driver Unit	\$19,500.00	\$
Mechanical		20 years
Structural		40 years
Pump		25 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$36,000,000.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance Cost	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifier	21400	sqft
Diameter of each circular clarifier	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	3,57	lb/(sqft·d)
Hydraulic retention time	2,53	hr
Weir length	50300	ft
Volume of sludge generated	8,63	MGD(US)
Surface overflow rate	2200	gal(US)/(sqft·d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete required	374000	cuft
Wall thickness	15	in
Volume of wall concrete required	183000	cuft
Costs		
Operational labor cost	\$68,700	\$/yr
Maintenance labor cost	\$41,900	\$/yr
Material and supply cost	\$141,000	\$/yr
Energy cost	\$12,700	\$/yr
Amortization cost	\$802,000	\$/yr

Notes

Effluent soluble TKN adjusted to satisfy user-specified TKN removal.

Waste Sludge Pumping

Design Information

Average daily pumping rate	8,63	MGD(US)
Total pumping capacity	8,63	MGD(US)
Design capacity per pump	4,32	MGD(US)
Number of pumps	3	
Number of batteries	1	
Firm pumping capacity	8,63	MGD(US)

Quantities

Operation labor required	606	pers-hrs/yr
Maintenance labor required	514	pers-hrs/yr
Electrical energy required	288000	kWh/yr
Volume of earthwork required	2960	cuft
Area of pump building	370	sqft

Costs

Operational labor cost	\$4,850	\$/yr
Maintenance labor cost	\$4,430	\$/yr
Material and supply cost	\$1,110	\$/yr
Energy cost	\$57,600	\$/yr
Amortization cost	\$10,400	\$/yr

Digestion Anaerobica

User Input Data

Anaerobic Digestion

Description	Value	Units
Specific Gravity		1,05

Percent Volatile Solids Destroyed		50 %
Concentration in Digester		3,4 %
Minimum Detention Time in Primary Digester		15 d
Location	Warm-Winter > 10 D	
Raw Wastewater		60,8 deg F
Digester		104 deg F
Fraction of Influent Flow Returned as Supernatant		2 %
Suspended Solids		6250 mg/L
BOD		1000 mg/L
COD		2150 mg/L
TKN		950 mgN/L
Ammonia		650 mg/L
Override Design	TRUE	
Diameter		90 ft
Sidewater Depth		75 ft
Number of Primary Digester Tanks		14
Number of Secondary Digester Tanks		0
Number of Batteries		1
Override Database Costs	FALSE	
Standard 70 ft Diameter Floating Cover	\$444,000.00	\$
Standard 60 ft Diameter Gas Circulation Unit	\$131,000.00	\$
Standard 1 Million Btu/Hr Heating Unit	\$55,300.00	\$
Standard 2 in Diameter Gas Safety Equipment	\$43,400.00	\$
Standard Size Sludge Pump 8gpm At 70 ft of H	\$5,960.00	\$
Natural Gas Per 1000 cuft	\$21.10	\$
Floating Cover		20 years
Gas Circulation Unit		20 years
Heating Unit		20 years
Gas Safety Equipment		20 years
Sludge Pump		25 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$149,000,000.00	\$
Override Annual Operational Cost	TRUE	
	\$398,000.00	\$
Override Annual Maintenance Cost	TRUE	
	\$237,000.00	\$
Override Annual Materials Cost	TRUE	
	\$322,000.00	\$
Override Annual Chemical Cost	TRUE	
	\$0.00	\$
Override Annual Energy Cost	TRUE	
	\$846,000.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Anaerobic Digestion		
Design Information		
Percent VSS destroyed		50 %
Solids concentration in digester		3,4 %
Detention time		15 d

Digester depth	75 ft
Digester diameter	90 ft
Effective digester volume	7010000 cuft
Number of digesters per battery	14
Number of primary digesters per battery	14
Number of secondary digesters per battery	0
Number of batteries	1
Gas produced	92,5 MGD(US)
Heat required	76200000 BTU/hr
Digester gas required	31,7 MGD(US)
Total natural gas required	0 MGD(US)
Quantities	
Operation labor required	85800 pers-hrs/yr
Maintenance labor required	47800 pers-hrs/yr
Electrical energy required	7140000 kWh/yr
Volume of earthwork required	3130000 cuft
Slab thickness	22,3 in
Volume of slab concrete required	175000 cuft
Wall thickness	45 in
Volume of wall concrete required	1240000 cuft
Sidewater depth	75 ft
Surface area/floor of 2-story control bldg	14100 sqft
Piping size	10 in
Length of total piping system	6200 ft
Number of 90 degree elbows	182
Number of tees	357
Number of plug valves	259
Total dry solids treated	1820000 lb/d
Costs	
Amortization cost	\$4,100,000 \$/yr
Notes	
Mass balance based on user input	

BAF

User Input Data

User Wastewater Process

Description	Value	Units
Suspended Solids		95 % Reduction
Volatile Solids		90 % Reduction
BOD		90 % Reduction
Soluble BOD		90 % Reduction
COD		90 % Reduction
Soluble COD		90 % Reduction
TKN		50 % Reduction
Soluble TKN		50 % Reduction
Ammonia		50 % Reduction
Total Phosphorus		5 % Reduction
pH		7
Cations		0 % Reduction
Anions		0 % Reduction
Settleable Solids		90 % Reduction
Oil and Grease		0 % Reduction
Nitrite		0 % Reduction
Nitrate		0 % Reduction
Average Summer		68 deg F
Average Winter		60,8 deg F

Flow Generated	15,6 MGD(US)
Suspended Solids	1 %

Cost Override

Description	Value	Units
Override Construction Cost	TRUE \$640,000,000.00	\$
Override Annual Operational Cost	TRUE \$520,000.00	\$
Override Annual Maintenance Cost	TRUE \$520,000.00	\$
Override Annual Materials Cost	TRUE \$1,500,000.00	\$
Override Annual Chemical Cost	TRUE \$0.00	\$
Override Annual Energy Cost	TRUE \$23,000,000.00	\$
Override Annual Amortization Cost	TRUE \$10,000,000.00	\$

Design Output Data

Description	Value	Units
User Specified Wastewater Process Design Information	No Design Data	

Deshidratación por centrifugas

User Input Data

Centrifugation

Description	Value	Units
Cake Solids Content		28 %
Solids Capture		90 %
Power Requirement		1 HP/gpm(US)
Daily Operating Time		8 hr/d
Weekly Operating Time		7 d/wk
Number of Units		5
Excess Capacity Factor		1,25
Chemical Dose		1 % dry wt
Override Database Costs	FALSE	
Standard 50 hp Centrifuge	\$271,000.00	\$
Centrifuge		15 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE \$50,000,000.00	\$
Override Annual Operational Cost	TRUE \$438,000.00	\$
Override Annual Maintenance Cost	TRUE \$547,000.00	\$
Override Annual Materials Cost	TRUE \$0.00	\$
Override Annual Chemical Cost	TRUE \$5,420,000.00	\$
Override Annual Energy Cost	TRUE	

	\$3,640,000.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	8690	HP
Power required per unit	197	HP
Excess capacity factor	1,25	
Number of units	44	
Chemical dose	1	% dry wt
Chemicals required	29800	lb/d
Sludge flow	10	MGD(US)
Initial solid conc	3,4	%
Operational hours per day	8	hr
Operational days per week	7	d
Quantities		
Number of centrifuges	44	
Power required per unit	197	HP
Area of building	11700	sqft
Dry solids produced	946000	lb/d
Operation labor required	138000	pers-hrs/yr
Maintenance labor required	22000	pers-hrs/yr
Electrical energy required	9820000	kWh/yr
Costs		
Amortization cost	\$6,150,000	\$/yr
Polymer Feed System		
Quantities		
Polymer dosage	9930	lb/d
Liquid chemical solution fed	0,476	MGD(US)
O&M labor required	57600	pers-hrs/yr
Dry material handling and mixing labor required	3730	pers-hrs/yr
Total operation labor required	61300	pers-hrs/yr

Generacion con motores de combustion biogas

User Input Data

User Specified Sludge Process

Description	Value	Units
Volume Reduction		0 %
Percent Volatile Solids Destroyed		0 %

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$37,500,000.00	\$
Override Annual Operational Cost	TRUE	
	\$1,240,000.00	\$
Override Annual Maintenance Cost	TRUE	
	\$1,240,000.00	\$
Override Annual Materials Cost	TRUE	
	\$833,000.00	\$
Override Annual Chemical Cost	TRUE	
	\$0.00	\$
Override Annual Energy Cost	TRUE	

Override Annual Amortization Cost	\$-11,100,000.00	\$
	TRUE	
	\$1,800,000.00	\$

Design Output Data

Description	Value	Units
-------------	-------	-------

Filtro Desnitrificador

User Input Data

Denitrification - Attached Growth

Description	Value	Units
Allowable Effluent Nitrate		5 mg/L
Alkalinity Production		3 mg/L
Methanol Requirement		3 lb/lb NO3
Specific Surface Area of Media		41 1/ft
Application Rate		1080 gal(US)/(sqft·d)
Backwash Rate		17300 gal(US)/(sqft·d)
Minimum Media Depth		12 ft
Override Database Costs	FALSE	
Media per cuft	\$5.09	\$
1 Cross-Sectional sqft of Distribution System ar	\$121.00	\$
Standard 3000gpm Pump and Driver Unit	\$19,500.00	\$
1 lb of Methanol	\$0.84	\$
Distribution System		25 years
Pump		25 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance Cost	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	TRUE	
	\$12,300,000.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Attached Growth Denitrification		
Design Information		
Surface removal rate		0,0061 lb/(sqft·d)
Total media surface area	-4900000	sqft
Total volume of media needed	-110000	cuft
Total column area	338000	sqft
Actual media volume	4050000	cuft
Hydraulic retention time		120 min
Daily methanol required		0 lb/d
Total backwash required		4860 MGD(US)

Costs		
Construction and equipment cost	\$96,000,000	\$
Operational labor cost	\$248,000	\$/yr
Maintenance labor cost	\$424,000	\$/yr
Material and supply cost	\$480,000	\$/yr
Energy cost	\$7,740,000	\$/yr
Amortization cost	\$5,560,000	\$/yr
Notes		
This unit is not needed. The influent nitrate is less than the allowable effluent nitrate.		

Internal Recycle Pumping

Design Information

Average daily pumping rate	365 MGD(US)
Total pumping capacity	730 MGD(US)
Design capacity per pump	26,1 MGD(US)
Number of pumps	5
Number of batteries	7
Firm pumping capacity	365 MGD(US)

Quantities

Operation labor required	8340 pers-hrs/yr
Maintenance labor required	5520 pers-hrs/yr
Electrical energy required	12000000 kWh/yr
Volume of earthwork required	126000 cuft
Area of pump building	15800 sqft

Costs

Construction and equipment cost	\$9,890,000	\$
Operational labor cost	\$66,700	\$/yr
Maintenance labor cost	\$47,600	\$/yr
Material and supply cost	\$69,200	\$/yr
Energy cost	\$2,410,000	\$/yr
Amortization cost	\$645,000	\$/yr

Wash Water Pumping

Design Information

Average daily pumping rate	38 MGD(US)
Total pumping capacity	38 MGD(US)
Design capacity per pump	19 MGD(US)
Number of pumps	3
Number of batteries	1
Firm pumping capacity	38 MGD(US)

Quantities

Operation labor required	946 pers-hrs/yr
Maintenance labor required	897 pers-hrs/yr
Electrical energy required	1730 kWh/yr
Volume of earthwork required	7600 cuft
Area of pump building	950 sqft

Costs

Construction and equipment cost	\$588,000	\$
Operational labor cost	\$7,570	\$/yr
Maintenance labor cost	\$7,730	\$/yr
Material and supply cost	\$4,120	\$/yr
Energy cost	\$346	\$/yr
Amortization cost	\$38,400	\$/yr

Disposicion Final - Costo No Incluido

User Input Data

Hauling and Land Filling

Description	Value	Units
-------------	-------	-------

Distance to Disposal Site	15,5 miles
Daily Operation	8 hr
Loading Time per Vehicle	0,75 hr
Hauling Time per Trip	1 hr
Disposal Cost Based On	Sludge Disposal per
Override Database Costs	TRUE
Standard 22 cuyd Vehicle	\$314,000.00 \$
Annual Charge of Land Fill	\$43,100.00 \$
Sludge Disposal per cuyd	\$23.60 \$
Sludge Disposal per ton	\$28.00 \$
Vehicle	15 years
Structural	40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance Cost	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	TRUE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling		
Design Information		
Volume of sludge hauled	0,364	MGD(US)
Truck capacity	810	cuft
Round trip time to disposal site	1	hr
Truck loading time	0,75	hr
Operational hours per day	8	hr
Number of trucks required	14	
Distance to disposal site	15,5	miles
Quantities		
Total sludge volume hauled	0,364	MGD(US)
Maximum anticipated landfill downtime	30	d
Anticipated sludge storage height	8	ft
Sludge storage shed area	183000	sqft
Width of sludge storage shed slab	302	ft
Length of sludge storage shed slab	605	ft
Volume of earthwork required	463000	cuft
Volume of slab concrete required	187000	cuft
Surface area of canopy roof	183000	sqft
Round trip haul distance	31,1	miles
Round trips per day per truck	5	
Distance traveled per year per truck	38800	miles
Sludge hauled	3190000	lb/d
Operation labor required	43900	pers-hrs/yr

LandFilling cost	\$15,500,000	\$/yr
------------------	--------------	-------

Desinfeccion por cloro

User Input Data

Chlorination

Description	Value	Units
Contact Time At Peak Flow		30 min
Chlorine Dose		10 mg/L
Influent Coliform Count		10000000 /100mL
Override Design	FALSE	
Volume of Tank		2030000 cuft
Override Database Costs	FALSE	
1 Ton of Chlorine	\$1,610.00	\$
Standard 2000 lb/d Chlorinator	\$37,900.00	\$
Chlorinator		15 years
Structural		40 years

Cost Override


Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance Cost	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Chlorination		
Design Information		
Volume of tank	2030000	cuft
Average chlorine required	30400	lb/d
Peak chlorine required	60900	lb/d
Influent coliform count	10000000	/100mL
Effluent coliform count	29,2	/100mL
Quantities		
Operational labor required	9790	pers-hrs/yr
Maintenance labor required	11800	pers-hrs/yr
Electrical energy required	269000	kWh/yr
Volume of earthwork required	731000	cuft
Volume of slab concrete required	204000	cuft
Volume of wall concrete required	167000	cuft
Number of chlorinators and evaporators	4	
Chlorination building area	1440	sqft
Number of chlorine cylinders	457	
Area of chlorine storage building	64000	sqft
Costs		
Construction and equipment cost	\$10,300,000	\$

Operational labor cost	\$78,300	\$/yr
Maintenance labor cost	\$102,000	\$/yr
Material and supply cost	\$140,000	\$/yr
Chemical cost	\$8,940,000	\$/yr
Energy cost	\$53,700	\$/yr
Amortization cost	\$656,000	\$/yr

FIII-Alt 1- Alim Esc+FDNs



Summary
Equipment Database
 Sept 2007,(USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$3,010,000,000	\$1,650,000,000	\$3,700,000	\$3,080,000	\$4,030,000	\$28,400,000	\$38,000,000	\$35,600,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Tratamiento Preliminar	\$13,200,000	\$367,000	\$127,000	\$331,000	\$0	\$50,000	\$669,000
Coagulación y Floculación	\$0	\$0	\$0	\$0	\$4,550,000	\$0	\$0
Sedimentación Primaria	\$36,000,000	\$73,200	\$46,100	\$142,000	\$0	\$60,600	\$811,000
Alimentación Escalonada (MLE)	\$179,000,000	\$233,000	\$184,000	\$1,340,000	\$0	\$23,100,000	\$11,400,000
Sedimentador Secundario	\$61,000,000	\$114,000	\$71,200	\$301,000	\$0	\$59,700	\$1,800,000
Filtro Desnitrificador	\$107,000,000	\$323,000	\$480,000	\$555,000	\$9,490,000	\$10,200,000	\$6,260,000
Desinfección por cloro	\$10,300,000	\$78,300	\$102,000	\$140,000	\$8,940,000	\$53,700	\$656,000
Espasamiento pro gravedad	\$10,000,000	\$95,800	\$44,800	\$23,500	\$0	\$11,900	\$148,000
Digestion Anaerobica	\$149,000,000	\$398,000	\$237,000	\$322,000	\$0	\$846,000	\$3,880,000
Deshidratación por centrifugas	\$50,000,000	\$438,000	\$547,000	\$0	\$5,420,000	\$3,640,000	\$4,020,000
Generación con motores de co	\$37,500,000	\$1,240,000	\$1,240,000	\$833,000	\$0	\$0	\$1,800,000
Blower System	\$79,200,000	\$0	\$0	\$0	\$0	\$0	\$4,000,000
Iron Feed System	\$2,360,000	\$44,800	\$0	\$47,100	\$0	\$0	\$119,000
Other Costs	\$912,000,000	\$293,000	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		210 acre
Administration labor hours		35400 hr/yr
Laboratory labor hours		14500 hr/yr
Costs		
DIRECT COSTS		
Mobilization	\$14,500,000	\$
Site preparation	\$12,500,000	\$
Site electrical	\$48,400,000	\$
Yard piping	\$29,600,000	\$
Instrumentation and control	\$30,300,000	\$
Lab and administration building	\$23,100,000	\$
Unit process construction costs	\$734,000,000	\$
Profit	\$134,000,000	\$
Total construction costs	\$1,030,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$216,000,000	\$
Legal cost	\$20,500,000	\$
Engineering design fee	\$154,000,000	\$
Inspection cost	\$20,500,000	\$
Contingency	\$103,000,000	\$
Technical	\$20,500,000	\$
Total indirect costs	\$534,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$85,600,000	\$
LABOR COSTS		
Administration labor cost	\$177,000	\$/yr
Laboratory labor cost	\$116,000	\$/yr
Unit process operation labor cost	\$3,400,000	\$/yr
Unit process maintenance labor cost	\$3,080,000	\$/yr
Total labor costs	\$6,780,000	\$/yr
PROJECT SUMMARY		
Present worth	\$3,010,000,000	\$
Total project cost	\$1,650,000,000	\$
Total operation labor cost	\$3,700,000	\$/yr
Total maintenance labor cost	\$3,080,000	\$/yr
Total material cost	\$4,030,000	\$/yr
Total chemical cost	\$28,400,000	\$/yr
Total energy cost	\$38,000,000	\$/yr
Total amortization cost	\$35,600,000	\$/yr

Summary of Air Supply System

Description	Value	Units
Blower System for Entire Plant		
Design Information		
Minimum air flow capacity		242000 scfm

Safety factor	2	
Requested air flow capacity	483000	scfm
Total capacity of blowers	483000	scfm
Number of blowers in use	5	
Total number of blowers	6	
Capacity of individual blowers	96700	scfm
Estimated cost of an installed blower	\$11,900,000	\$
Blower building area	3650	sqft
Costs		
Construction and equipment cost	\$79,200,000	\$
Amortization cost	\$4,000,000	\$/yr

Notes

Energy costs are shown at the individual unit processes that require air

Summary of Chemical Feed System for Iron

Description	Value	Units
Iron Salt Solution Feed System		
Quantities		
Ferric chloride dosage rate	45800	lb/d
Iron salt dosage rate as equivalent	15700	lb/d
Liquid chemical solution fed	0,0129	MGD(US)
Operation labor required	5600	pers-hrs/yr
Costs		
Construction and equipment cost	\$2,360,000	\$
Operational labor cost	\$44,800	\$/yr
Material and supply cost	\$47,100	\$/yr
Amortization cost	\$119,000	\$/yr

Afluente Canoas (MM)

User Input Data

Description	Value	Units
Average Flow	365	MGD(US)
Minimum Flow	320	MGD(US)
Maximum Flow	730	MGD(US)
Suspended Solids	226	mg/L
% Volatile Solids	75	%
BOD	271	mg/L
Soluble BOD	80	mg/L
COD	550	mg/L
Soluble COD	350	mg/L
TKN	70,4	mgN/L
Soluble TKN	35,2	mgN/L
Ammonia	26	mgN/L
Total Phosphorus	9,7	mgP/L
pH	7,3	
Cations	160	mg/L
Anions	160	mg/L
Settleable Solids	50	mL/L
Oil and Grease	100	mg/L
Nitrite	0	mgN/L
Nitrate	0	mgN/L
Non-Degradable Fraction of VS	40	%
Average Summer	68	deg F
Average Winter	60,8	deg F

Tratamiento Preliminar

User Input Data

Screening

Description	Value	Units
Cleaning Method	Mechanically Cleaned	
Mechanically Cleaned Depth	9,84	ft
Manually Cleaned Depth	2	ft
Width	0,25	in
Space	0,235	in
Slope	15	degrees
Shape Factor	1,8	
Approach	1,31	ft/s
Max	3	ft/s
Ave	1,31	ft/s

Grit Removal

Description	Value	Units
Particle Size	0,00786	in
Specific Gravity	2	
Type of Grit Removal	Aerated	
Number of Units	1	
Design By	Depth	
Depth	14,8	ft
Width	65,6	ft
Current Allowance	1,7	
Manning Coefficient	0,035	
Volume of Grit	40	cuft grit/MGal(US)
Detention Time	10	min
Air Supply per Unit Length of T	3	scfm/ft
Surface Velocity	1,5	ft/s
Tank Floor Velocity	1	ft/s
Capital Cost	40	years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		
Bar size	0,25	in
Bar spacing	0,235	in
Slope of bars from horizontal	15	degrees

Head loss through screen	2,6965E+308	ft
Approach velocity	1,31	ft/s
Average flow through velocity (1,31	ft/s
Maximum flow through velocity	3	ft/s
Screen channel width	45,1	ft
Average channel depth	9,84	ft
Aerated Grit Chamber		
Design Information		
Maximum flow	740	MGD(US)
Average flow	376	MGD(US)
Minimum flow	331	MGD(US)
Temperature	60,8	deg F
Maximum flow through velocity	0,359	ft/s
Average flow through velocity (0,182	ft/s
Size of smallest particle 100%	0,00786	in
Specific gravity of particle	2	
Number of units	1	
Maximum flow/unit	740	MGD(US)
Width of channel	216	ft
Depth of channel	14,8	ft
Length of channel	216	ft
Settling velocity of particle	0,0513	ft/s
Hydraulic retention time	10	min
Volume of grit	0,113	MGD(US)
Air supply	3	cfm
Costs		
Construction and equipment cost	\$13,200,000	\$
Operational labor cost	\$367,000	\$/yr
Maintenance labor cost	\$127,000	\$/yr
Material and supply cost	\$331,000	\$/yr
Energy cost	\$50,000	\$/yr
Amortization cost	\$669,000	\$/yr

Coagulation y Floculación

User Input Data

Chemical Phosphorus Removal

Description	Value	Units
Metal Precipitant	Equivalent Iron	
Effluent Phosphorus		5 mg/L
Override Design	TRUE	
Chemical Dosage		5 mg/L

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$

Override Annual Amortization (FALSE
 \$0.00 \$

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal Design Information		
Chemical used	Equivalent Iron	
Chemical dosage		5 mg/L
Mass of chemical per year	2610000	kg/yr
Chemical sludge production		31,1 mg/L
Organic sludge production		2,8 mg/L
Costs		
Chemical cost	\$4,550,000	\$/yr

Espasamiento pro gravedad

User Input Data

Gravity Thickening

Description	Value	Units
Underflow Concentration		5 %
Depth		14 ft
Based On	Mass Loading	
Mass Loading		24 lb/(sqft·d)
Settling Velocity	0,000694	ft/s
Initial Height		4 ft
Intercept		3 ft
Override Design	TRUE	
Surface Area per Thickener		4500 sqft
Number of Units		7
Override Database Costs	FALSE	
Standard 90 ft Diameter Thickener	\$145,000.00	\$
Thickener		20 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$10,000,000.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization (FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Gravity Thickening Design Information		
Initial concentration		1 %

Thickened concentration	5 %
Mass loading	24 lb/(sqft·d)
Hydraulic loading	416 gal(US)/(sqft·d)
Hydraulic retention time	6,03 hr
Number of tanks	7
Tank volume	441000 cuft
Depth	14 ft
Surface area per tank	4500 sqft
Tank diameter	76 ft
Quantities	
Amount of sludge generated	1090000 lb/d
Volume of thickened sludge	2,25 MGD(US)
Operation labor required	12000 pers-hrs/yr
Maintenance labor required	5200 pers-hrs/yr
Electrical energy required	59700 kWh/yr
Volume of earthwork required	401000 cuft
Slab thickness	11,4 in
Volume of slab concrete requir	35100 cuft
Wall thickness	14 in
Volume of wall concrete requir	31100 cuft
Costs	
Operational labor cost	\$95,800 \$/yr
Maintenance labor cost	\$44,800 \$/yr
Material and supply cost	\$23,500 \$/yr
Energy cost	\$11,900 \$/yr
Amortization cost	\$148,000 \$/yr

Sedimentación Primaria

User Input Data

Primary Clarification

Description	Value	Units
Design Basis	Peak Flow	
Surface Overflow Rate	2400	gal(US)/(sqft·d)
Sidewater Depth	16	ft
Specific Gravity	1,05	
Underflow Concentration	1	%
Weir Overflow Rate	15000	gal(US)/(ft·d)
Type of Clarifier	Circular	
Suspended Solids	58	%
BOD	32	%
COD	40	%
TKN	5	%
Phosphorus	5	%
Override Design	TRUE	
Length-Rectangular Only	0	ft
Width-Rectangular Only	0	ft
Diameter-Circular Only	165	ft
Excavation Depth	4	ft
Number of Tanks per Battery	4	
Number of Batteries	4	
Override Database Costs	FALSE	
Standard 20 X 120 ft Rectangu	\$119,000.00	\$
Standard 90 ft Diameter Circul:	\$97,600.00	\$
Standard 3000 gpm Pump and	\$19,500.00	\$
Mechanical	20	years
Structural	40	years

Pump 25 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE \$36,000,000.00	\$
Override Annual Operational Cost	FALSE \$0.00	\$
Override Annual Maintenance	FALSE \$0.00	\$
Override Annual Materials Cost	FALSE \$0.00	\$
Override Annual Chemical Cost	FALSE \$0.00	\$
Override Annual Energy Cost	FALSE \$0.00	\$
Override Annual Amortization Cost	FALSE \$0.00	\$

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifier	21400	sqft
Diameter of each circular clarifier	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	2,97	lb/(sqft·d)
Hydraulic retention time	2,6	hr
Weir length	49600	ft
Volume of sludge generated	7,17	MGD(US)
Surface overflow rate	2170	gal(US)/(sqft·d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete required	374000	cuft
Wall thickness	15	in
Volume of wall concrete required	183000	cuft
Costs		
Operational labor cost	\$68,700	\$/yr
Maintenance labor cost	\$41,900	\$/yr
Material and supply cost	\$141,000	\$/yr
Energy cost	\$12,700	\$/yr
Amortization cost	\$802,000	\$/yr
Notes		
Effluent soluble TKN adjusted to satisfy user-specified TKN removal.		
Waste Sludge Pumping		
Design Information		
Average daily pumping rate	7,17	MGD(US)
Total pumping capacity	7,17	MGD(US)
Design capacity per pump	3,59	MGD(US)
Number of pumps	3	

Number of batteries		1
Firm pumping capacity		7,17 MGD(US)
Quantities		
Operation labor required		570 pers-hrs/yr
Maintenance labor required		484 pers-hrs/yr
Electrical energy required		239000 kWh/yr
Volume of earthwork required		2730 cuft
Area of pump building		341 sqft
Costs		
Operational labor cost	\$4,560	\$/yr
Maintenance labor cost	\$4,170	\$/yr
Material and supply cost	\$1,030	\$/yr
Energy cost	\$47,800	\$/yr
Amortization cost	\$9,580	\$/yr

Digestion Anaerobica

User Input Data

Anaerobic Digestion

Description	Value	Units
Specific Gravity		1,05
Percent Volatile Solids Destroy		50 %
Concentration in Digester		3,4 %
Minimum Detention Time in Pri		15 d
Location	Warm-Winter >	10 D
Raw Wastewater		60,8 deg F
Digester		104 deg F
Fraction of Influent Flow Return		2 %
Suspended Solids		6250 mg/L
BOD		1000 mg/L
COD		2150 mg/L
TKN		950 mgN/L
Ammonia		650 mg/L
Override Design	TRUE	
Diameter		90 ft
Sidewater Depth		75 ft
Number of Primary Digester T ₂		14
Number of Secondary Digester		0
Number of Batteries		1
Override Database Costs	FALSE	
Standard 70 ft Diameter Floatir	\$444,000.00	\$
Standard 60 ft Diameter Gas C	\$131,000.00	\$
Standard 1 Million Btu/Hr Heat	\$55,300.00	\$
Standard 2 in Diameter Gas S ₂	\$43,400.00	\$
Standard Size Sludge Pump 8 ₂	\$5,960.00	\$
Natural Gas Per 1000 cuft	\$21.10	\$
Floating Cover		20 years
Gas Circulation Unit		20 years
Heating Unit		20 years
Gas Safety Equipment		20 years
Sludge Pump		25 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$149,000,000.00	\$

Override Annual Operational Cost	TRUE	
		\$398,000.00 \$
Override Annual Maintenance	TRUE	
		\$237,000.00 \$
Override Annual Materials Cost	TRUE	
		\$322,000.00 \$
Override Annual Chemical Cost	TRUE	
		\$0.00 \$
Override Annual Energy Cost	TRUE	
		\$846,000.00 \$
Override Annual Amortization Cost	FALSE	
		\$0.00 \$

Design Output Data

Description	Value	Units
Anaerobic Digestion Design Information		
Percent VSS destroyed	50	%
Solids concentration in digester	3,4	%
Detention time	15	d
Digester depth	75	ft
Digester diameter	90	ft
Effective digester volume	7010000	cuft
Number of digesters per battery	14	
Number of primary digesters per battery	14	
Number of secondary digesters per battery	0	
Number of batteries	1	
Gas produced	37,7	MGD(US)
Heat required	46300000	BTU/hr
Digester gas required	19,2	MGD(US)
Total natural gas required	0	MGD(US)
Quantities		
Operation labor required	51300	pers-hrs/yr
Maintenance labor required	29200	pers-hrs/yr
Electrical energy required	4370000	kWh/yr
Volume of earthwork required	3130000	cuft
Slab thickness	22,3	in
Volume of slab concrete required	175000	cuft
Wall thickness	45	in
Volume of wall concrete required	1240000	cuft
Sidewater depth	75	ft
Surface area/floor of 2-story concrete	14100	sqft
Piping size	10	in
Length of total piping system	6200	ft
Number of 90 degree elbows	182	
Number of tees	357	
Number of plug valves	259	
Total dry solids treated	985000	lb/d
Costs		
Amortization cost	\$3,880,000	\$/yr
Notes		
Mass balance based on user input		

Alimentacion Escalonada (MLE)

User Input Data

Pre-denitrification

Description	Value	Units
Aeration Type	Diffused Aeration	
Effluent Nitrate	20	mgN/L
Design Basis	Specify Design SRT	
Design SRT	7	d
Safety Factor for Calculated SRT	1,5	
Maximum Heterotrophic Specific Growth Rate	6	1/d
Heterotrophic Decay Rate	0,24	1/d
Maximum Autotrophic Specific Growth Rate	0,5	1/d
Autotrophic Decay Rate	0,04	1/d
Biomass Yield	0,5	
Readily Biodegradable Substrate Fraction	30	%
Suspended Solids	3200	mg/L
Bubble Size	Fine Bubble	
Alpha Factor for Oxygen Transfer	0,5	
Beta Factor for Oxygen Saturation	0,95	
Coarse Bubble Minimum Air Flow	19,8	scfm/1000 cuft
Fine Bubble Minimum Air Flow	0,12	scfm/ft2
Standard Oxygen Transfer Efficiency	20	%
Override Design	TRUE	
Aerobic Volume	15100000	cuft
Anoxic Volume	5610000	cuft
Tank Width	22	ft
Tank Depth	16,4	ft
Pipe Gallery Width	55,6	ft
Excavation Depth	4,27	ft
Number of Tanks	7	
Number of Batteries	22	
Required Air Flow - Diffused Aeration	16	scfm/1000 cuft
Required Horsepower - Mechanical	0	HP
Number of Mixers per Anoxic Tank	3	
Override Database Costs	FALSE	
Slow Speed 20 hp Aerator	\$21,700.00	\$
Standard 2 scfm Fine Bubble Diffuser	\$54.20	\$
Standard 12 scfm Coarse Bubble Diffuser	\$32.50	\$
Standard 550 scfm Swing Arm Diffuser	\$15,200.00	\$
5 hp Vertical Turbine Mixer	\$9,700.00	\$
Standard 3000 gpm Pump and Control	\$19,500.00	\$
Mechanical Aerator	20	years
Fine Bubble Diffuser	10	years
Coarse Bubble Diffuser	20	years
Swing Arm Diffuser	20	years
Turbine Mixer	20	years
Pump	25	years
Structural	40	years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$

Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Pre-Denitrification Activated Sludge Design Information		
Design Override Enabled - sized		
Pre-denitrification Design		
Design aerobic SRT for nitrification	7 d	
Total reactor SRT	9,6 d	
Design SS	3790 mg/L	
Calculated VSS	2720 mg/L	
Calculated VSS:TSS ratio	0,717 lb VSS/lb SS	
Total volume of anoxic reactors	5610000 cuft	
Total volume of aerobic reactors	15100000 cuft	
Total volume of all reactors	20700000 cuft	
Width of parallel train	22 ft	
Sidewater depth	16,4 ft	
Number of batteries	22	
Number of parallel trains per battery	7	
Number of anoxic cells within battery	2	
Number of aerobic cells within battery	3	
Total number of dividing walls	616	
Anoxic hydraulic retention time	2,72 hr	
Aerobic hydraulic retention time	7,31 hr	
Amount of sludge generated	511000 lb/d	
Sludge recycle rate	227 MGD(US)	
Nitrogen requirement for biomass	11,8 mg/L	
Phosphorus requirement for biomass	2,37 mg/L	
Oxygen requirement to meet average	1160000 lb/d	
Air flow required to meet average	242000 scfm	
Design air flow	16 scfm/1000 cuft	
Design air flow	40,4 scfm/ft2	
Quantities		
Operation labor required	23400 pers-hrs/yr	
Maintenance labor required	17200 pers-hrs/yr	
Electrical energy required	93200000 kWh/yr	
Volume of earthwork required	10400000 cuft	
Volume of slab concrete required	3230000 cuft	
Volume of wall concrete required	2360000 cuft	
Handrail length	4400 ft	
Number of diffusers per train	785	
Fine bubble diffuser floor coverage	5,8 %	
Number of swing arm headers	15	
Required mixing power	2770 HP	
Total number of mixers	924	
Design mixing power per mixer	5 HP	
Mixing power for each un-aerated	9 HP	
Costs		
Construction and equipment cost	\$152,000,000	\$
Operational labor cost	\$187,000	\$/yr

Maintenance labor cost	\$149,000	\$/yr
Material and supply cost	\$1,150,000	\$/yr
Energy cost	\$18,600,000	\$/yr
Amortization cost	\$9,690,000	\$/yr

Notes

Minimum winter SRT not calculated, design SRT specified by user

Design is based on user specified design overrides - Performance data is assumed to be correct

Internal Recycle Pumping

Design Information

Average daily pumping rate	2,91 MGD(US)
Total pumping capacity	5,81 MGD(US)
Design capacity per pump	2,91 MGD(US)
Number of pumps	462
Number of batteries	1
Firm pumping capacity	2,91 MGD(US)

Quantities

Operation labor required	505 pers-hrs/yr
Maintenance labor required	422 pers-hrs/yr
Electrical energy required	97200 kWh/yr
Volume of earthwork required	2520 cuft
Area of pump building	315 sqft

Costs

Construction and equipment cost	\$20,600,000	\$
Operational labor cost	\$4,040	\$/yr
Maintenance labor cost	\$3,640	\$/yr
Material and supply cost	\$144,000	\$/yr
Energy cost	\$2,990,000	\$/yr
Amortization cost	\$1,350,000	\$/yr

Notes

Pumps are sized based on an individual battery of internal pumps for each train

Sludge Recycle Pumping

Design Information

Average daily pumping rate	227 MGD(US)
Total pumping capacity	453 MGD(US)
Design capacity per pump	28,3 MGD(US)
Number of pumps	5
Number of batteries	4
Firm pumping capacity	227 MGD(US)

Quantities

Operation labor required	5150 pers-hrs/yr
Maintenance labor required	3630 pers-hrs/yr
Electrical energy required	7490000 kWh/yr
Volume of earthwork required	77900 cuft
Area of pump building	9740 sqft

Costs

Construction and equipment cost	\$6,210,000	\$
Operational labor cost	\$41,200	\$/yr
Maintenance labor cost	\$31,300	\$/yr
Material and supply cost	\$43,500	\$/yr
Energy cost	\$1,500,000	\$/yr
Amortization cost	\$405,000	\$/yr

Deshidratación por centrifugas

User Input Data

Centrifugation

Description	Value	Units
-------------	-------	-------

Cake Solids Content		28 %
Solids Capture		90 %
Power Requirement		1 HP/gpm(US)
Daily Operating Time		8 hr/d
Weekly Operating Time		7 d/wk
Number of Units		5
Excess Capacity Factor		1,25
Chemical Dose		1 % dry wt
Override Database Costs	FALSE	
Standard 50 hp Centrifuge	\$271,000.00	\$
Centrifuge		15 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE \$50,000,000.00	\$
Override Annual Operational Cost	TRUE \$438,000.00	\$
Override Annual Maintenance	TRUE \$547,000.00	\$
Override Annual Materials Cost	TRUE \$0.00	\$
Override Annual Chemical Cost	TRUE \$5,420,000.00	\$
Override Annual Energy Cost	TRUE \$3,640,000.00	\$
Override Annual Amortization Cost	FALSE \$0.00	\$

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	5670	HP
Power required per unit	196	HP
Excess capacity factor	1,25	
Number of units	29	
Chemical dose	1	% dry wt
Chemicals required	19400	lb/d
Sludge flow	6,53	MGD(US)
Initial solid conc	3,4	%
Operational hours per day	8	hr
Operational days per week	7	d
Quantities		
Number of centrifuges	29	
Power required per unit	196	HP
Area of building	7740	sqft
Dry solids produced	617000	lb/d
Operation labor required	95300	pers-hrs/yr
Maintenance labor required	15300	pers-hrs/yr
Electrical energy required	6620000	kWh/yr
Costs		
Amortization cost	\$4,020,000	\$/yr
Polymer Feed System		
Quantities		

Polymer dosage	6480 lb/d
Liquid chemical solution fed	0,311 MGD(US)
O&M labor required	43700 pers-hrs/yr
Dry material handling and mixii	3300 pers-hrs/yr
Total operation labor required	47000 pers-hrs/yr

Generacion con motores de combustion biogas

User Input Data

User Specified Sludge Process

Description	Value	Units
Volume Reduction		0 %
Percent Volatile Solids Destroy		0 %

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$37,500,000.00	\$
Override Annual Operational C	TRUE	
	\$1,240,000.00	\$
Override Annual Maintenance	TRUE	
	\$1,240,000.00	\$
Override Annual Materials Cos	TRUE	
	\$833,000.00	\$
Override Annual Chemical Cos	TRUE	
	\$0.00	\$
Override Annual Energy Cost	TRUE	
	\$-11,100,000.00	\$
Override Annual Amortization (TRUE	
	\$1,800,000.00	\$

Design Output Data

Description	Value	Units
-------------	-------	-------

Sedimentador Secundario

User Input Data

Secondary Clarifier

Description	Value	Units
Design Basis	Average Flow	
Surface Overflow Rate		500 gal(US)/(sqft·d)
Sidewater Depth		9 ft
Specific Gravity		1,03
Underflow Concentration		1 %
Weir Overflow Rate - Maximun		15000 gal(US)/(ft·d)
Effluent Suspended Solids		20 mg/L
Type of Clarifier	Circular	
Override Design	FALSE	
Length-Rectangular Only		0 ft
Width-Rectangular Only		0 ft
Diameter-Circular Only		122 ft
Excavation Depth		4 ft
Number of Tanks per Battery		16
Number of Batteries		4
Override Database Costs	FALSE	
Rectangular Clarifier Mechanis	\$119,000.00	\$
Circular Clarifier Mechanism-9	\$97,600.00	\$
Standard 3000 gpm Pump and	\$19,500.00	\$

Mechanical	20 years
Structural	40 years
Pump	25 years

Cost Override

Description	Value	Units
Override Construction Cost	TRUE	
	\$61,000,000.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Secondary Clarification		
Design Information		
Surface area	742000	sqft
Surface area per circular clarifier	11600	sqft
Diameter of each circular clarifier	122	ft
Number of clarifiers per battery	16	
Number of batteries	4	
Solids loading rate	25,5	lb/(sqft-d)
Hydraulic retention time	3,23	hr
Weir length	49100	ft
Volume of wasted sludge	5,95	MGD(US)
Quantities		
Operation labor required	13700	pers-hrs/yr
Maintenance labor required	7790	pers-hrs/yr
Electrical energy required	99900	kWh/yr
Volume of earthwork required	10700000	cuft
Slab thickness	10,1	in
Volume of slab concrete required	709000	cuft
Wall thickness	11,5	in
Volume of wall concrete required	256000	cuft
Costs		
Operational labor cost	\$109,000	\$/yr
Maintenance labor cost	\$67,200	\$/yr
Material and supply cost	\$301,000	\$/yr
Energy cost	\$20,000	\$/yr
Amortization cost	\$1,790,000	\$/yr
Waste Sludge Pumping		
Design Information		
Average daily pumping rate	5,95	MGD(US)
Total pumping capacity	5,95	MGD(US)
Design capacity per pump	2,97	MGD(US)
Number of pumps	3	
Number of batteries	1	

Firm pumping capacity		5,95 MGD(US)
Quantities		
Operation labor required		553 pers-hrs/yr
Maintenance labor required		469 pers-hrs/yr
Electrical energy required		198000 kWh/yr
Volume of earthwork required		2540 cuft
Area of pump building		317 sqft
Costs		
Operational labor cost	\$4,430	\$/yr
Maintenance labor cost	\$4,040	\$/yr
Material and supply cost	\$947	\$/yr
Energy cost	\$39,700	\$/yr
Amortization cost	\$8,830	\$/yr

Disposicion Final - Costo No Incluido

User Input Data

Hauling and Land Filling

Description	Value	Units
Distance to Disposal Site		15,5 miles
Daily Operation		8 hr
Loading Time per Vehicle		0,75 hr
Hauling Time per Trip		1 hr
Disposal Cost Based On	Sludge Disposal per	
Override Database Costs	TRUE	
Standard 22 cuyd Vehicle	\$314,000.00	\$
Annual Charge of Land Fill	\$43,100.00	\$
Sludge Disposal per cuyd	\$23.60	\$
Sludge Disposal per ton	\$28.00	\$
Vehicle		15 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational C	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cos	FALSE	
	\$0.00	\$
Override Annual Chemical Cos	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization (TRUE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling		
Design Information		
Volume of sludge hauled		0,237 MGD(US)
Truck capacity		810 cuft
Round trip time to disposal site		1 hr
Truck loading time		0,75 hr

Operational hours per day	8 hr
Number of trucks required	9
Distance to disposal site	15,5 miles
Quantities	
Total sludge volume hauled	0,237 MGD(US)
Maximum anticipated landfill d	30 d
Anticipated sludge storage hei	8 ft
Sludge storage shed area	119000 sqft
Width of sludge storage shed s	244 ft
Length of sludge storage shed	488 ft
Volume of earthwork required	303000 cuft
Volume of slab concrete requir	123000 cuft
Surface area of canopy roof	119000 sqft
Round trip haul distance	31,1 miles
Round trips per day per truck	5
Distance traveled per year per	38800 miles
Sludge hauled	2080000 lb/d
Operation labor required	28600 pers-hrs/yr
LandFilling cost	\$10,100,000 \$/yr

Filtro Desnitrificador

User Input Data

Denitrification - Attached Growth

Description	Value	Units
Allowable Effluent Nitrate		20 mg/L
Alkalinity Production		3 mg/L
Methanol Requirement		3 lb/lb NO3
Specific Surface Area of Media		41 1/ft
Application Rate		1080 gal(US)/(sqft-d)
Backwash Rate		17300 gal(US)/(sqft-d)
Minimum Media Depth		12 ft
Override Database Costs	FALSE	
Media per cuft	\$5.09	\$
1 Cross-Sectional sqft of Distrib	\$121.00	\$
Standard 3000gpm Pump and	\$19,500.00	\$
1 lb of Methanol	\$0.84	\$
Distribution System		25 years
Pump		25 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational C	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cos	FALSE	
	\$0.00	\$
Override Annual Chemical Cos	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization (FALSE	
	\$0.00	\$

Design Output Data

Description	Value	Units
Attached Growth Denitrification		
Design Information		
Surface removal rate	0,0061	lb/(sqft-d)
Total media surface area	0	sqft
Total volume of media needed	0	cuft
Total column area	338000	sqft
Actual media volume	4060000	cuft
Hydraulic retention time	120	min
Daily methanol required	183000	lb/d
Total backwash required	4870	MGD(US)

Costs

Construction and equipment cost	\$96,300,000	\$
Operational labor cost	\$248,000	\$/yr
Maintenance labor cost	\$425,000	\$/yr
Material and supply cost	\$482,000	\$/yr
Chemical cost	\$9,490,000	\$/yr
Energy cost	\$7,740,000	\$/yr
Amortization cost	\$5,580,000	\$/yr

Notes

This unit is not needed. The influent nitrate is less than the allowable effluent nitrate.

Internal Recycle Pumping

Design Information

Average daily pumping rate	365	MGD(US)
Total pumping capacity	730	MGD(US)
Design capacity per pump	26,1	MGD(US)
Number of pumps	5	
Number of batteries	7	
Firm pumping capacity	365	MGD(US)

Quantities

Operation labor required	8340	pers-hrs/yr
Maintenance labor required	5520	pers-hrs/yr
Electrical energy required	12100000	kWh/yr
Volume of earthwork required	126000	cuft
Area of pump building	15800	sqft

Costs

Construction and equipment cost	\$9,890,000	\$
Operational labor cost	\$66,800	\$/yr
Maintenance labor cost	\$47,600	\$/yr
Material and supply cost	\$69,200	\$/yr
Energy cost	\$2,410,000	\$/yr
Amortization cost	\$645,000	\$/yr

Wash Water Pumping

Design Information

Average daily pumping rate	38	MGD(US)
Total pumping capacity	38	MGD(US)
Design capacity per pump	19	MGD(US)
Number of pumps	3	
Number of batteries	1	
Firm pumping capacity	38	MGD(US)

Quantities

Operation labor required	946	pers-hrs/yr
Maintenance labor required	897	pers-hrs/yr
Electrical energy required	1730	kWh/yr

Volume of earthwork required		7600 cuft
Area of pump building		950 sqft
Costs		
Construction and equipment cost	\$588,000	\$
Operational labor cost	\$7,570	\$/yr
Maintenance labor cost	\$7,740	\$/yr
Material and supply cost	\$4,120	\$/yr
Energy cost	\$346	\$/yr
Amortization cost	\$38,400	\$/yr

Desinfeccion por cloro

User Input Data

Chlorination

Description	Value	Units
Contact Time At Peak Flow		30 min
Chlorine Dose		10 mg/L
Influent Coliform Count	10000000	/100mL
Override Design	FALSE	
Volume of Tank	2030000	cuft
Override Database Costs	FALSE	
1 Ton of Chlorine	\$1,610.00	\$
Standard 2000 lb/d Chlorinator	\$37,900.00	\$
Chlorinator		15 years
Structural		40 years

Cost Override

Description	Value	Units
Override Construction Cost	FALSE	
	\$0.00	\$
Override Annual Operational Cost	FALSE	
	\$0.00	\$
Override Annual Maintenance	FALSE	
	\$0.00	\$
Override Annual Materials Cost	FALSE	
	\$0.00	\$
Override Annual Chemical Cost	FALSE	
	\$0.00	\$
Override Annual Energy Cost	FALSE	
	\$0.00	\$
Override Annual Amortization Cost	FALSE	
	\$0.00	\$

Design Output Data


Description	Value	Units
Chlorination		
Design Information		
Volume of tank	2030000	cuft
Average chlorine required	30400	lb/d
Peak chlorine required	60900	lb/d
Influent coliform count	10000000	/100mL
Effluent coliform count	29,2	/100mL
Quantities		
Operational labor required	9790	pers-hrs/yr
Maintenance labor required	11800	pers-hrs/yr
Electrical energy required	269000	kWh/yr
Volume of earthwork required	731000	cuft

Volume of slab concrete requir	204000	cuft
Volume of wall concrete requir	167000	cuft
Number of chlorinators and ev:	4	
Chlorination building area	1440	sqft
Number of chlorine cylinders	457	
Area of chlorine storage buildir	64000	sqft

Costs

Construction and equipment cc	\$10,300,000	\$
Operational labor cost	\$78,300	\$/yr
Maintenance labor cost	\$102,000	\$/yr
Material and supply cost	\$140,000	\$/yr
Chemical cost	\$8,940,000	\$/yr
Energy cost	\$53,700	\$/yr
Amortization cost	\$656,000	\$/yr

FIII/FII-línea de lodos THP



Summary

Equipment Database

Sept 2007, (USA Avg)

Layout Summary

Present Worth	Project	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
\$1,140,000,000	\$402,000,000	\$1,390,000	\$915,000	\$13,000,000	\$6,950,000	\$5,250,000	\$22,600,000

Process Summary

Process	Construction	Operation (/yr)	Maintenance (/yr)	Material (/yr)	Chemical (/yr)	Energy (/yr)	Amortization (/yr)
Espesamiento pro gravedad	\$10.000.000	\$58.200	\$28.600	\$23.500	\$0	\$8.150	\$148.000
Digestion Anaeróbica	\$149.000.000	\$518.000	\$308.000	\$418.000	\$0	\$1.100.000	\$15.000.000
Deshidratación por centrifugas	\$23.000.000	\$438.000	\$547.000	\$0	\$5.420.000	\$3.640.000	\$7.070.000
Disposicion Final	\$5.760.000	\$254.000	\$0	\$12.500.000	\$0	\$0	\$422.000
Espesador de Banda de Gravedad	\$30.500.000	\$120.000	\$31.300	\$0	\$1.530.000	\$494.000	\$0
Other Costs	\$184.000.000	\$0	\$0	\$0	\$0	\$0	\$0

Summary of Costs for Layout

Description	Value	Units
Other Costs		
Quantities		
Required land		8,57 acre
Administration labor hours		0 hr/yr
Laboratory labor hours		0 hr/yr
Costs		
DIRECT COSTS		
Unit process construction cost	\$218,000,000	\$
Profit	\$32,700,000	\$
Total construction costs	\$251,000,000	\$
INDIRECT COSTS		
Miscellaneous cost	\$52,700,000	\$
Legal cost	\$5,020,000	\$
Engineering design fee	\$37,700,000	\$
Inspection cost	\$5,020,000	\$
Contingency	\$25,100,000	\$
Technical	\$5,020,000	\$
Total indirect costs	\$131,000,000	\$
MISC		
Cost of land	\$0	\$
Interest during construction	\$20,900,000	\$
LABOR COSTS		
Administration labor cost	\$0	\$/yr
Laboratory labor cost	\$0	\$/yr
Unit process operation labor cost	\$1,390,000	\$/yr
Unit process maintenance labor cost	\$915,000	\$/yr
Total labor costs	\$2,300,000	\$/yr

PROJECT SUMMARY

Present worth	\$1,140,000,000	\$
Total project cost	\$402,000,000	\$
Total operation labor cost	\$1,390,000	\$/yr
Total maintenance labor cost	\$915,000	\$/yr
Total material cost	\$13,000,000	\$/yr
Total chemical cost	\$6,950,000	\$/yr
Total energy cost	\$5,250,000	\$/yr
Total amortization cost	\$22,600,000	\$/yr

Afluente Canoas (MM)

Tratamiento Preliminar

Design Output Data

Description	Value	Units
Mechanically Cleaned Bar Screen		
Design Information		
Bar size		0,25 in
Bar spacing		0,235 in
Slope of bars from horizontal		15 degrees
Head loss through screen	2,6965E+308	ft
Approach velocity		1,31 ft/s
Average flow through velocity (1,31 ft/s
Maximum flow through velocity		3 ft/s
Screen channel width		45,3 ft
Average channel depth		9,84 ft
Aerated Grit Chamber		
Design Information		
Maximum flow		742 MGD(US)
Average flow		378 MGD(US)

Minimum flow	333 MGD(US)
Temperature	60,8 deg F
Maximum flow through velocity	0,359 ft/s
Average flow through velocity (0,183 ft/s
Size of smallest particle 100%	0,00786 in
Specific gravity of particle	2
Number of units	1
Maximum flow/unit	742 MGD(US)
Width of channel	216 ft
Depth of channel	14,8 ft
Length of channel	216 ft
Settling velocity of particle	0,0513 ft/s
Hydraulic retention time	10 min
Volume of grit	0,113 MGD(US)
Air supply	3 cfm

Coagulación y Floculación

Design Output Data

Description	Value	Units
Chemical Phosphorus Removal		
Design Information		
Chemical used	Equivalent Iron	
Chemical dosage	12 mg/L	
Mass of chemical per year	6300000 kg/yr	
Chemical sludge production	40 mg/L	
Organic sludge production	6,71 mg/L	

Espasamiento pro gravedad

Design Output Data

Description	Value	Units
Gravity Thickening		
Design Information		
Initial concentration	1 %	
Thickened concentration	5 %	
Mass loading	24 lb/(sqft·d)	
Hydraulic loading	218 gal(US)/(sqft·d)	
Hydraulic retention time	11,5 hr	
Number of tanks	7	
Tank volume	441000 cuft	
Depth	14 ft	
Surface area per tank	4500 sqft	
Tank diameter	76 ft	
Quantities		
Amount of sludge generated	572000 lb/d	
Volume of thickened sludge	1,18 MGD(US)	
Operation labor required	7270 pers-hrs/yr	
Maintenance labor required	3430 pers-hrs/yr	
Electrical energy required	40800 kWh/yr	
Volume of earthwork required	401000 cuft	
Slab thickness	11,4 in	
Volume of slab concrete requir	35100 cuft	
Wall thickness	14 in	
Volume of wall concrete requir	31100 cuft	
Costs		
Operational labor cost	\$58,200	\$/yr
Maintenance labor cost	\$28,600	\$/yr
Material and supply cost	\$23,500	\$/yr
Energy cost	\$8,150	\$/yr
Amortization cost	\$148,000	\$/yr

Espesador de Banda de Gravedad

Design Output Data

Description	Value	Units
Gravity Belt Thickener		

Design Information		
Belt filter width		6,56 ft
Number of units		94
Hydraulic loading per unit per r		0,18 MGD(US)
Hydraulic loading required per		33,8 MGD(US)
Final solids content		6 %
Solids capture fraction		0,985
Quantities		
Operation labor required		15000 pers-hrs/yr
Maintenance labor required		3750 pers-hrs/yr
Power		2470000 kWh/yr
Polymer required		1850 lb/d
Dry solids produced		463000 lb/d
Belt filter(s)	\$25,900,000	\$
Building	\$1,540,000	\$
Installation	\$6,490,000	\$
Polymer system	\$9,600,000	\$
Feed pumps	\$2,850,000	\$
Conveyor system	\$6,490,000	\$
Costs		
Operational labor cost	\$120,000	\$/yr
Maintenance labor cost	\$31,300	\$/yr
Chemical cost	\$1,530,000	\$/yr
Energy cost	\$494,000	\$/yr

Sedimentación Primaria

Design Output Data

Description	Value	Units
Primary Clarification		
Design Information		
Surface area	342000	sqft
Surface area per circular clarifi	21400	sqft
Diameter of each circular clarif	165	ft
Number of clarifiers per battery	4	
Number of batteries	4	
Solids loading rate	2,85	lb/(sqft·d)
Hydraulic retention time	2,59	hr
Weir length	49700	ft
Volume of sludge generated	6,86	MGD(US)
Surface overflow rate	2180	gal(US)/(sqft·d)
Quantities		
Operation labor required	8580	pers-hrs/yr
Maintenance labor required	4860	pers-hrs/yr
Electrical energy required	63700	kWh/yr
Volume of earthwork required	5580000	cuft
Slab thickness	11,9	in
Volume of slab concrete requir	374000	cuft
Wall thickness	15	in
Volume of wall concrete requir	183000	cuft
Notes		
Effluent soluble TKN adjusted to satisfy user-specified TKN removal.		
Waste Sludge Pumping		
Design Information		
Average daily pumping rate	6,86	MGD(US)
Total pumping capacity	6,86	MGD(US)
Design capacity per pump	3,43	MGD(US)
Number of pumps	3	
Number of batteries	1	
Firm pumping capacity	6,86	MGD(US)
Quantities		
Operation labor required	564	pers-hrs/yr
Maintenance labor required	479	pers-hrs/yr
Electrical energy required	229000	kWh/yr
Volume of earthwork required	2680	cuft

Area of pump building 335 sqft

Digestion Anaerobica

Design Output Data

Description	Value	Units
Anaerobic Digestion		
Design Information		
Percent VSS destroyed	43	%
Solids concentration in digeste	3,4	%
Detention time	15	d
Digester depth	75	ft
Digester diameter	90	ft
Effective digester volume	7010000	cuft
Number of digesters per batter	14	
Number of primary digesters p	14	
Number of secondary digester:	0	
Number of batteries	1	
Gas produced	29,5	MGD(US)
Heat required	43300000	BTU/hr
Digester gas required	18	MGD(US)
Total natural gas required	0	MGD(US)
Quantities		
Operation labor required	51200	pers-hrs/yr
Maintenance labor required	29100	pers-hrs/yr
Electrical energy required	4360000	kWh/yr
Volume of earthwork required	3130000	cuft
Slab thickness	22,3	in
Volume of slab concrete requir	175000	cuft
Wall thickness	45	in
Volume of wall concrete requir	1240000	cuft
Sidewater depth	75	ft
Surface area/floor of 2-story cc	14100	sqft
Piping size	10	in
Length of total piping system	6200	ft
Number of 90 degree elbows	182	
Number of tees	357	
Number of plug valves	259	
Total dry solids treated	982000	lb/d

Notes

Mass balance based on user input

Alimentacion Escalonada

Design Output Data

Description	Value	Units
BNR System for BIO-P and N Removal		
Design Information		
Design Override Enabled - sizi		
5-Stage Biological Phosphorus		
Design aerobic SRT for nitrifica	5	d
Total reactor SRT	10	d
Design SS	2260	mg/L
Calculated VSS	1390	mg/L
Calculated VSS:TSS ratio	0,613	lb VSS/lb SS
Total volume of anaerobic reac	366000	cuft
Total volume of anoxic reactor:	16000000	cuft
Total volume of aerobic reacto	16400000	cuft
Total volume of all reactors	32800000	cuft
Width of parallel train	262	ft
Sidewater depth	16,4	ft
Number of batteries	1	
Number of parallel trains per b:	24	
Number of anoxic cells within c	3	
Number of aerobic cells within	3	
Anaerobic hydraulic retention t	0,176	hr

Anoxic hydraulic retention time	7,72 hr
Aerobic hydraulic retention time	7,9 hr
Amount of sludge generated	464000 lb/d
Sludge recycle ratio	51 %
Sludge recycle rate	190 MGD(US)
Nitrogen required for biomass	14,9 mg/L
Phosphorus required for biomass	2,98 mg/L
Oxygen required to meet average	944000 lb/d
Air flow required to meet average	277000 scfm
Design air flow	16,9 scfm/1000 cuft
Design air flow	6,65 scfm/ft2

Quantities

Operation labor required	19800 pers-hrs/yr
Maintenance labor required	14900 pers-hrs/yr
Electrical energy required	81000000 kWh/yr
Volume of earthwork required	14200000 cuft
Volume of slab concrete required	4250000 cuft
Volume of wall concrete required	578000 cuft
Handrail length	15400 ft
Number of diffusers per train	5770
Fine bubble diffuser floor coverage	6,12 %
Number of swing arm headers	13
Required mixing power	8100 HP
Total number of mixers	288
Required mixing power per mixer	28,1 HP
Design mixing power per mixer	5 HP
Mixing power for each unaerated	84,4 HP

Notes

Minimum SRT not calculated, design SRT specified by user

Design is based on user specified design overrides - Performance data is assumed to be correct.

WARNING: Anoxic HRT is out of the normal range, consider changing your design override values

WARNING: Anaerobic HRT is out of the normal range, consider changing your design override values

Required hp per mixer exceeds the maximum allowed of 5 hp/mixer, consider increasing number of mixers per tank

Aerobic-Anoxic internal recycle pumps sized for 4x the influent flow

Internal Recycle Pumping

Design Information

Average daily pumping rate	62,2 MGD(US)
Total pumping capacity	62,2 MGD(US)
Design capacity per pump	20,7 MGD(US)
Number of pumps	96
Number of batteries	1
Firm pumping capacity	62,2 MGD(US)

Quantities

Operation labor required	1450 pers-hrs/yr
Maintenance labor required	1230 pers-hrs/yr
Electrical energy required	2060000 kWh/yr
Volume of earthwork required	11400 cuft
Area of pump building	1430 sqft

Notes

Pumps are sized based on an individual battery of internal pumps for each train

Sludge Recycle Pumping

Design Information

Average daily pumping rate	373 MGD(US)
Total pumping capacity	373 MGD(US)
Design capacity per pump	23,3 MGD(US)
Number of pumps	5
Number of batteries	4
Firm pumping capacity	373 MGD(US)

Quantities

Operation labor required	8530 pers-hrs/yr
Maintenance labor required	5630 pers-hrs/yr
Electrical energy required	12300000 kWh/yr
Volume of earthwork required	65200 cuft
Area of pump building	8160 sqft

Deshidratación por centrifugas

Design Output Data

Description	Value	Units
Centrifugation		
Design Information		
Total power required	6290	HP
Power required per unit	196	HP
Excess capacity factor	1,25	
Number of units	32	
Chemical dose	1	% dry wt
Chemicals required	21600	lb/d
Sludge flow	7,24	MGD(US)
Initial solid conc	3,4	%
Operational hours per day	8	hr
Operational days per week	7	d
Quantities		
Number of centrifuges	32	
Power required per unit	196	HP
Area of building	8550	sqft
Dry solids produced	685000	lb/d
Operation labor required	104000	pers-hrs/yr
Maintenance labor required	16700	pers-hrs/yr
Electrical energy required	7280000	kWh/yr
Polymer Feed System		
Quantities		
Polymer dosage	7190	lb/d
Liquid chemical solution fed	0,345	MGD(US)
O&M labor required	46700	pers-hrs/yr
Dry material handling and mixi	3400	pers-hrs/yr
Total operation labor required	50100	pers-hrs/yr

Generacion con motores de combustion biogas

Design Output Data

Description	Value	Units
--------------------	--------------	--------------

Sedimentador Secundario

Design Output Data

Description	Value	Units
Secondary Clarification		
Design Information		
Surface area	509000	sqft
Surface area per circular clarifi	25400	sqft
Diameter of each circular clarif	180	ft
Number of clarifiers per batter	5	
Number of batteries	4	
Solids loading rate	20,9	lb/(sqft·d)
Hydraulic retention time	4,16	hr
Weir length	49200	ft
Volume of wasted sludge	8,06	MGD(US)
Surface overflow rate	733	gal(US)/(sqft·d)
Quantities		
Operation labor required	10900	pers-hrs/yr
Maintenance labor required	6190	pers-hrs/yr
Electrical energy required	80300	kWh/yr
Volume of earthwork required	8660000	cuft
Slab thickness	12,2	in
Volume of slab concrete requir	566000	cuft
Wall thickness	15,5	in
Volume of wall concrete requir	273000	cuft
Waste Sludge Pumping		
Design Information		
Average daily pumping rate	8,06	MGD(US)
Total pumping capacity	8,06	MGD(US)

Design capacity per pump	4,03 MGD(US)
Number of pumps	3
Number of batteries	1
Firm pumping capacity	8,06 MGD(US)
Quantities	
Operation labor required	592 pers-hrs/yr
Maintenance labor required	502 pers-hrs/yr
Electrical energy required	269000 kWh/yr
Volume of earthwork required	2870 cuft
Area of pump building	359 sqft

Secado Térmico

Design Output Data

Description	Value	Units
-------------	-------	-------

Disposicion Final

Design Output Data

Description	Value	Units
Sludge Hauling and Land Filling		
Design Information		
Volume of sludge hauled	0,263 MGD(US)	
Truck capacity	810 cuft	
Round trip time to disposal site	1 hr	
Truck loading time	0,75 hr	
Operational hours per day	8 hr	
Number of trucks required	10	
Distance to disposal site	15,5 miles	
Quantities		
Total sludge volume hauled	0,263 MGD(US)	
Maximum anticipated landfill duration	30 d	
Anticipated sludge storage height	8 ft	
Sludge storage shed area	132000 sqft	
Width of sludge storage shed	257 ft	
Length of sludge storage shed	514 ft	
Volume of earthwork required	336000 cuft	
Volume of slab concrete required	136000 cuft	
Surface area of canopy roof	132000 sqft	
Round trip haul distance	31,1 miles	
Round trips per day per truck	5	
Distance traveled per year per truck	38800 miles	
Sludge hauled	2310000 lb/d	
Operation labor required	31700 pers-hrs/yr	
Landfilling cost	\$11,200,000	\$/yr
Costs		
Construction and equipment cost	\$5,760,000	\$
Operational labor cost	\$254,000	\$/yr
Material and supply cost	\$12,500,000	\$/yr
Amortization cost	\$422,000	\$/yr

Desinfeccion por cloro

Design Output Data

Description	Value	Units
Chlorination		
Design Information		
Volume of tank	2030000 cuft	
Average chlorine required	30400 lb/d	
Peak chlorine required	60900 lb/d	
Influent coliform count	10000000 /100mL	
Effluent coliform count	29,2 /100mL	
Quantities		
Operational labor required	9790 pers-hrs/yr	
Maintenance labor required	11800 pers-hrs/yr	
Electrical energy required	269000 kWh/yr	
Volume of earthwork required	731000 cuft	

Volume of slab concrete requir	204000 cuft
Volume of wall concrete requir	167000 cuft
Number of chlorinators and ev:	4
Chlorination building area	1440 sqft
Number of chlorine cylinders	457
Area of chlorine storage buildir	64000 sqft